				Printed on: 09/09/2024 09:10:09	
Application No:	<b>Consultees Name:</b>	Received:	<b>Comment:</b>	Response:	
2024/2874/P	Shane Rooney	07/09/2024 09:37:19	OBJ	I hike I appreciate the nature of seeking to reduce carbon emissions I must register my objections to this application based on concerns relating to breaches of acoustic criteria I am a leaseholder owner of Flat 11 Dennington Hse and directly impacted by this application The acoustic treatment report is inadequate as it does not reference the fact there are 3 separate units planned The application does not indicate the location of the 3 units adequately The proposed screening is in my opinion (as a MCIOB chartered builder) and Surveying professional inadequate It proposes to offer a vertical screen - without defining materials but does not provide a "cap or lid " to the screening - this will simply act as a funnel with vertical escape of noise and impact by exceeding permissible acoustic levels	
				Should more definitive details and clearer acoustic assessments be made to reflect the 3 number units and demonstrate that vertical acoustic break out is considered this may alleviate concerns	