



secondary DHW flow/return
(2 pipes)
(150 x 150 - approx space
take)
BCWS (1pipe)
(150 x 150 - approx space
take)

Pump and Cold Water
Store -750litre. 1200 x 750

vrf pipes from bc
to distribute to rooms

DHW 2pipes
BCWS 1pipe
VRF 2 pipes (tray)

Within riser to distribute around the
building.
Single riser from basement to roof

vrf pipework from light
well to guest rooms

200 x 100 approx tray
size

primary LTHW
flow/return (2 pipes)
from light well
VRF tray

450x150 approximate
space take.

- GENERAL NOTES**
- DO NOT SCALE FROM THIS DRAWING
 - THE CONTRACTOR MUST VERIFY ALL DIMENSIONS, TOLERANCES AND REFERENCES BEFORE PROCEEDING WITH WORKS
 - ANY DISCREPANCY FOUND BETWEEN THIS DRAWING AND OTHER DOCUMENTS MUST BE REPORTED TO THE CONTRACT ADMINISTRATOR
 - REMOVE THIS DRAWING FROM CURRENCY WHEN REVISED DRAWING IS ISSUED
 - COPYRIGHT OF DESIGNS SHOWN ON THIS DRAWING REMAIN WITH ELEMENTA CONSULTING LTD.
 - THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE SPECIFICATION AND ALL OTHER CONTRACT PROJECT DOCUMENTS
 - THE CONTRACTOR SHALL REFER TO ARCHITECTS OR INTERIOR DESIGN DRAWINGS INCLUDING REFLECTED CEILING PLANS AND OTHER SPECIALIST DRAWINGS FOR SETTING OUT ALL VISIBLE WALL AND CEILING MOUNTED EQUIPMENT

A1 ORIGINAL SIZE DRAWING			
No.	Stage 2	REVISION	DATE
		SAC	06/09/2024

Introba
London Design Studio
150 Holborn
London, EC1N 2NS
t: +44(0)203 6979300
e: hello@introba.com
www.introba.com

CLIENT
Garth Hotel Limited

PROJECT
69 Gower Street

TITLE
Lower Ground Floor - Proposed Mechanical and Domestic Distribution Sketch

DATE CREATED 2024.09.04	SCALE 1:100 @A3
DESIGNED TDB	CHECKED TH
APPROVED SAC	
SUITABILITY CODE S2	SUITABILITY DESCRIPTION Preliminary
DRAWING STATUS Stage 2	
DRAWING No. 10499-IRB-XX-LG-S-Z-5701	REVISION P01