



| RISK ASSESSMENT SUMMARY (RAS) | | | | |
|-------------------------------|----|--|---|--|
| DATE | ΒY | ELEMENT OF DESIGN | RESIDUAL RISK | ACTION - INFORMATION TO REDUCE RISK |
| May'24 | PC | Floor Chasing | Chasing over existing services | Contractor to check with 'cat' detector prior to commencement of any works. |
| May'24 | PC | Over-head working to rafts/ceilings | Contractor falling/objects falling | Contractor to complete high-level work prior to installation of any new cabinets and to use suitable equipment & trained staff |
| May'24 | PC | Asbestos | Disturbing asbestos maybe a health risk. | Contractor to follow the risk assessment . Refer to any method statements for any works required. Wear PPE at all times. |
| May'24 | PC | Installation of signage at high level | Falling from height / injury due to falling objects | Contractor to use suitable access platform and complete method statement for works. wear ppe at all times. |

