



ACOUSTIC TRICKLE VENTS  
REQUIRED TO WINDOWS

First Floor

- GENERAL NOTES:
- This drawing is not an Architects drawing and must not be interpreted as such.
  - Do not scale off this drawing.
  - This drawing must not be used for construction or installation purposed unless stated.
  - All dimensions must be verified on site before completing shop drawings or setting out the work.
  - This drawing to be read in conjunction with the relevant technical specifications.
  - This drawing is to be read in conjunction with Architectural and Structural Engineers drawings.

HW - Hot Water	NRV - Non Return Valve
HL - High Level	S/C - Stop Cock
LL - Low Level	C/V - Control Valve
TA - To Above	DRV - Double Regulating Valve
TB - To Below	LSV - Lock Shield Valve
FA - From Above	IV - Isolation Valve
FB - From Below	STR - Strainer
SS - Stub Stack	HTG - Heating
AAV - Air Admittance Valve	CW - Cold Water
SVP - Soil Vent Pipe	TD - Tundish
DCV - Double Check Valve	F - Flow
SV - Solenoid Valve	R - Return
NRV - Non Return Valve	
PRV - Pressure Relief Valve	
Pipes Hidden H/L	-----
Pipes Hidden L/L	-----
Pipes Exposed H/L	-----
Pipes Solid L/L	-----

P1	UPDATED FOR REDUCED BASEMENT	29/08/2024
P0	PRELIMINARY ISSUE	09/04/2021
REV	MODIFICATIONS	DATE

CARNELL  
WARREN  
ASSOCIATES  
DUKE HOUSE, DUKE STREET, WOKING, GU215BA  
PROJECTS@CARNELLWARREN.CO.UK 01483 730995

PROJECT  
11 - 15 KINGS TERRACE  
LONDON  
NW1 0JP

TITLE  
FIRST FLOOR

CLIENT  
PRIVATE CLIENT

SCALE @ A1  
1:50

DATE  
Apr' '21

DRN  
WW

DRAWING NO.  
1719/PLAN/103

REV.  
P1

Fire Protection Notes:

- **Ductwork:** Where ductwork crossed a protected escape route or passes through a fire rated floor. Ducts shall be provided with fire dampers or for PVC flat duct, approved fire wrap.
- **Soil Pipework:** Where passing through fire rated floors shall be fitting with approved fire collars.
- **Small Services:** ie. Small bore pipework and cabling. All penetrations passing through fire rated structure shall be suitably fire stopped in accordance with approved details.