

45 Warren Street London. London. Opera.

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT

REVISION 01 - 30 OCTOBER 2024



FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT – REV. 01

Audit sheet.

Rev.	Date	Description of change / purpose of issue	Prepared	Reviewed	Authorised
00	01/10/2024	Gateway One Planning Statement	AS	GF	MH
01	30/10/2024	Updated with current drawings	AS	GF	MH

This document has been prepared for Opera only and solely for the purposes expressly defined herein. We owe no duty of care to any third parties in respect of its content. Therefore, unless expressly agreed by us in signed writing, we hereby exclude all liability to third parties, including liability for negligence, save only for liabilities that cannot be so excluded by operation of applicable law. The consequences of climate change and the effects of future changes in climatic conditions cannot be accurately predicted. This report has been based solely on the specific design assumptions and criteria stated herein.

Project number: 19/22398 Document reference: 1923845-HLE-NOT-Gateway One Statement-Rev01.docx

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT – REV. 01

Contents.

Audit sheet.	2
Introduction.	4

Fire statement form.

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT – REV. 01

Introduction.

This document has been prepared for Opera only and solely for the purposes expressly defined herein. We owe no duty of care to any third parties in respect of its content. Therefore, unless expressly agreed by us in signed writing, we hereby exclude all liability to third parties, including liability for negligence, save only for liabilities that cannot be so excluded by operation of applicable law. The consequences of climate change and the effects of future changes in climatic conditions cannot be accurately predicted. This report has been based solely on the specific design assumptions and criteria stated herein

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT – REV. 01

Fire statement form.

Applica	ation information	
1.	Site address line 1	45 Warren Street
	Site address line 2	
	Site address line 3	
	Town	London
	County	
	Site postcode (optional)	W1T 6AG
2.	Description of proposed development including any changes of use (as stated on the application form).	This Fire Strategy Gateway 1 statement has been prepared by Hoare Lea Fire Engineering on behalf of Opera ("the Applicant") in support of planning redevelopment of 45 Warren Street/255 Euston Road ("the Site") within the London Borough of Camden.
		The site is bounded by Warren Street, Euston Road, Fitzroy Street and Conroy Street, and consists of basement car parking, ground to fourth floor of apartment across fifth and sixth floor. The building is considered to be over 18m to the top-occupied floor.
		The existing construction is concrete slab and frame (with a small amount of metal deck). Tiled facing to the Warren Street façade, blockwork facing t panels to Euston Road. Metal frame windows throughout.
		The site benefits from good accessibility to public transport, i.e. bus connections and railway/tube stations.
		The site is not within a conservation area nor does it comprise any listed buildings.
		The project consists of refurbishment of the commercial floors with no proposed works to the residential areas. There will be no change of use. Exter for-like with regard to area), new entrances and canopies, new terrace, and new rooftop plant. No EV parking is currently provided in the basement commercial floors.
3.	Name of persons completing the fire statement (as section 15), relevant qualifications and experience.	All Hoare Lea design projects are headed by chartered engineers with proven experience on a wide range of fire safety consultancy projects. All work and approved by a senior chartered fire engineer. This statement has been produced, reviewed and approved by the following key individuals. The de strategy will be undertaken by the same individuals. - Miller Hannah BEng (Hons), CEng, MIFireE - Director
	Guide: no more than 200 words	 Angela Sanson Misc, BSC (Hons), AlFride - Senior Associate Sam Percy BEng (Hons), Graduate Fire Engineer
4.	State what, if any, consultation has been undertaken on issues relating to the fire safety of the development; and what account has been taken of this.	No formal consultation undertaken to date. The scheme and proposed fire strategy will be developed in detail following this planning application at w fully statutorily consulted.
	Guide: no more than 200 words.	
5.	Site layout plan with block nu	mbering as per building schedule referred to in 6.
	(consistent with other plans d	rawings and information submitted in connection with the application)
Site lay	/out plan is:	
L		

gapplications ("the Applications") for the f commercial office space, and residential to Fitzroy Street and cementitious cladding rnal alterations include replacing windows (likear park nor proposed. < produced at Hoare Lea has been reviewed</pre> esign and development of the fire safety which point the Statutory Authorities will be

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT – REV. 01



HOARE LEA (H.)

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT – REV. 01



HOARE LEA (H.)

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT – REV. 01



HOARE LEA (H.)

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT -REV. 01

Application information

The principles, concepts and approach relating to fire safety that have been applied to the development							
6. Building sched	dule						
a. Block no. as per site layout plan above	 b. Block height (m) Number of storeys excluding those below ground levels Number of storeys including below ground level 	c. proposed use (one per line)	d. location of use within block by storey ^{NOTE [1]}	e. standards relating to fire safety approach applied	f. balconies	g. external wall systems	h. approach to evacuation
N/A	Building is over 18m, less than 30m. 8 storeys (ground, first to sixth, and basement)	Commercial	Basement car parking and plant. Ground to fourth floor commercial office.	Approved Document B Vol. 2.	None (new terrace proposed).	Commercial: New or altered areas proposed to achieve Class A2 or better.	The entire building currently adopts a simultaneous evacuation strategy and will continue to do so after the proposed works.
N/A	Building is over 18m, less than 30m. 7 storeys (ground, first to sixth) and basement.	Residential flats.	Fifth and sixth floor residential flats.	Approved Document B Vol. 1.	None to apartments. External walkway on lower residential floor.	Residential: Not being altered in the proposed works. Existing wall systems considered acceptable as existing situation not being made worse.	The entire building currently adopts a simultaneous evacuation strategy and will continue to do so after the proposed works.

7. Specific technical complexities

Explain any specific technical complexities in terms of fire safety (for example green walls) and/or departures from information building schedule above. Guide: no more than 500 words

This is in existing building over 18m to the top-occupied floor. Due to this building being constructed in the 1970s, there are elements of the building that do not comply with the cu

- The building is not served with a firefighting shaft (i.e. firefighting stair, firefighting lift, ventilated firefighting lobby), however it is provided with a dry fire main. It is noted that the ex required for firefighting stairs). It is proposed that protected lobbies are provided to both stairs on every floor not currently provided with a lobby, and that one lift is provided with b are proposed to be ventilated, either by a 1.0m² AOV located on the façade at every floor or one AOV at the head of each stair. This is therefore considered an improvement on the retained and maintained to BS 9990.
- The building has residential flats over 11m above ground floor (on fifth and sitxth floor), however the building is not provided with sprinkler-protection. Given the relatively works pro a material change of use, sprinklers are not proposed to be provided, based on the residential apartments not being altered in the proposed works and based on the improvement wo that the building currently operates a simultaneous evacuation strategy and will continue to do so after the proposed works; this is considered to improve life safety and means of ese adopted for residential apartments.
- The residential apartments share the same escape stairs as the commercial floors below. This is an existing situation and will be addressed as follows to improve the existing situation
 All floors are served by two escape stairs. Where not already provided, both stairs will be preceded by a protected lobby. Further, any corridors linking both stairs will be divided.
 - separated alternative escape.

i. automatic suppression	j. accessible housing provided			
None currently provided.	N/A			
None currently provided.	None known (residential apartments constructed in 1971 with no known upgrades since).			
urrent Building Regulations; these being:				
xisting stairs are at lea backup/secondary po e existing condition. T	ast 1.1m wide (that ower. Further, both stairs The dry fire main will be			
oposed, that are considered to not constitute orks detailed in this note. It should be noted scape compared to a 'stay-put policy' usually				
): ided by a cross-corridor fire door to ensure				

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT -REV. 01

Application information

- Both stairs will be provided with ventilation, either by a 1.0m² AOV located on the façade at every floor or one AOV at the head of each stair.
- The existing automatic fire detection and alarm system will be upgraded to the current BS 5839-1 with a simultaneous evacuation strategy adopted throughout the building panel provided in the residential area and a fire alarm panel in the commercial area.
- It should be emphasised that the residential areas are not being altered in the proposed works and that the proposed works in the commercial floors are not considered a material ch (windows on the façade) will be like-for-like with respect to areas. The occupant loads of the commercial floors will not be increased and the current fire load is considered to not sign automatic fire detection and alarm system will be upgraded as necessary in line with the current BS 5839-1 (to a minimum Category L2). The dry fire main will be retained and maint smoke ventilated, will be provided with AOV(s).
- Issues which might affect the fire safety of the development Explain how any issues which might affect the fire safety of the development have been addressed. Guide: no more than 500 words

See Item 7.

 Local development document policies relating to fire safety Explain how any policies relating to fire safety in relevant local development documents have been taken into account. Guide: no more than 500 words

The development plan is the Camden Local Plan adopted in July 2017. It is understood that the London Plan will not apply to the proposed works at this location.

Emergency road vehicle access and water supplies for firefighting purposes 10. Fire service site plan Explanation of fire service site plan(s) provided in 14. including what guidance documents have informed the proposed arrangements for fire service access and facilities? Guide: no more than 200 words Access for firefighting appliances is provided around the perimeter of the building (Warren Street, Euston Road, Fitzroy Street and Conway Street). Fire tender access to the dry fire Fitzroy Street. 11. Emergency road vehicle access Specify emergency road vehicle access to the site entrances indicated on the site plan Guide: no more than 200 words Public roads (Warren Street, Euston Road, Fitzroy Street and Conway Street) surround the building allowing good access for emergency vehicles. Is the emergency vehicle tracking route within the site to the siting points for appliances clear and unobstructed? Yes. 12. Siting of fire appliances Guide: no more than 200 words There is fire tender access to the dry fire main inlet within 18m on Euston Road and Fitzroy Street. 13. Suitability of water supply for the scale of development proposed Guide: no more than 200 words Existing public hydrants currently assumed within 100m of the fire main inlet in accordance with relevant guidance as outlined in section 14. A hydrant survey will be completed by locations and suitability. If a hydrant is not within 100m of the building, additional private hydrant(s) will be provided.

(all fire alarm panels being linked – a fire alarm
hange of use. Any alterations to glazing gnificantly increase in the proposed works. The tained to BS 9990. The stairs, not currently
e main inlet is within 18m on Euston Road and
the relevant party to confirm the hydrant

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT – REV. 01

Emergency road vehicle access and water supplies for firefighting purposes

Nature of water supply: Hydrant – public.

Does the proposed development rely on existing hydrants and if so, are they currently usable / operable?

Considered existing given location and existing building. (Note that this will be investigated further as the design develops and additional hydrants will be required).

14. Fire Service site planFire Service site plan is: Inserted in the form (note a formal tracking plan will be provided as the design develops).

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT – REV. 01



HOARE LEA (H.)

FIRE ENGINEERING GATEWAY ONE FIRE STATEMENT – REV. 01

Fire statement completed by	
15. Signature	Melle Hand
	Miller Hannah BEng (Hons), CEng, MIFireE
16. Date	30/10/2024



ANGELA SANSOM

SENIOR ASSOCIATE

+44 20 3668 7244 angelasansom@hoarelea.com

HOARELEA.COM

Western Transit Shed 12-13 stable Street London N1C 4AB England

