

**Sunlight**  
Assessments UK

# Impact Assessment

Site address: 15 Montpelier Grove, London NW5 2XD, UK

Impact address: 14 Montpelier Grove, London NW5 2XD, UK

---

**Designer/Architects STUDIO MCLEOD**

November 2024

Completed by: Milica Mijajlović





## Contents

1.	Introduction.....	3
2.	Methodology .....	4
3.	Standard Survey Limitations.....	5
4.	The Site .....	6
5.	The Proposal.....	7
6.	Impact on the Surrounding Properties .....	8
7.	Assessment Results.....	9
8.	Conclusion .....	10



# 1. Introduction

- 1.1 Sunlight Assessments UK have been instructed to assess the daylight and sunlight of the proposed extension on 15 Montpelier Grove, London NW5 2XD, UK.
- 1.2 The report relates to the proposed Scheme presented by STUDIO MCLEOD, and provides detailed technical support regarding the potential impact to the daylight and sunlight of 14 Montpelier Grove, London NW5 2XD, UK.
- 1.3 The Local Authority will be informed in this by the BRE document entitled 'Site layout planning for daylight and sunlight: a guide to good practice' (BR209 2022). This document is the principal guidance in this area and sets out the methodology for measuring light and recommends what it considers to be permitted or unobtrusive levels of change.
- 1.4 The BRE guidelines are not mandatory, though local planning authorities and planning inspectors will consider the suitability of a proposed scheme for a site within the context of BRE guidance. Consideration will be given to the urban context within which a scheme is located, and the daylight and sunlight will be one of several planning considerations which the local authority will weigh.

## Sources of Information

- 1.5 In the process of compiling this report, the following sources of information have been used:

### **Ordnance Survey Data**

OS Map

**Proposed drawings in Appendix 1**



## 2. Methodology

### Effect on daylight

#### Vertical Sky Component (VSC), to surrounding properties.

BRE guidance summary on daylight:

2.2.23 If any part of a new building or extension, measured in a vertical section perpendicular to a main window wall of an existing building, from the centre of the lowest window, subtends an angle of more than  $25^\circ$  to the horizontal, then the diffuse daylighting of the existing building may be adversely affected. This will be the case if either:

- the VSC measured at the centre of an existing main window is less than 27%, and less than 0.80 times its former value.

the area of the working plane in a room which can receive direct skylight is reduced to less than 0.80 times its former value.

### Effect on sunlight

#### Annual probable sunlight hours (APSH), to surrounding properties.

BRE guidance summary on sunlight:

3.2.13 If a living room of an existing dwelling has a main window facing within  $90^\circ$  of due south, and any part of a new development subtends an angle of more than  $25^\circ$  to the horizontal measured from the centre of the window in a vertical section perpendicular to the window, then the sun lighting of the existing dwelling may be adversely affected. This will be the case if the centre of the window:

- values less than 25% of annual probable sunlight hours and less than 0.80 times its former annual value; or less than 5% of annual probable sunlight hours between 21 September and 21 March and less than 0.80 times its former value during that period.

and also has a reduction in sunlight received over the whole year greater than 4% of annual probable sunlight hours.

### Sun on ground

#### Sunlight on ground (SOG) to surrounding properties.


BRE guidance summary on gardens and amenity spaces:

3.3.17 It is recommended that for it to appear adequately sunlit throughout the year, at least half of a garden or amenity area should receive at least two hours of sunlight on 21 March. If as a result of new development an existing garden or amenity area does not meet the above, and the area that can receive two hours of sun on 21 March is less than 0.80 times its former value, then the loss of sunlight is likely to be noticeable. If a detailed calculation cannot be carried out, it is recommended that the centre of the area should receive at least two hours of sunlight on 21 March



### 3. Standard Survey Limitations

- 3.1 Although we have undertaken as detailed an inspection as possible, we are required by our professional indemnity insurers to notify you that our report is based upon the Standard Terms and Conditions. Our understanding of the proposed development is informed in the drawings in Appendix 1 and information supplied by STUDIO MCLEOD.
- 3.2 In addition to our standard limitations, the following limitations and assumptions also apply:
- Best estimates were made in establishing building use (residential or commercial) and room uses; generally, these were made from external observations and recourse to planning records where available.
  - Where floor plans of surrounding properties were not available, room depths have been assumed from external observations. Where no indicators of room depth were available a standard of 4m, 6m or 8m depths have been used.



## 4. The Site

- 4.1 The site is located at 15 Montpelier Grove, London NW5 2XD, UK.





## 5. The Proposal

### PROPOSED DEVELOPMENT

- 5.1 Our understanding of the proposed rear extension is illustrated in the drawings, located in Appendix 1.
- 5.2 STUDIO MCLEOD has provided floorplans and elevations.







## 6. Impact on the Surrounding Properties

- 6.1 Due to the proximity to the site, we have assessed windows and garden of 14 Montpelier Grove, London NW5 2XD, UK.
- 6.2 This/these residential properties are located adjacent to the Site.
- 6.3 The location of these properties is highlighted in the map:







## 7. Assessment Results

### Vertical Sky Component (VSC)

- 7.1 The results show that the windows and associated room will not experience a noticeable reduction in daylight as defined in the BRE guidance.

### Annual probable sunlight hours (APSH)

- 7.2 The results show that all windows and associated rooms will not experience a noticeable reduction in sunlight as defined in the BRE guidance.
- 7.3 Alternate text

### Garden Amenity (SOG)

- 7.4 The results show that the garden amenity space will not experience a noticeable reduction in sunlight as defined in the BRE guidance.



## 8. Conclusion



- 8.1 The daylight and sunlight to the analysed windows and garden space of 14 Montpelier Grove, London NW5 2XD, UK will not experience a noticeable reduction of daylight and sunlight as set out in the BRE guidelines.
- 8.2 We, therefore, conclude that the effects of the proposed scheme in relation to daylight and sunlight are BRE compliant and we have identified no grounds for rejection of a planning application for this proposal.

# Appendix 1:

Drawings











# Appendix 2:

Window Maps





# Appendix 3:

Technical Analysis



### Vertical Sky Component (VSC) results

Building Name	Floor Name	Window Name	Window Orientation	VSC Existing	VSC Proposed	Pr/Ex	Meets BRE Criteria
14 Montpelier Grove	Ground	W1	96°	35.86	35.85	1	YES
14 Montpelier Grove	Ground	W2	136°	37.07	36.4	0.98	YES
14 Montpelier Grove	Ground	W3	121°	37.62	35.58	0.95	YES
14 Montpelier Grove	Ground	W4	186°	23.58	19.23	0.82	YES
14 Montpelier Grove	Ground	W5	251°	6.28	6.02	0.96	YES
14 Montpelier Grove	Ground	W6	186°	17.79	16.78	0.94	YES
14 Montpelier Grove	Ground	W7	96°	18.8	18.07	0.96	YES



### Annual probable sunlight hours (APSH) results

Building Name	Floor Name	Window Name	Window Orientation	Annual Ex	Annual Pr	Pr/Ex	Meets BRE Criteria
14 Montpelier Grove	Ground	W1	96°	51	51	1	YES
14 Montpelier Grove	Ground	W2	136°	67	66	0.99	YES
14 Montpelier Grove	Ground	W3	121°	65	60	0.92	YES
14 Montpelier Grove	Ground	W4	186°	58	50	0.86	YES
14 Montpelier Grove	Ground	W5	251°	22	20	0.91	YES
14 Montpelier Grove	Ground	W6	186°	37	37	1	YES
14 Montpelier Grove	Ground	W7	96°	37	36	0.97	YES

\* The BRE guidelines state regarding the APSH test “any windows facing within 90 degrees due north does not need to be analysed as there is no expectation of sunlight”.







### Garden Amenity, Sun On Ground (SOG) results

Building Name	Floor Name	Amenity Name	Amenity Area	Lit Area Ex	Lit Area Pr	Existing %	Proposed %	Pr/Ex	Meets BRE Criteria
14 Montpelier Grove	Ground	A1	110.70	67.79	66.12	61%	60%	0.98	YES

Existing garden sunlight map (March 21st)



Proposed Garden sunlight map (March 21st)



End of report.

Sunlight Assessments UK LTD

November 2024

DISCLAIMER:

N.B This report has been prepared by Sunlight Assessments UK LTD as appointed Daylight & Sunlight consultants. This report is intended solely for STUDIO MCLEOD and may contain confidential information. No part or whole of its contents may be disclosed to or relied upon by any Third Party without the express written consent of STUDIO MCLEOD It is accurate as at the time of publication and based upon the information we have been provided with as set out in the report.

