

Application ref: 2022/4469/P
Contact: Kristina Smith
Tel: 020 7974 4986
Email: Kristina.Smith@camden.gov.uk
Date: 5 December 2024

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

West Green Planning
36 Cranleigh Road
London
N15 3AD

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted Subject to a Section 106 Legal Agreement

Address:
340 Gray's Inn Road
London
Camden
WC1X 8BG

Proposal:

Change of use of first floor commercial floorspace to residential use and erection of a two storey (plus basement) extension fronting Britannia Street comprising commercial floorspace at basement and ground floors and 5 residential units at first floor; public realm works

Drawing Nos: 350 (PL03); 050 (PL02); 150 (PL01); 251 (PL02); 151 (PL03); 250 (PL02); 300 (PL01); 201 (PL01); 200 (PL01); 010 (PL01); 100 (PL01); 101 (PL01)

Design and Access Statement, prepared by Ruff Architects; Heritage Assessment prepared by Icen Projects; Daylight & Sunlight Report prepared by Rights of Light Consulting; Air Quality Assessment prepared by Entran; Noise Impact Assessment prepared by Sandy Brown Associates; Energy and Sustainability Report prepared by Pro Sustainability; Overheating Assessment prepared by Pro Sustainability; GLA Carbon Emissions Reporting Spreadsheet prepared by Pro Sustainability; BREEAM Pre-Assessment (Non-Domestic) prepared by Sustain Quality; Arboricultural Impact Assessment prepared by David Archer Associates; Basement Impact Assessment prepared by London Structures Lab; Flood Risk Assessment prepared by London Structures Lab; Drainage Strategy prepared by London Structures Lab.

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans: 350 (PL03); 050 (PL02); 150 (PL01); 251 (PL02); 151 (PL03); 250 (PL02); 300 (PL01); 201 (PL01); 200 (PL01); 010 (PL01); 100 (PL01); 101 (PL01)

Design and Access Statement, prepared by Ruff Architects; Heritage Assessment prepared by Icen Projects; Daylight & Sunlight Report prepared by Rights of Light Consulting; Air Quality Assessment prepared by Entran; Noise Impact Assessment prepared by Sandy Brown Associates; Energy and Sustainability Report prepared by Pro Sustainability; Overheating Assessment prepared by Pro Sustainability; GLA Carbon Emissions Reporting Spreadsheet prepared by Pro Sustainability; BREEAM Pre-Assessment (Non-Domestic) prepared by Sustain Quality; Arboricultural Impact Assessment prepared by David Archer Associates; Basement Impact Assessment prepared by London Structures Lab; Flood Risk Assessment prepared by London Structures Lab; Drainage Strategy prepared by London Structures Lab.

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 and D2 of the London Borough of Camden Local Plan 2017.

- 4 Before the relevant part of the work is begun, detailed drawings, or samples of materials as appropriate, in respect of the following, shall be submitted to and approved in writing by the local planning authority:

a) Details including sections at 1:10 of all windows (including jambs, head and cill), ventilation grills, stall risers, external doors and gates;

b) Plan, elevation and section drawings, including fascia, cornice, pilasters and glazing panels of the new shopfronts at a scale of 1:10;

c) Manufacturer's specification details of all facing materials (to be submitted to the Local Planning Authority) and samples of those materials (to be provided on site).

The relevant part of the works shall be carried out in accordance with the details thus approved and all approved samples shall be retained on site during the course of the works.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy D1 and D2 of the London Borough of Camden Local Plan 2017.

- 5 Prior to the commencement of construction/demolition works on site, tree protection measures shall be installed in accordance with approved Tree Protection Plan. The protection shall then remain in place for the duration of works on site and works should be undertaken in line with the approved arboricultural method statement, unless otherwise agreed in writing by the local authority.

Reason: To ensure that the development will not have an adverse effect on existing trees and in order to maintain the character and amenity of the area in accordance with the requirements of policies A2 and A3 of the London Borough of Camden Local Plan 2017.

- 6 The development shall not be carried out other than in strict accordance with the methodologies, recommendations and requirements of the Basement Impact Assessment (prepared by Ed Moseley ref 1560 rev O4 dated June 2023) and supporting assessments hereby approved, and the confirmation at the detailed design stage that the damage impact assessment would be limited to Burland Category 1.

Reason: To ensure proper consideration of the structural stability of neighbouring buildings and to safeguard the appearance and character of the immediate area in accordance with the requirements of policies D1, D2 and A5 of the London Borough of Camden Local Plan 2017.

- 7 All non-Road mobile Machinery (any mobile machine, item of transportable industrial equipment, or vehicle - with or without bodywork) of net power between 37kW and 560kW used on the site for the entirety of the [demolition and/construction] phase of the development hereby approved shall be required to meet Stage IIIB of EU Directive 97/68/EC. The site shall be registered on the NRMM register for the construction phase of the development.

Reason: To safeguard the amenities of the adjoining occupiers, the area generally and contribution of developments to the air quality of the borough in accordance with the requirements of policies G1, A1, CC1 and CC4 of the London Borough of Camden Local Plan 2017.

- 8 The development hereby approved shall achieve a maximum internal water use of 110litres per person per day. The dwellings shall not be occupied until the Building Regulation optional requirement has been complied with.

Reason: To ensure the development contributes to minimising the need for further water infrastructure in an area of water stress in accordance with Policies CC1, CC2, CC3 of the London Borough of Camden Local Plan 2017.

- 9 Before the development commences, details of secure, covered and accessible cycle storage areas for 10 residential and 13 commercial cycles, plus at least 1 short stay space provision, shall be submitted to and approved by the local planning authority. The approved facilities shall thereafter be provided in their entirety prior to the first occupation of any of the new units, and permanently retained thereafter.

Reason: To ensure the development provides adequate cycle parking facilities in accordance with the requirements of policy T1 of the London Borough of Camden Local Plan 2017.

- 10 Before the development commences, details of the location, design and method of waste storage and removal including recycled materials, shall be submitted to and approved by the local planning authority in writing. The facility as approved shall be provided prior to the first occupation of any of the new units and permanently retained thereafter.

Reason: To ensure that sufficient provision for the storage and collection of waste has been made in accordance with the requirements of policy CC5, A1, A4 and TC4 of the London Borough of Camden Local Plan 2017.

- 11 The external noise level emitted from plant, machinery or equipment at the development hereby approved shall be lower than the typical existing background noise level by at least 10dBA, or by 15dBA where the source is tonal, as assessed according to BS4142:2014 at the nearest and/or most affected noise sensitive premises, with all machinery operating together at maximum capacity.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 12 Prior to use, machinery, plant or equipment at the development shall be mounted with proprietary anti-vibration isolators and fan motors shall be vibration-isolated from the casing and adequately silenced and maintained as such.

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017.

- 13 All habitable rooms exposed to external road traffic noise in excess of 55 dBA Leq 16 hour [free field] during the day [07.00 to 23.00 hours] or 45 dBA Leq 8 hour [free field] at night [23.00 to 07.00 hours] shall be subject to sound insulation measures to ensure that all such rooms achieve an internal noise level of 35 dBA Leq 16 hours during the day and 30 dBA Leq 8 hours at night. The submitted scheme shall ensure that habitable rooms subject to sound insulation measures shall be able to be effectively ventilated without opening

windows. No dwelling shall be occupied until the approved sound insulation and ventilation measures have been installed to that property in accordance with the approved details. The approved measures shall be retained thereafter in perpetuity.

Reason: To ensure that the amenities of future occupiers are protected in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017

- 14 Prior to commencement of the above ground works, details shall be submitted to and approved in writing by the Council, of an enhanced sound insulation value $D_{nT,w}$ and $L'_{nT,w}$ of at least 5dB above the Building Regulations value, for the floor/ceiling structures separating different uses. Approved details shall be implemented prior to occupation of the development and thereafter be permanently retained.

Reason: To ensure that the amenity of occupiers of the development site is not adversely affected by noise in accordance with the requirements of policies A1 and A4 of the London Borough of Camden Local Plan 2017

- 15 Prior to first occupation of the buildings, detailed plans showing the location and extent of photovoltaic cells to be installed on the building shall have been submitted to and approved by the Local Planning Authority in writing. The measures shall include the installation of a meter to monitor the energy output from the approved renewable energy systems. The cells shall be installed in full accordance with the details approved by the Local Planning Authority and permanently retained and maintained thereafter.

Reason: To ensure the development provides adequate on-site renewable energy facilities in accordance with the requirements of Policy G1, CC1 and CC2 of the London Borough of Camden Local Plan 2017.

- 16 Prior to commencement of above-ground development, full details in respect of the green roof in the area indicated on the approved roof plan shall be submitted to and approved by the local planning authority. Details of the green roof provided shall include: species, planting density, substrate and a section at scale 1:20 showing that adequate depth (a minimum of 150mm) is available in terms of the construction and long term viability of the green roof, as well as details of the maintenance programme for green roof. The buildings shall not be occupied until the approved details have been implemented and these works shall be permanently retained and maintained thereafter.

Reason: In order to ensure the development undertakes reasonable measures to take account of biodiversity and the water environment in accordance with policies A3, CC2 and CC3 of the London Borough of Camden Local Plan policies.

- 17 The sustainable drainage system hereby approved shall be installed as part of the development to accommodate all storms up to and including a 1:100 year storm with a 40% provision for climate change, such that flooding does not occur in any part of a building or in any utility plant susceptible to water and to achieve 2l/s run off. The system shall include attenuation tank 5.2m³ and

green roof 108m² as stated in the approved drawings and shall thereafter retained and maintained in accordance with the approved maintenance plan.

Reason: To reduce the rate of surface water run-off from the buildings and limit the impact on the storm-water drainage system in accordance with policies CC2 and CC3 of the London Borough of Camden Local Plan Policies and Policy SI 13 of the London Plan 2021.

- 18 The development hereby approved shall not commence until such time as a suitably qualified chartered engineer with membership of the appropriate professional body has been appointed to inspect, check for compliance with the design (as approved by the local planning authority and building control body) and monitor the critical elements of both permanent and temporary basement construction works throughout their duration. Details of the appointment and the appointee's responsibilities shall be submitted to and approved in writing by the local planning authority prior to the commencement of development. Any subsequent change or reappointment shall be confirmed forthwith for the duration of the construction works.

Reason: To ensure proper consideration of the structural stability of neighbouring buildings and to safeguard the appearance and character of the immediate area in accordance with the requirements of policies D1, D2(if in CA) and A5 of the London Borough of Camden Local Plan 2017.

- 19 The development hereby approved shall be constructed in accordance with the approved energy statement [Energy statement prepared by Pro Sustainability dated 20/09/2022] to achieve an overall reduction of 4% (commercial) and 11% (residential) of carbon dioxide emissions beyond Part L 2021 Building Regulations in line with the energy hierarchy, and a 28% (commercial) and 53% (residential) reduction through renewable technologies. Prior to occupation, evidence demonstrating that the approved measures have been implemented shall be submitted and approved in writing by the Local Planning Authority.

Reason: To ensure the development contributes to minimising the effects of, and can adapt to a changing climate in accordance with policies CC1 and CC2 of the Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 2 All works should be conducted in accordance with the Camden Minimum

Requirements - a copy is available on the Council's website (search for 'Camden Minimum Requirements' at www.camden.gov.uk) or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

- 3 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road closures and suspension of parking bays, will be subject to approval of relevant licence from either the Council's Streetworks Authorisations & Compliance Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444) or where located on the TLRN, Transport for London [<https://tfl.gov.uk/info-for/urban-planning-and-construction/our-land-and-infrastructure/highway-licences>].

Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.

- 4 This proposal may be liable for the Mayor of London's Community Infrastructure Levy (CIL) and the Camden CIL. Both CILs are collected by Camden Council after a liable scheme has started, and could be subject to surcharges for failure to assume liability or submit a commencement notice PRIOR to commencement. We issue formal CIL liability notices setting out how much you may have to pay once a liable party has been established. CIL payments will be subject to indexation in line with construction costs index. You can visit our planning website at www.camden.gov.uk/cil for more information, including guidance on your liability, charges, how to pay and who to contact for more advice. Camden adopted new CIL rates in October 2020 which can be viewed at the above link.
- 5 Your attention is drawn to the fact that there is a separate legal agreement with the Council which relates to the development for which this permission is granted. Information/drawings relating to the discharge of matters covered by the Heads of Terms of the legal agreement should be marked for the attention of the Planning Obligations Officer, Sites Team, Camden Town Hall, Argyle Street, WC1H 8EQ.
- 6 If a revision to the postal address becomes necessary as a result of this development, application under Part 2 of the London Building Acts (Amendment) Act 1939 should be made to the Camden Contact Centre on Tel: 020 7974 4444 or Environment Department (Street Naming & Numbering) Camden Town Hall, Argyle Street, WC1H 8EQ.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with the National Planning Policy Framework. The council publishes its adopted policies online, along with detailed Camden Planning Guidance. It also provides advice on the website for submitting applications and offers a pre-application advice service.

You can find advice about your rights of appeal at:

<https://www.gov.uk/appeal-planning-decision>.

If you submit an appeal against this decision you are now eligible to use the new [submission form](#) (Before you start - Appeal a planning decision - GOV.UK).

Yours faithfully

A handwritten signature in black ink, appearing to read 'DPope', is positioned above the printed name and title of the signatory.

Daniel Pope
Chief Planning Officer