



11 Murray Street, London NW1

Daylight and Sunlight Assessment

Job No: 5937

Issued: December, 2024

Issue No.: 4

Contents

1.0	Introduction.....	3
2.0	Project Summary.....	4
3.0	Methodology.....	5
4.0	Modelling & Data Sources.....	6
5.0	BRE Guidance Targets.....	7
6.0	Window Schedules.....	8
7.0	Daylight Impact Results.....	9
8.0	Sunlight Impact Results.....	10
9.0	Sunlight To Neighbouring Gardens.....	12
10.0	Conclusions.....	13

Document Prepared By:

Document Authorised By:

Ollie Westover

Bernice Waterman

Dated:

Dated:

16.12.24

16.12.24

Signed:

Signed:



This report has been prepared for the exclusive use of the commissioning party and may not be reproduced without prior written permission from T16 Design.

All work has been carried out within the terms of the brief using all reasonable skill, care, and diligence. No liability is accepted by T16 Design for the accuracy of data or opinions provided by others in the preparation of this report, or for any use of this report other than for the purpose for which it was produced.

1.0 Introduction

- 1.1 This daylight and sunlight assessment has been prepared in relation to a planning application for the proposed works at 11 Murray Street, London NW1.
- 1.2 The report assesses the proposals in respect of daylight, sunlight and overshadowing matters, having regard to industry standard guidance.
- 1.3 The report concludes that the proposal is acceptable and in accordance with planning policy requirements in relation to daylight and sunlight.
- 1.4 There is no existing specific National Planning Policy relating to the prospective impacts of developments on daylight and sunlight on their surrounding environment.
- 1.5 However, the NPPF (Para 129) does refer to daylight and sunlight in relation to density, encouraging Local Planning Authorities to take a flexible approach to applying policies and guidance relating to the impacts of proposals where they would otherwise inhibit making effective use of the site.
- 1.6 The BRE Report 'Site Layout Planning for Daylight and Sunlight: A Guide to Good Practice' (3rd Edition, 2022) is the established National guidance to aid the developer to prevent and/or minimise the impact of a new development on the availability of daylight and sunlight in the environs of the site.
- 1.7 It refers in turn to the daylight and sunlight recommendations in BS EN 17037: 2018+A1:2021 (with UK Annexe): 'Daylight in Buildings'
- 1.8 These reference documents are accepted as the authoritative works in the field on daylight, sunlight and overshadowing and the BRE guidance specifically referred to in many Local Authorities' planning policy guidance for daylighting.
- 1.9 The methodology therein has been used in numerous lighting analyses and the standards of permissible reduction in light are accepted as the industry standards.

2.0 Project Summary

- 2.1 The proposal site is 11 Murray Street, NW1, and is occupied by a terraced 3-4 storey building used for residential purposes.
- 2.2 The proposed works involve a small rear extension at ground floor level, along with other associated works.
- 2.3 The impacts of the scheme have been assessed, in line with BRE guidance. Generally, it is the impacts on residential neighbours which are of primary concern.
- 2.4 Further details on the location of the assessed neighbours and their windows are given in Section 5.0.



Site Location

3.0 Methodology

3.1 For this analysis, we have undertaken the most common calculations for the change in daylight and sunlight to existing buildings, as recommended in BRE Digest 209. These are:

- Vertical Sky Component (VSC) for daylight impacts
- Annual Probable Sunlight Hours and Winter Probable Sunlight Hours (WPSH) (APSH) for sunlight impacts

3.2 The VSC method measures the general amount of light available on the outside plane of the window as a ratio (%) of the amount of total unobstructed sky viewable following introduction of visible barriers such as buildings. The maximum value is just under 40% for a completely unobstructed vertical wall.

3.3 The VSC is calculated using computer simulation under a CIE overcast sky. This works by simulating the amount of visible sky from the centre point of each window. It is not affected by orientation and so all potentially affected windows are assessed.

3.4 Annual Probable Sunlight Hours (APSH) and Winter Probable Sun light Hours (WPSH) are a measure of the amount of potential direct sunlight that is available to a given surface. APSH covers sunlight over the whole year and WPSH from September 21st to March 21st.

3.5 The number of total available hours is calculated from a data file in the software, built up over a number of years of actual weather data records.

3.6 Only windows which face within 90° of due south need be assessed for sunlight. This is looked at in Section 8.

3.7 APSH can also be used to assess the impact on external spaces such as gardens. This is looked at in Section 9.

4.0 Modelling & Data Sources

- 4.1 The first stage of the analysis is to create the analysis model of the existing site condition and the proposal. This allows us to analyse the impact of the proposal when compared to the existing condition.
- 4.2 2D drawings have been provided by the design team. These drawings are used to construct a 3D analysis model which is exported into the specialist daylight software. Calculations are then run, for both existing and proposed scenarios.
- 4.3 Sufficient detail is added to the model for the analysis. In accordance with BRE recommendations, trees and foliage have been omitted from the calculations.
- 4.4 Information on the properties has been provided to us by the design team in the form of drawings giving the site as existing and proposed and photographs of the site and surroundings.
- 4.5 Web-based mapping sources and planning records for neighbouring buildings have also been used.

5.0 BRE Guidance Targets

- 5.1 The reference document for this analysis, BRE Digest 209, gives the methodology for undertaking the calculations. It also provides benchmark figures for the acceptable reduction in the daylight on existing properties which might be affected by development.
- 5.2 Specifically, the guidance gives figures for the VSC and APSH, as a percentage reduction that is "permissible" for the effect on existing windows.
- 5.3 It is worth noting the following statement in the Guidance introduction:
- "The guide is intended for building designers and their clients, consultants and planning officials. The advice given here is not mandatory and this document should not be seen as an instrument of planning policy. Its aim is to help rather than constrain the developer.
 - Although it gives numerical guidelines, these should be interpreted flexibly because natural lighting is only one of the many factors in site layout design."
- 5.4 The relevant BRE recommendations for daylight and sunlight are:
- The Vertical Sky Component measured at the centre of a window should be no less than 27%, or if reduced to below this, no less than 0.8 times the former value.
 - The window should receive at least 25% of available annual sunlight hours and more than 5% during the winter months (September 21st to March 21st), or, where this is not the case, 80% of its former value.

6.0 Window Schedules



40 Stratford Villas



12 Murray Street



8/10 Murray Street

7.0 Daylight Impact Results

- 7.1 The Vertical Sky Component has been calculated for each of the 11 assessed windows for both the existing and proposed conditions.
- 7.2 As can be seen in the results below, all windows retain in excess of 80% of their current values with almost no impact on their existing levels of daylight.
- 7.3 The scheme is therefore compliant with BRE recommendations in relation to daylight impacts.

Vertical Sky Component					
Window	Property	Existing VSC	Proposed VSC	% Retained	Meets BRE Guidance?
1	40 Stratford Villas	27.491	27.491	100.00%	Yes
2	40 Stratford Villas	25.837	25.837	100.00%	Yes
3	40 Stratford Villas	30.209	30.209	100.00%	Yes
4	40 Stratford Villas	33.755	33.755	100.00%	Yes
5	12 Murray Street	33.497	33.497	100.00%	Yes
6	12 Murray Street	20.032	19.498	97.34%	Yes
7	12 Murray Street	23.105	23.105	100.00%	Yes
8	10 Murray Street	19.721	19.175	97.23%	Yes
9	10 Murray Street	32.737	32.119	98.11%	Yes
10	10 Murray Street	36.966	36.966	100.00%	Yes
11	8 Murray Street	22.790	22.761	99.87%	Yes

8.0 Sunlight Impact Results

- 8.1 BRE guidance states that only windows which face within 90° of due south need be assessed for sunlight provision. In this instance, 10 windows fall into this category.
- 8.2 The Annual Probable Sunlight Hours has been calculated for each of these windows for both the existing and proposed conditions using the methodology described previously, both over the whole year, and through the "winter months" (September 21st until March 21st)
- 8.3 The BRE guidance states that the sun lighting may be adversely affected if the centre of the window:
- Receives less than 25% of annual hours or less than 5% of winter hours
 - and
 - Receives less than 80% of its current sunlight hours during either period
 - and
 - Has a reduction in sunlight over the whole year greater than 4% of annual probable sunlight hours
- 8.4 It is clear from the wording of the above that all three clauses need to be met to qualify as an adverse impact. Thus, if the window does not meet any one of these criteria, the impact is acceptable.
- 8.5 The results below show that all of the assessed windows retain well in excess of 80% of their existing sunlight levels, over both periods,
- 8.6 The scheme is therefore compliant with BRE guidance in relation to sunlight impacts.

8.0 Sunlight Impact Results

Window	Property	Annual Sunlight Hours			Winter Sunlight Hours			Meets BRE Guidance?
		Ex. Hrs Received (%)	Prop. Hrs Received (%)	% Retained	Ex. Hrs Received (%)	Prop. Hrs Received (%)	% Retained	
1	40 Stratford Villas	54.054	54.054	100.00%	16.909	16.909	100.00%	Yes
2	40 Stratford Villas	40.818	40.818	100.00%	15.593	15.593	100.00%	Yes
3	40 Stratford Villas	62.231	62.231	100.00%	25.849	25.849	100.00%	Yes
4	40 Stratford Villas	65.627	65.627	100.00%	26.681	26.681	100.00%	Yes
5	12 Murray Street	58.212	58.212	100.00%	21.414	21.414	100.00%	Yes
6	12 Murray Street	21.067	20.305	96.38%	3.465	2.923	84.34%	Yes
7	12 Murray Street	27.512	27.512	100.00%	2.564	2.564	100.00%	Yes
8	10 Murray Street	32.363	32.363	100.00%	2.772	2.772	100.00%	Yes
9	10 Murray Street	61.816	61.816	100.00%	20.305	20.305	100.00%	Yes
10	10 Murray Street	63.964	63.964	100.00%	22.453	22.453	100.00%	Yes

9.0 Sunlight To Neighbouring Gardens

- 9.1 The impacts on gardens and amenity spaces are generally assessed using the sunlight hours test, but only on March 21st. The guidance describes a well-lit space as being one which receives at least 2 hours of direct sunlight on this date over 50% of its area.
- 9.2 BRE guidance also uses the "80%" rule for this test, whereby the effects are considered acceptable if the remaining sunlight is in excess of 80% of the existing level. This clause applies if the space is reduced to less than 50% of the area well sunlit.
- 9.3 This assessment has been run for the gardens of the properties nearest to the site as identified below.
- 9.4 As can be seen, the neighbouring gardens retain well in excess of 80% of their existing values and the scheme is therefore compliant with BRE guidance in relation to impacts on gardens and outdoor spaces.



Site Location

Amenity Sunlight Hours

Garden	Existing Area Receiving 2 Hours	Proposed Area Receiving 2 Hours	% Retained	Meets BRE Guidance?
G1	81.11%	81.11%	100.00%	Yes
G2	68.35%	67.51%	98.77%	Yes

10.0 Conclusions

- 10.1 Using industry standard methodology, we have made numerical analyses to ascertain the effects of the proposed development at 11 Murray Street, NW1, and the levels of change in daylight and sunlight for the windows and gardens of the neighbouring properties.
- 10.2 The main criteria used in this analysis to show compliance are the Vertical Sky Component for daylight impacts and Annual and Winter Probable Sunlight Hours for sunlight impacts
- 10.3 As has been shown, the effect on VSC is within the 80% guidance value in all cases.
- 10.4 There will therefore be no adverse impact on neighbouring residents in terms of daylight.
- 10.5 In terms of sunlight, all of the assessed windows retain 80% of their existing sunlight levels, over both periods,
- 10.6 The neighbouring gardens retain well in excess of 80% of their existing area which receives 2 hours or more of sunlight on March 21st.
- 10.7 The scheme is therefore fully compliant with BRE guidance in relation to sunlight impacts.
- 10.8 From a planning perspective therefore, it is the conclusion of this report that the proposed development is entirely acceptable for planning, in daylight and sunlight terms.



T16 Design Ltd.

T: 01206 572452

E: info@t16design.com

W: www.t16design.com

© 2024