

From: Thames Water
Sent: 16 December 2024 16:31
To: Planning
Subject: 3rd Party Planning Application - 2024/5408/P

London Borough of Camden

Our DTS Ref: 75947

Camden Town Hall

Your Ref: 2024/5408/P

Argyle Street

Euston Road

London

WC1H 8EQ

16 December 2024

Dear Sir/Madam

Re: 125, SHAFTESBURY AVENUE, LONDON, WC2H 0JG

Waste Comments

Thames Water would advise that with regard to the COMBINED WASTE WATER network infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

There are public sewers crossing or close to your development. If you're planning significant work near our sewers, it's important that you minimize the risk of damage. We'll need to check that your development doesn't limit repair or maintenance activities, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or

diverting our pipes.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Flarger-scale-developments%2Fplanning-your-development%2Fworking-near-our-pipes&data=05%7C02%7Cplanning%40camden.gov.uk%7C8354dfcf2c794caec68008dd1def148f%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638699634870066500%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIlwLjAuMDAwMCIslAIiOiJXaW4zMilslkFOIjoiTWFPbCIslldUIjoyfQ%3D%3D%7C0%7C%7C%7C&sdata=r%2B6b3EokyafYBGhfOA74FiVdtHjk%2F7PCy868Z%2FwEIs%3D&reserved=0>

Water Comments

Following initial investigations, Thames Water has identified an inability of the existing water network infrastructure to accommodate the needs of this development proposal. As such Thames Water request that the following condition be added to any planning permission. No development shall be occupied until confirmation has been provided that either:- all water network upgrades required to accommodate the additional demand to serve the development have been completed; or - a development and infrastructure phasing plan has been agreed with Thames Water to allow development to be occupied. Where a development and infrastructure phasing plan is agreed no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Reason - The development may lead to no / low water pressure and network reinforcement works are anticipated to be necessary to ensure that sufficient capacity is made available to accommodate additional demand anticipated from the new development” The developer can request information to support the discharge of this condition by visiting the Thames Water website at [thameswater.co.uk/preplanning](https://www.thameswater.co.uk/preplanning). Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (e-mail: devcon.team@thameswater.co.uk) prior to the planning application approval.

Thames Water recommend the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

There are water mains crossing or close to your development. Thames Water do NOT permit the building over or construction within 3m of water mains. If you're planning significant works near our mains (within 3m) we'll need to check that your development doesn't reduce capacity, limit repair or maintenance activities during and after construction, or inhibit the services we provide in any other way. The applicant is advised to read our guide working near or diverting our pipes.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Flarger-scale-developments%2Fplanning-your-development%2Fworking-near-our-pipes&data=05%7C02%7Cplanning%40camden.gov.uk%7C8354dfcf2c794caec68008dd1def148f%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638699634870086121%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIlwLjAuMDAwMCIslIAiOiJXaW4zMilslkFOIjoiTWfPbCIslldUIjoyfQ%3D%3D%7C0%7C%7C%7C&sdata=6jniGgPXBf5JLVpeKkS6W1rJ%2FVZbuSqsQxSQ9A0Vm0k%3D&reserved=0>

The proposed development is located within 15m of a strategic water main. Thames Water request that the following condition be added to any planning permission. No piling shall take place until a piling method statement (detailing the depth and type of piling to be undertaken and the methodology by which such piling will be carried out, including measures to prevent and minimise the potential for damage to subsurface water infrastructure, and the programme for the works) and piling layout plan including all Thames Water clean water assets, the local topography and clearance between the face of the pile to the face of a pipe has been submitted to and approved in writing by the local planning authority in

consultation with Thames Water. Any piling must be undertaken in accordance with the terms of the approved piling method statement and piling layout plan. Reason: The proposed works will be in close proximity to underground water utility infrastructure. Piling has the potential to impact on local underground water utility infrastructure. Please read our guide 'working near our assets' to ensure your workings will be in line with the necessary processes you need to follow if you're considering working above or near our pipes or other structures.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Flarger-scale-developments%2Fplanning-your-development%2Fworking-near-our-pipes&data=05%7C02%7Cplanning%40camden.gov.uk%7C8354dfcf2c794caec68008dd1def148f%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638699634870101461%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIwLjAuMDAwMCIsIlAiOiJXaW4zMilslkFOljoitWFBpCisldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=a%2F3030s3Bvf0x%2F%2FidRMi9eAVgfe15MLtUBKGEjPqDeU%3D&reserved=0>

Should you require further information please contact Thames Water. Email: developer.services@thameswater.co.uk Phone: 0800 009 3921 (Monday to Friday, 8am to 5pm) Write to: Thames Water Developer Services, Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB

Yours faithfully

Development Planning Department

Development Planning,

Thames Water,

Maple Lodge STW,

Denham Way,

Rickmansworth,

WD3 9SQ

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk Visit us online <https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.thameswater.co.uk%2F&data=05%7C02%7Cplanning%40camden.gov.uk%7C8354dfcf2c794caec68008dd1def148f%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638699634870116638%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOilwLjAuMDAwMCIslIAiOiJXaW4zMilslkFOljoiTWFpbCislldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=93lHp%2BWYDSf17Xm1qDMjPak%2Fjschrk%2Be%2B52fNePP%2B04%3D&reserved=0> , follow us on twitter

<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.twitter.com%2Fthameswater&data=05%7C02%7Cplanning%40camden.gov.uk%7C8354dfcf2c794caec68008dd1def148f%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638699634870132164%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOilwLjAuMDAwMCIslIAiOiJXaW4zMilslkFOljoiTWFpbCislldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=sQmanDqzH4UShiJCK6D8yUilntuqvF8vnzWYRKqogHI%3D&reserved=0> or find us on

<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.facebook.com%2Fthameswater&data=05%7C02%7Cplanning%40camden.gov.uk%7C8354dfcf2c794caec68008dd1def148f%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638699634870148595%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOilwLjAuMDAwMCIslIAiOiJXaW4zMilslkFOljoiTWFpbCislldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=5sTgaPpHp1ndBd6xplAfRRlIYcXxT9jNmhJpzm%2BJXrg%3D&reserved=0>. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road,

Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.