

Project name

Bayham Street - Be Green Scenario - Final For Planning

As designed

Date: Thu Dec 12 11:21:36 2024

Administrative information

Building Details

Address: 101 Bayham Street, London,

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.26

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.26

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 404.69The CO₂ emission and primary energy rates of the building must not exceed the targets

The building does not comply with England Building Regulations Part L 2021

| | |
|---|-------------------------|
| Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum | 7.46 |
| Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum | 10.38 |
| Target primary energy rate (TPER), kWh _{PE} /m ² annum | 80.85 |
| Building primary energy rate (BPER), kWh _{PE} /m ² annum | 111.09 |
| Do the building's emission and primary energy rates exceed the targets? | BER > TER BPER > TPER |

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

| Fabric element | U _a -Limit | U _a -Calc | U _i -Calc | First surface with maximum value |
|--------------------------------------|-----------------------|----------------------|----------------------|--|
| Walls* | 0.26 | 1.15 | 1.15 | FN000000:Surf[0] |
| Floors | 0.18 | 0.3 | 0.3 | FN00018E:Surf[0] |
| Pitched roofs | 0.16 | - | - | No pitched roofs in building |
| Flat roofs | 0.18 | 0.18 | 0.18 | SP000004:Surf[0] |
| Windows** and roof windows | 1.6 | 2.58 | 5 | SP000020:Surf[1] |
| Rooflights*** | 2.2 | 3.4 | 3.4 | SP00000C:Surf[5] |
| Personnel doors [^] | 1.6 | 0.32 | 1.6 | 00000000:Surf[2] |
| Vehicle access & similar large doors | 1.3 | - | - | No vehicle access doors in building |
| High usage entrance doors | 3 | - | - | No high usage entrance doors in building |

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.

[^] For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

| Air permeability | Limiting standard | This building |
|--|-------------------|---------------|
| m ³ /(h.m ²) at 50 Pa | 8 | 25 |

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

| | |
|---|------|
| Whole building lighting automatic monitoring & targeting with alarms for out-of-range values | NO |
| Whole building electric power factor achieved by power factor correction | <0.9 |

1- Electric Heating with Natural Vent

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 1 | - | 0.2 | - | - |
| Standard value | N/A | N/A | N/A | N/A | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | NO |

2- ASHP (Heating and Cooling) + MVHR_AHU1

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4.07 | 6.63 | 0 | 1.98 | 0.73 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | NO |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

3- Electric Heating with MVHR

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 1 | - | 0.2 | - | 0.79 |
| Standard value | N/A | N/A | N/A | N/A | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | NO |

4- ASHP (Heating and Cooling) + MVHR_AHU2

| | Heating efficiency | Cooling efficiency | Radiant efficiency | SFP [W/(l/s)] | HR efficiency |
|--|--------------------|--------------------|--------------------|---------------|---------------|
| This system | 4.07 | 6.63 | 0 | 1.83 | 0.77 |
| Standard value | 2.5* | N/A | N/A | 2^ | N/A |
| Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system | | | | | NO |
| * Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps. | | | | | |
| ^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components. | | | | | |

1- DHW

| | Water heating efficiency | Storage loss factor [kWh/litre per day] |
|-----------------------|--------------------------|---|
| This building | 1 | 0.005 |
| Standard value | 1 | N/A |

Zone-level mechanical ventilation, exhaust, and terminal units

| ID | System type in the Approved Documents |
|----|---|
| A | Local supply or extract ventilation units |
| B | Zonal supply system where the fan is remote from the zone |
| C | Zonal extract system where the fan is remote from the zone |
| D | Zonal balanced supply and extract ventilation system |
| E | Local balanced supply and extract ventilation units |
| F | Other local ventilation units |
| G | Fan assisted terminal variable air volume units |
| H | Fan coil units |
| I | Kitchen extract with the fan remote from the zone and a grease filter |

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

| Zone name | SFP [W/(l/s)] | | | | | | | | | | HR efficiency | |
|-------------------------------|-------------------|-----|-----|-----|---|-----|-----|-----|---|---|---------------|----------|
| | ID of system type | A | B | C | D | E | F | G | H | I | Zone | Standard |
| Standard value | 0.3 | 1.1 | 0.5 | 2.3 | 2 | 0.5 | 0.5 | 0.4 | 1 | | | |
| 02_Storage | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 02_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 02_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 01_Storage | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 01_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 01_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 03_Storage | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 03_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 03_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 04_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 04_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 00_Storage | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 00_WC Lobby | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 00_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 00_Comms | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 00_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 00_Office | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 00_Office | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 00_BMS Office | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 00_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 00_Corridor | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 00_Entrance Lobby / Reception | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 00_Waiting Area | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| -01_WC | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| -01_Showers/Lockers | - | - | - | 1.3 | - | - | - | - | - | - | - | N/A |
| 01_Office | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 02_Office | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 04_Office | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |
| 03_Office | - | - | - | - | - | - | - | 0.2 | - | - | - | N/A |

| Zone name | General lighting and display lighting | General luminaire | Display light source | |
|-----------------|---------------------------------------|-------------------|----------------------|-----------------------------------|
| | Standard value | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] |
| | 95 | 80 | 0.3 | |
| 01_Stairs | 100 | - | - | |
| 01_Stairs | 100 | - | - | |
| 02_Stairs | 100 | - | - | |
| 02_Stairs Lobby | 100 | - | - | |
| 02_Storage | 100 | - | - | |
| 02_WC | 100 | - | - | |
| 02_WC | 100 | - | - | |
| 01_Storage | 100 | - | - | |
| 01_WC | 100 | - | - | |
| 01_WC | 100 | - | - | |

| General lighting and display lighting | | General luminaire | Display light source | |
|---------------------------------------|-----------------------|-------------------|----------------------|-----------------------------------|
| Zone name | | Efficacy [lm/W] | Efficacy [lm/W] | Power density [W/m ²] |
| | Standard value | 95 | 80 | 0.3 |
| 03_Stairs | | 100 | - | - |
| 03_Stairs Lobby | | 100 | - | - |
| 03_Storage | | 100 | - | - |
| 03_WC | | 100 | - | - |
| 03_WC | | 100 | - | - |
| 04_Stairs | | 100 | - | - |
| 04_WC | | 100 | - | - |
| 04_WC | | 100 | - | - |
| 01_Stairs | | 100 | - | - |
| 02_Stairs | | 100 | - | - |
| 03_Stairs | | 100 | - | - |
| 04_Stairs | | 100 | - | - |
| 00_Storage | | 100 | - | - |
| 00_Technick Room | | 100 | - | - |
| 00_Storage | | 100 | - | - |
| 00_WC Lobby | | 100 | - | - |
| 00_WC | | 100 | - | - |
| 00_Comms | | 100 | - | - |
| 00_WC | | 100 | - | - |
| 00_Stairs | | 100 | - | - |
| 00_Office | | 100 | - | - |
| 00_LV Switch Room | | 100 | - | - |
| 00_Office | | 100 | - | - |
| 00_BMS Office | | 100 | - | - |
| 00_WC | | 100 | - | - |
| 00_Corridor | | 100 | - | - |
| 00_Entrance Lobby / Reception | | 100 | 100 | 1.35 |
| 00_Waiting Area | | 100 | - | - |
| 00_Bin Store | | 100 | - | - |
| 00_Stairs | | 100 | - | - |
| 00_Substation | | 100 | - | - |
| -01_Bike Storage | | 100 | - | - |
| -01_Lift Lobby | | 100 | - | - |
| -01_Plant Room | | 100 | - | - |
| -01_Stairs | | 100 | - | - |
| -01_WC | | 100 | - | - |
| -01_Showers/Lockers | | 100 | - | - |
| 00_Entrance | | 100 | - | - |
| 01_Office | | 100 | - | - |
| 02_Office | | 100 | - | - |
| 04_Office | | 100 | - | - |
| 03_Office | | 100 | - | - |

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

| Zone | Solar gain limit exceeded? (%) | Internal blinds used? |
|-------------------------------|--------------------------------|-----------------------|
| 02_Storage | N/A | N/A |
| 01_Storage | N/A | N/A |
| 03_Storage | N/A | N/A |
| 00_Storage | NO (-100%) | NO |
| 00_Comms | N/A | N/A |
| 00_Office | YES (+103.4%) | NO |
| 00_Office | YES (+66.7%) | NO |
| 00_BMS Office | N/A | N/A |
| 00_Corridor | N/A | N/A |
| 00_Entrance Lobby / Reception | YES (+24.6%) | NO |
| 00_Waiting Area | YES (+47.4%) | NO |
| 01_Office | YES (+16.3%) | NO |
| 02_Office | YES (+24.5%) | NO |
| 04_Office | YES (+86.4%) | NO |
| 03_Office | YES (+12.2%) | NO |

Regulation 25A: Consideration of high efficiency alternative energy systems

| | |
|---|-----------|
| Were alternative energy systems considered and analysed as part of the design process? | NO |
| Is evidence of such assessment available as a separate submission? | NO |
| Are any such measures included in the proposed design? | NO |

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

| | Actual | Notional |
|---|---------|----------|
| Floor area [m ²] | 2664.9 | 2664.9 |
| External area [m ²] | 2940.7 | 2940.7 |
| Weather | LON | LON |
| Infiltration [m ³ /hm ² @ 50Pa] | 25 | 3 |
| Average conductance [W/K] | 2606.87 | 1817.11 |
| Average U-value [W/m ² K] | 0.89 | 0.62 |
| Alpha value* [%] | 24.95 | 10 |

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

% Area Building Type

| | |
|------------|---|
| | Retail/Financial and Professional Services |
| | Restaurants and Cafes/Drinking Establishments/Takeaways |
| 100 | Offices and Workshop Businesses |
| | General Industrial and Special Industrial Groups |
| | Storage or Distribution |
| | Hotels |
| | Residential Institutions: Hospitals and Care Homes |
| | Residential Institutions: Residential Schools |
| | Residential Institutions: Universities and Colleges |
| | Secure Residential Institutions |
| | Residential Spaces |
| | Non-residential Institutions: Community/Day Centre |
| | Non-residential Institutions: Libraries, Museums, and Galleries |
| | Non-residential Institutions: Education |
| | Non-residential Institutions: Primary Health Care Building |
| | Non-residential Institutions: Crown and County Courts |
| | General Assembly and Leisure, Night Clubs, and Theatres |
| | Others: Passenger Terminals |
| | Others: Emergency Services |
| | Others: Miscellaneous 24hr Activities |
| | Others: Car Parks 24 hrs |
| | Others: Stand Alone Utility Block |

Energy Consumption by End Use [kWh/m²]

| | Actual | Notional |
|----------------|--------------|-------------|
| Heating | 19.27 | 6.48 |
| Cooling | 2.92 | 2.1 |
| Auxiliary | 15.74 | 6.83 |
| Lighting | 7.12 | 11.52 |
| Hot water | 31.77 | 28.66 |
| Equipment* | 42.95 | 42.95 |
| TOTAL** | 76.82 | 55.6 |

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

| | Actual | Notional |
|------------------------------|-------------|-------------|
| Photovoltaic systems | 4.14 | 0.92 |
| Wind turbines | 0 | 0 |
| CHP generators | 0 | 0 |
| Solar thermal systems | 0 | 0 |
| <i>Displaced electricity</i> | <i>4.14</i> | <i>0.92</i> |

Energy & CO₂ Emissions Summary

| | Actual | Notional |
|---|--------|----------|
| Heating + cooling demand [MJ/m ²] | 203.9 | 86.82 |
| Primary energy [kWh _{PE} /m ²] | 111.09 | 80.85 |
| Total emissions [kg/m ²] | 10.38 | 7.46 |

HVAC Systems Performance

| System Type | Heat dem MJ/m2 | Cool dem MJ/m2 | Heat con kWh/m2 | Cool con kWh/m2 | Aux con kWh/m2 | Heat SSEFF | Cool SSEER | Heat gen SEFF | Cool gen SEER |
|--|-------------------|-------------------|--------------------|--------------------|-------------------|---------------|---------------|------------------|------------------|
| [ST] Fan coil systems, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 349.1 | 45.5 | 26.5 | 2.6 | 22 | 3.65 | 4.81 | 4.07 | 6.63 |
| Notional | 42.3 | 66.3 | 4.2 | 4 | 9.4 | 2.78 | 4.63 | ---- | ---- |
| [ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 218.3 | 0 | 75.8 | 0 | 5.8 | 0.8 | 0 | 1 | 0 |
| Notional | 114.5 | 0 | 22.6 | 0 | 1.5 | 1.41 | 0 | ---- | ---- |
| [ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 291.5 | 0 | 101.2 | 0 | 0 | 0.8 | 0 | 1 | 0 |
| Notional | 124 | 0 | 24.4 | 0 | 0 | 1.41 | 0 | ---- | ---- |
| [ST] Fan coil systems, [HS] ASHP, [HFT] Electricity, [CFT] Electricity | | | | | | | | | |
| Actual | 116.6 | 68 | 8.9 | 3.9 | 18.7 | 3.65 | 4.86 | 4.07 | 6.63 |
| Notional | 49.3 | 39.4 | 4.9 | 2.4 | 8.3 | 2.78 | 4.63 | ---- | ---- |
| [ST] No Heating or Cooling | | | | | | | | | |
| Actual | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Notional | 0 | 0 | 0 | 0 | 0 | 0 | 0 | ---- | ---- |

Key to terms

| | |
|-------------------|---|
| Heat dem [MJ/m2] | = Heating energy demand |
| Cool dem [MJ/m2] | = Cooling energy demand |
| Heat con [kWh/m2] | = Heating energy consumption |
| Cool con [kWh/m2] | = Cooling energy consumption |
| Aux con [kWh/m2] | = Auxiliary energy consumption |
| Heat SSEFF | = Heating system seasonal efficiency (for notional building, value depends on activity glazing class) |
| Cool SSEER | = Cooling system seasonal energy efficiency ratio |
| Heat gen SSEFF | = Heating generator seasonal efficiency |
| Cool gen SSEER | = Cooling generator seasonal energy efficiency ratio |
| ST | = System type |
| HS | = Heat source |
| HFT | = Heating fuel type |
| CFT | = Cooling fuel type |