

Project name

Bayham Street - Be Lean Scenario - Final
For Planning

As designed

Date: Thu Dec 12 10:50:02 2024

Administrative information

Building Details

Address: 101 Bayham Street, London,

Certifier details

Name: Name

Telephone number: Phone

Address: Street Address, City, Postcode

Certification tool

Calculation engine: Apache

Calculation engine version: 7.0.26

Interface to calculation engine: IES Virtual Environment

Interface to calculation engine version: 7.0.26

BRUKL compliance module version: v6.1.e.1

Foundation area [m²]: 404.69The CO₂ emission and primary energy rates of the building must not exceed the targets

The building does not comply with England Building Regulations Part L 2021

Target CO ₂ emission rate (TER), kgCO ₂ /m ² annum	7.46
Building CO ₂ emission rate (BER), kgCO ₂ /m ² annum	11.94
Target primary energy rate (TPER), kWh _{PE} /m ² annum	80.86
Building primary energy rate (BPER), kWh _{PE} /m ² annum	127.86
Do the building's emission and primary energy rates exceed the targets?	BER > TER BPER > TPER

The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U _a -Limit	U _a -Calc	U _i -Calc	First surface with maximum value
Walls*	0.26	1.15	1.15	FN000000:Surf[0]
Floors	0.18	0.3	0.3	FN00018E:Surf[0]
Pitched roofs	0.16	-	-	No pitched roofs in building
Flat roofs	0.18	0.18	0.18	SP000004:Surf[0]
Windows** and roof windows	1.6	2.58	5	SP000020:Surf[1]
Rooflights***	2.2	3.4	3.4	SP00000C:Surf[5]
Personnel doors^	1.6	0.32	1.6	00000000:Surf[2]
Vehicle access & similar large doors	1.3	-	-	No vehicle access doors in building
High usage entrance doors	3	-	-	No high usage entrance doors in building

U_a-Limit = Limiting area-weighted average U-values [W/(m²K)]U_i-Calc = Calculated maximum individual element U-values [W/(m²K)]U_a-Calc = Calculated area-weighted average U-values [W/(m²K)]

* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

** Display windows and similar glazing are excluded from the U-value check. *** Values for rooflights refer to the horizontal position.

^ For fire doors, limiting U-value is 1.8 W/m²K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m ³ /(h.m ²) at 50 Pa	8	25

Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	NO
Whole building electric power factor achieved by power factor correction	<0.9

1- Electric Heating with Natural Vent

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	1	-	0.2	-	-
Standard value	N/A	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO

2- ASHP (Heating and Cooling) + MVHR_AHU2

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	2.5	5	0	1.83	0.77
Standard value	2.5*	N/A	N/A	2^	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

3- Electric Heating with MVHR

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	1	-	0.2	-	0.79
Standard value	N/A	N/A	N/A	N/A	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO

4- ASHP (Heating and Cooling) + MVHR_AHU1

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
This system	2.5	5	0	1.98	0.73
Standard value	2.5*	N/A	N/A	2^	N/A
Automatic monitoring & targeting with alarms for out-of-range values for this HVAC system					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

1- DHW

	Water heating efficiency	Storage loss factor [kWh/litre per day]
This building	1	0.005
Standard value	1	N/A

Zone-level mechanical ventilation, exhaust, and terminal units

ID	System type in the Approved Documents
A	Local supply or extract ventilation units
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal balanced supply and extract ventilation system
E	Local balanced supply and extract ventilation units
F	Other local ventilation units
G	Fan assisted terminal variable air volume units
H	Fan coil units
I	Kitchen extract with the fan remote from the zone and a grease filter

NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I		
	Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1	Zone	Standard
02_Storage		-	-	-	-	-	-	-	0.2	-	-	N/A
02_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
02_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
01_Storage		-	-	-	-	-	-	-	0.2	-	-	N/A
01_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
01_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
03_Storage		-	-	-	-	-	-	-	0.2	-	-	N/A
03_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
03_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
04_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
04_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
00_Storage		-	-	-	-	-	-	-	0.2	-	-	N/A
00_WC Lobby		-	-	-	1.3	-	-	-	-	-	-	N/A
00_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
00_Comms		-	-	-	-	-	-	-	0.2	-	-	N/A
00_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
00_Office		-	-	-	-	-	-	-	0.2	-	-	N/A
00_Office		-	-	-	-	-	-	-	0.2	-	-	N/A
00_BMS Office		-	-	-	-	-	-	-	0.2	-	-	N/A
00_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
00_Corridor		-	-	-	-	-	-	-	0.2	-	-	N/A
00_Entrance Lobby / Reception		-	-	-	-	-	-	-	0.2	-	-	N/A
00_Waiting Area		-	-	-	-	-	-	-	0.2	-	-	N/A
-01_WC		-	-	-	1.3	-	-	-	-	-	-	N/A
-01_Showers/Lockers		-	-	-	1.3	-	-	-	-	-	-	N/A
01_Office		-	-	-	-	-	-	-	0.2	-	-	N/A
02_Office		-	-	-	-	-	-	-	0.2	-	-	N/A
04_Office		-	-	-	-	-	-	-	0.2	-	-	N/A
03_Office		-	-	-	-	-	-	-	0.2	-	-	N/A

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m²]
	Standard value	95	80	0.3
01_Stairs		100	-	-
01_Stairs		100	-	-
02_Stairs		100	-	-
02_Stairs Lobby		100	-	-
02_Storage		100	-	-
02_WC		100	-	-
02_WC		100	-	-
01_Storage		100	-	-
01_WC		100	-	-
01_WC		100	-	-

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m²]
	Standard value	95	80	0.3
03_Stairs		100	-	-
03_Stairs Lobby		100	-	-
03_Storage		100	-	-
03_WC		100	-	-
03_WC		100	-	-
04_Stairs		100	-	-
04_WC		100	-	-
04_WC		100	-	-
01_Stairs		100	-	-
02_Stairs		100	-	-
03_Stairs		100	-	-
04_Stairs		100	-	-
00_Storage		100	-	-
00_Technick Room		100	-	-
00_Storage		100	-	-
00_WC Lobby		100	-	-
00_WC		100	-	-
00_Comms		100	-	-
00_WC		100	-	-
00_Stairs		100	-	-
00_Office		100	-	-
00_LV Switch Room		100	-	-
00_Office		100	-	-
00_BMS Office		100	-	-
00_WC		100	-	-
00_Corridor		100	-	-
00_Entrance Lobby / Reception		100	100	1.35
00_Waiting Area		100	-	-
00_Bin Store		100	-	-
00_Stairs		100	-	-
00_Substation		100	-	-
-01_Bike Storage		100	-	-
-01_Lift Lobby		100	-	-
-01_Plant Room		100	-	-
-01_Stairs		100	-	-
-01_WC		100	-	-
-01_Showers/Lockers		100	-	-
00_Entrance		100	-	-
01_Office		100	-	-
02_Office		100	-	-
04_Office		100	-	-
03_Office		100	-	-

The spaces in the building should have appropriate passive control measures to limit solar gains in summer

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
02_Storage	N/A	N/A
01_Storage	N/A	N/A
03_Storage	N/A	N/A
00_Storage	N/A	N/A
00_Comms	N/A	N/A
00_Office	YES (+103.5%)	NO
00_Office	YES (+66.7%)	NO
00_BMS Office	N/A	N/A
00_Corridor	N/A	N/A
00_Entrance Lobby / Reception	YES (+24.7%)	NO
00_Waiting Area	YES (+47.3%)	NO
01_Office	YES (+16.2%)	NO
02_Office	YES (+24.4%)	NO
04_Office	YES (+66.4%)	NO
03_Office	YES (+12.1%)	NO

Regulation 25A: Consideration of high efficiency alternative energy systems

Were alternative energy systems considered and analysed as part of the design process?	NO
Is evidence of such assessment available as a separate submission?	NO
Are any such measures included in the proposed design?	NO

Technical Data Sheet (Actual vs. Notional Building)

Building Global Parameters

	Actual	Notional
Floor area [m ²]	2664.9	2664.9
External area [m ²]	2940.7	2940.7
Weather	LON	LON
Infiltration [m ³ /hm ² @ 50Pa]	25	3
Average conductance [W/K]	2606.95	1817.11
Average U-value [W/m ² K]	0.89	0.62
Alpha value* [%]	24.95	10

* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

Building Use

% Area	Building Type
	Retail/Financial and Professional Services
	Restaurants and Cafes/Drinking Establishments/Takeaways
100	Offices and Workshop Businesses
	General Industrial and Special Industrial Groups
	Storage or Distribution
	Hotels
	Residential Institutions: Hospitals and Care Homes
	Residential Institutions: Residential Schools
	Residential Institutions: Universities and Colleges
	Secure Residential Institutions
	Residential Spaces
	Non-residential Institutions: Community/Day Centre
	Non-residential Institutions: Libraries, Museums, and Galleries
	Non-residential Institutions: Education
	Non-residential Institutions: Primary Health Care Building
	Non-residential Institutions: Crown and County Courts
	General Assembly and Leisure, Night Clubs, and Theatres
	Others: Passenger Terminals
	Others: Emergency Services
	Others: Miscellaneous 24hr Activities
	Others: Car Parks 24 hrs
	Others: Stand Alone Utility Block

Energy Consumption by End Use [kWh/m²]

	Actual	Notional
Heating	25.49	6.48
Cooling	3.68	2.1
Auxiliary	15.65	6.83
Lighting	7.12	11.52
Hot water	31.77	28.66
Equipment*	42.95	42.95
TOTAL **	83.7	55.6

* Energy used by equipment does not count towards the total for consumption or calculating emissions.

** Total is net of any electrical energy displaced by CHP generators, if applicable.

Energy Production by Technology [kWh/m²]

	Actual	Notional
Photovoltaic systems	0	0.92
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>0</i>	<i>0.92</i>

Energy & CO₂ Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m ²]	202.77	86.82
Primary energy [kWh _{PE} /m ²]	127.86	80.86
Total emissions [kg/m ²]	11.94	7.46

HVAC Systems Performance										
System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER	
[ST] Fan coil systems, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
	Actual	350.3	45.2	43.6	3.4	22	2.23	3.68	2.5	5
	Notional	41.3	66.4	4.1	4	9.4	2.78	4.63	----	----
[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity										
	Actual	218.5	0	75.9	0	5.8	0.8	0	1	0
	Notional	114.5	0	22.6	0	1.5	1.41	0	----	----
[ST] Other local room heater - unfanned, [HS] Direct or storage electric heater, [HFT] Electricity, [CFT] Electricity										
	Actual	292	0	101.4	0	0	0.8	0	1	0
	Notional	124	0	24.4	0	0	1.41	0	----	----
[ST] Fan coil systems, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
	Actual	117.7	65.2	14.8	4.9	18.6	2.21	3.72	2.5	5
	Notional	49.5	39.4	4.9	2.4	8.3	2.78	4.63	----	----
[ST] No Heating or Cooling										
	Actual	0	0	0	0	0	0	0	0	0
	Notional	0	0	0	0	0	0	0	----	----

Key to terms

Heat dem [MJ/m2]	= Heating energy demand
Cool dem [MJ/m2]	= Cooling energy demand
Heat con [kWh/m2]	= Heating energy consumption
Cool con [kWh/m2]	= Cooling energy consumption
Aux con [kWh/m2]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type