


Pell Frischmann		Page 5
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:08 File 104878 Phase 1A.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

2 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor	1.000	Manhole Headloss Coeff (Global)	0.500	MADD Factor * 10m <sup>3</sup> /ha Storage	2.000
Hot Start (mins)	0	Foul Sewage per hectare (l/s)	0.000	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Additional Flow - % of Total Flow	0.000	Flow per Person per Day (l/per/day)	0.000


Number of Input Hydrographs	0	Number of Offline Controls	0	Number of Time/Area Diagrams	0
Number of Online Controls	1	Number of Storage Structures	1	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FEH	D3 (1km)	0.234
FEH Rainfall Version	1999	E (1km)	0.332
Site Location	GB 526100 184450 TQ 26100 84450	F (1km)	2.519
C (1km)	-0.025	Cv (Summer)	0.750
D1 (1km)	0.330	Cv (Winter)	0.840
D2 (1km)	0.277		


Margin for Flood Risk Warning (mm)	300.0	DVD Status	ON
Analysis Timestep	2.5 Second Increment (Extended)	Inertia Status	ON
DTS Status			OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440, 2160, 2880, 4320, 5760, 7200, 8640, 10080
Return Period(s) (years)	2, 30, 100
Climate Change (%)	0, 0, 40

Pell Frischmann		Page 6
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:08 File 104878 Phase 1A.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	


2 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	Name	Event	US/MH US/CL (m)	Water Surcharged			Flooded		Pipe Flow / Overflow (1/s)	Pipe Flow (1/s)	Status
				Level (m)	Depth (m)	Volume (m <sup>3</sup> )	Flow / Cap. (1/s)	Overflow (1/s)			

Pell Frischmann		Page 7
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:08 File 104878 Phase 1A.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

2 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	US/MH Name	Event	US/CL (m)	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m <sup>3</sup> )	Flow / Cap.	Overflow (l/s)	Pipe	Status
									Flow (l/s)	
S1.000	S1	15 minute 2 year Winter I+0%	49.400	48.088	-0.212	0.000	0.18		12.9	OK
S1.001	S2	15 minute 2 year Winter I+0%	49.500	47.996	-0.180	0.000	0.34		24.1	OK
S2.000	S3	15 minute 2 year Winter I+0%	49.550	48.089	-0.211	0.000	0.19		12.9	OK
S2.001	S4	15 minute 2 year Winter I+0%	49.500	48.021	-0.181	0.000	0.33		24.0	OK
S1.002	S3	720 minute 2 year Winter I+0%	49.200	46.578	0.153	0.000	0.02		0.9	SURCHARGED

Pell Frischmann		Page 8
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:08 File 104878 Phase 1A.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor	1.000	Manhole Headloss Coeff (Global)	0.500	MADD Factor * 10m <sup>3</sup> /ha Storage	2.000
Hot Start (mins)	0	Foul Sewage per hectare (l/s)	0.000	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Additional Flow - % of Total Flow	0.000	Flow per Person per Day (l/per/day)	0.000


Number of Input Hydrographs	0	Number of Offline Controls	0	Number of Time/Area Diagrams	0
Number of Online Controls	1	Number of Storage Structures	1	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FEH	D3 (1km)	0.234
FEH Rainfall Version	1999	E (1km)	0.332
Site Location	GB 526100 184450 TQ 26100 84450	F (1km)	2.519
C (1km)	-0.025	Cv (Summer)	0.750
D1 (1km)	0.330	Cv (Winter)	0.840
D2 (1km)	0.277		


Margin for Flood Risk Warning (mm)	300.0	DVD Status	ON
Analysis Timestep	2.5 Second Increment (Extended)	Inertia Status	ON
DTS Status			OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440, 2160, 2880, 4320, 5760, 7200, 8640, 10080
Return Period(s) (years)	2, 30, 100
Climate Change (%)	0, 0, 40

Pell Frischmann		Page 9
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:08 File 104878 Phase 1A.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	


30 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

US/MH	US/CL	Water Level	Surcharged Depth	Flooded Volume	Flow / Overflow Cap.	Pipe Flow	Status
PN Name	Event	(m)	(m)	(m <sup>3</sup> )	(1/s)	(1/s)	

Pell Frischmann		Page 10
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:08 File 104878 Phase 1A.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	US/MH Name	Event	US/CL (m)	Water	Surcharged	Flooded	Flow / Cap.	Overflow (l/s)	Pipe	Status
				Level (m)	Depth (m)	Volume (m <sup>3</sup> )			Flow (l/s)	
S1.000	S1	15 minute 30 year Winter I+0%	49.400	48.166	-0.134	0.000	0.49		34.5	OK
S1.001	S2	15 minute 30 year Winter I+0%	49.500	48.121	-0.055	0.000	0.99		71.2	OK
S2.000	S3	15 minute 30 year Winter I+0%	49.550	48.179	-0.121	0.000	0.51		34.5	OK
S2.001	S4	15 minute 30 year Winter I+0%	49.500	48.141	-0.061	0.000	0.98		71.4	OK
S1.002	S3	720 minute 30 year Winter I+0%	49.200	47.141	0.716	0.000	0.02		1.1	SURCHARGED

Pell Frischmann		Page 11
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:08 File 104878 Phase 1A.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor	1.000	Manhole Headloss Coeff (Global)	0.500	MADD Factor * 10m <sup>3</sup> /ha Storage	2.000
Hot Start (mins)	0	Foul Sewage per hectare (l/s)	0.000	Inlet Coeffiecient	0.800
Hot Start Level (mm)	0	Additional Flow - % of Total Flow	0.000	Flow per Person per Day (l/per/day)	0.000


Number of Input Hydrographs	0	Number of Offline Controls	0	Number of Time/Area Diagrams	0
Number of Online Controls	1	Number of Storage Structures	1	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FEH	D3 (1km)	0.234
FEH Rainfall Version	1999	E (1km)	0.332
Site Location	GB 526100 184450 TQ 26100 84450	F (1km)	2.519
C (1km)	-0.025	Cv (Summer)	0.750
D1 (1km)	0.330	Cv (Winter)	0.840
D2 (1km)	0.277		

Margin for Flood Risk Warning (mm)	300.0	DVD Status	ON
Analysis Timestep	2.5 Second Increment (Extended)	Inertia Status	ON
DTS Status			OFF


Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440, 2160, 2880, 4320, 5760, 7200, 8640, 10080
Return Period(s) (years)	2, 30, 100
Climate Change (%)	0, 0, 40

Pell Frischmann		Page 12
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:08 File 104878 Phase 1A.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm


US/MH	US/CL	Water Level	Surcharged Depth	Flooded Volume	Pipe Flow / Overflow Cap.	Pipe Flow	Status
PN Name	Event	(m)	(m)	(m <sup>3</sup> )	(1/s)	(1/s)	



Pell Frischmann		Page 13
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:08 File 104878 Phase 1A.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	US/MH Name	Event	US/CL (m)	Water Surcharged			Flooded Volume (m <sup>3</sup> )	Flow / Cap. (l/s)	Overflow (l/s)	Pipe Flow (l/s)	Status
				Level (m)	Depth (m)	Flow / Cap. (l/s)					
S1.000	S1	15 minute 100 year Winter I+40%	49.400	48.889	0.589	0.000	1.08		75.7	SURCHARGED	
S1.001	S2	15 minute 100 year Winter I+40%	49.500	48.746	0.570	0.000	2.12		151.8	SURCHARGED	
S2.000	S3	15 minute 100 year Winter I+40%	49.550	49.005	0.705	0.000	1.11		75.7	SURCHARGED	
S2.001	S4	15 minute 100 year Winter I+40%	49.500	48.886	0.684	0.000	2.06		150.2	SURCHARGED	
S1.002	S3	960 minute 100 year Winter I+40%	49.200	48.132	1.707	0.000	0.03		1.5	SURCHARGED	

Pell Frischmann		Page 1
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:37 File 104878 Phase 1B.MDX	Designed by MFox Checked by	
Innovyze		Network 2020.1.3

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm

Pipe Sizes STANDARD Manhole Sizes STANDARD

FEH Rainfall Model

Return Period (years)	100
FEH Rainfall Version	1999
Site Location GB 526100 184450 TQ 26100 84450	
C (1km)	-0.025
D1 (1km)	0.330
D2 (1km)	0.277
D3 (1km)	0.234
E (1km)	0.332
F (1km)	2.519
Maximum Rainfall (mm/hr)	50
Maximum Time of Concentration (mins)	30
Foul Sewage (l/s/ha)	0.000
Volumetric Runoff Coeff.	0.750
PIMP (%)	100
Add Flow / Climate Change (%)	10
Minimum Backdrop Height (m)	1.500
Maximum Backdrop Height (m)	1.500
Min Design Depth for Optimisation (m)	1.200
Min Vel for Auto Design only (m/s)	1.00
Min Slope for Optimisation (1:X)	500

Designed with Level Soffits

Free Flowing Outfall Details for Storm

Outfall Pipe Number	Outfall C. Name	Level I. (m)	Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
------------------------	--------------------	-----------------	--------------	------------------------	-------------	-----------


S1.003	S	49.220	45.920	0.000	0	0
--------	---	--------	--------	-------	---	---

Simulation Criteria for Storm

Volumetric Runoff Coeff	0.750	Additional Flow - % of Total Flow	0.000
Areal Reduction Factor	1.000	MADD Factor * 10m <sup>3</sup> /ha Storage	2.000
Hot Start (mins)	0	Inlet Coefficient	0.800
Hot Start Level (mm)	0	Flow per Person per Day (l/per/day)	0.000
Manhole Headloss Coeff (Global)	0.500	Run Time (mins)	60
Foul Sewage per hectare (l/s)	0.000	Output Interval (mins)	1


Number of Input Hydrographs	0	Number of Storage Structures	1
Number of Online Controls	1	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details

Pell Frischmann		Page 2
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:37 File 104878 Phase 1B.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

Synthetic Rainfall Details

Rainfall Model	FEH
Return Period (years)	100
FEH Rainfall Version	1999
Site Location	GB 526100 184450 TQ 26100 84450
C (1km)	-0.025
D1 (1km)	0.330
D2 (1km)	0.277
D3 (1km)	0.234
E (1km)	0.332
F (1km)	2.519
Summer Storms	Yes
Winter Storms	No
Cv (Summer)	0.750
Cv (Winter)	0.840
Storm Duration (mins)	30

Pell Frischmann		Page 3
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:37 File 104878 Phase 1B.MDX	Designed by MFox Checked by	
Innovyze		Network 2020.1.3

Online Controls for Storm

Hydro-Brake® Optimum Manhole: S4, DS/PN: S1.003, Volume (m³): 15.3

Unit Reference	MD-SHE-0068-2800-2000-2800
Design Head (m)	2.000
Design Flow (l/s)	2.8
Flush-Flo™	Calculated
Objective	Minimise upstream storage
Application	Surface
Sump Available	Yes
Diameter (mm)	68
Invert Level (m)	45.958
Minimum Outlet Pipe Diameter (mm)	100
Suggested Manhole Diameter (mm)	1200

Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	2.000	2.8
Flush-Flo™	0.298	2.0
Kick-Flo®	0.606	1.6
Mean Flow over Head Range	-	2.1

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	1.7	1.200	2.2	3.000	3.4	7.000	5.0
0.200	2.0	1.400	2.4	3.500	3.6	7.500	5.2
0.300	2.0	1.600	2.5	4.000	3.9	8.000	5.3
0.400	2.0	1.800	2.7	4.500	4.1	8.500	5.5
0.500	1.9	2.000	2.8	5.000	4.3	9.000	5.6
0.600	1.6	2.200	2.9	5.500	4.5	9.500	5.8
0.800	1.8	2.400	3.0	6.000	4.7		
1.000	2.0	2.600	3.2	6.500	4.8		

5 Manchester Square  
 London  
 W1U 3PD



Date 12/12/2022 14:37  
 File 104878 Phase 1B.MDX

Designed by MFox  
 Checked by


Innovyze Network 2020.1.3

Storage Structures for Storm

Tank or Pond Manhole: S4, DS/PN: S1.003

Invert Level (m) 45.958

Depth (m)	Area (m <sup>2</sup> )	Depth (m)	Area (m <sup>2</sup> )	Depth (m)	Area (m <sup>2</sup> )
0.000	260.5	2.000	260.5	2.001	0.0

Pell Frischmann		Page 5
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:37 File 104878 Phase 1B.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

2 year Return Period Summary of Critical Results by Maximum Level (Rank 1)  
for Storm

Simulation Criteria

Areal Reduction Factor 1.000      Additional Flow - % of Total Flow 0.000  
Hot Start (mins) 0      MADD Factor \* 10m<sup>3</sup>/ha Storage 2.000  
Hot Start Level (mm) 0      Inlet Coefficient 0.800  
Manhole Headloss Coeff (Global) 0.500      Flow per Person per Day (l/per/day) 0.000  
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0      Number of Storage Structures 1  
Number of Online Controls 1      Number of Time/Area Diagrams 0  
Number of Offline Controls 0      Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FEH  
FEH Rainfall Version 1999  
Site Location GB 526100 184450 TQ 26100 84450  
C (1km) -0.025  
D1 (1km) 0.330  
D2 (1km) 0.277  
D3 (1km) 0.234  
E (1km) 0.332  
F (1km) 2.519  
Cv (Summer) 0.750  
Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0  
Analysis Timestep 2.5 Second Increment (Extended)  
DTS Status OFF  
DVD Status ON  
Inertia Status ON

Profile(s) Summer and Winter  
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600,  
720, 960, 1440, 2160, 2880, 4320, 5760,  
7200, 8640, 10080  
Return Period(s) (years) 2, 30, 100  
Climate Change (%) 0, 0, 40

PN	US/MH Name	Event	Water Surcharged Flooded				
			US/CL (m)	Level (m)	Depth (m)	Volume (m <sup>3</sup> )	Flow / Cap.
S1.000	S1	15 minute 2 year Winter I+0%	49.200	47.798	-0.202	0.000	0.23
S1.001	S2	15 minute 2 year Winter I+0%	49.500	47.652	-0.163	0.000	0.43
S1.002	S3	15 minute 2 year Winter I+0%	49.500	47.357	-0.304	0.000	0.23
S2.000	S4	15 minute 2 year Winter I+0%	49.500	47.998	-0.202	0.000	0.23
S2.001	S5	15 minute 2 year Winter I+0%	49.400	47.846	-0.160	0.000	0.45
S2.002	S6	15 minute 2 year Winter I+0%	49.300	47.600	-0.308	0.000	0.22
S1.003	S4	720 minute 2 year Winter I+0%	49.300	46.345	0.162	0.000	0.07

5 Manchester Square  
 London  
 W1U 3PD




Date 12/12/2022 14:37  
 File 104878 Phase 1B.MDX

Designed by MFox  
 Checked by

Innovyze Network 2020.1.3

2 year Return Period Summary of Critical Results by Maximum Level (Rank 1)  
 for Storm

PN	US/MH Name	Overflow (l/s)	Pipe Flow (l/s)	Status
S1.000	S1		16.4	OK
S1.001	S2		30.4	OK
S1.002	S3		43.8	OK
S2.000	S4		16.6	OK
S2.001	S5		30.5	OK
S2.002	S6		44.0	OK
S1.003	S4		2.0	SURCHARGED

Pell Frischmann		Page 7
5 Manchester Square London W1U 3PD		
Date 12/12/2022 14:37 File 104878 Phase 1B.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1)  
for Storm

Simulation Criteria

Areal Reduction Factor 1.000      Additional Flow - % of Total Flow 0.000  
Hot Start (mins) 0      MADD Factor \* 10m<sup>3</sup>/ha Storage 2.000  
Hot Start Level (mm) 0      Inlet Coefficient 0.800  
Manhole Headloss Coeff (Global) 0.500      Flow per Person per Day (l/per/day) 0.000  
Foul Sewage per hectare (l/s) 0.000

Number of Input Hydrographs 0      Number of Storage Structures 1  
Number of Online Controls 1      Number of Time/Area Diagrams 0  
Number of Offline Controls 0      Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model FEH  
FEH Rainfall Version 1999  
Site Location GB 526100 184450 TQ 26100 84450  
C (1km) -0.025  
D1 (1km) 0.330  
D2 (1km) 0.277  
D3 (1km) 0.234  
E (1km) 0.332  
F (1km) 2.519  
Cv (Summer) 0.750  
Cv (Winter) 0.840

Margin for Flood Risk Warning (mm) 300.0  
Analysis Timestep 2.5 Second Increment (Extended)  
DTS Status OFF  
DVD Status ON  
Inertia Status ON

Profile(s) Summer and Winter  
Duration(s) (mins) 15, 30, 60, 120, 180, 240, 360, 480, 600,  
720, 960, 1440, 2160, 2880, 4320, 5760,  
7200, 8640, 10080  
Return Period(s) (years) 2, 30, 100  
Climate Change (%) 0, 0, 40

PN	US/MH Name	Event	US/CL (m)	Water Level (m)	Surcharged Depth (m)	Flooded Volume (m <sup>3</sup> )	Flow / Cap.
S1.000	S1	15 minute 30 year Winter I+0%	49.200	47.945	-0.055	0.000	0.60
S1.001	S2	15 minute 30 year Winter I+0%	49.500	47.877	0.062	0.000	1.19
S1.002	S3	15 minute 30 year Winter I+0%	49.500	47.481	-0.180	0.000	0.66
S2.000	S4	15 minute 30 year Winter I+0%	49.500	48.136	-0.064	0.000	0.61
S2.001	S5	15 minute 30 year Winter I+0%	49.400	48.061	0.055	0.000	1.28
S2.002	S6	15 minute 30 year Winter I+0%	49.300	47.724	-0.184	0.000	0.64
S1.003	S4	720 minute 30 year Winter I+0%	49.300	46.948	0.765	0.000	0.07



5 Manchester Square  
 London  
 W1U 3PD



Date 12/12/2022 14:37  
 File 104878 Phase 1B.MDX

Designed by MFox  
 Checked by

Innovyze Network 2020.1.3

30 year Return Period Summary of Critical Results by Maximum Level (Rank 1)  
 for Storm

PN	US/MH Name	Overflow (l/s)	Pipe Flow (l/s)	Status
S1.000	S1	43.2		OK
S1.001	S2	84.8		SURCHARGED
S1.002	S3	126.4		OK
S2.000	S4	44.0		OK
S2.001	S5	87.4		SURCHARGED
S2.002	S6	130.7		OK
S1.003	S4	2.0		SURCHARGED

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor	1.000	Additional Flow - % of Total Flow	0.000
Hot Start (mins)	0	MADD Factor * 10m <sup>3</sup> /ha Storage	2.000
Hot Start Level (mm)	0	Inlet Coefficient	0.800
Manhole Headloss Coeff (Global)	0.500	Flow per Person per Day (l/per/day)	0.000
Foul Sewage per hectare (l/s)	0.000		

Number of Input Hydrographs	0	Number of Storage Structures	1
Number of Online Controls	1	Number of Time/Area Diagrams	0
Number of Offline Controls	0	Number of Real Time Controls	0

Synthetic Rainfall Details

Rainfall Model	FEH
FEH Rainfall Version	1999
Site Location	GB 526100 184450 TQ 26100 84450
C (1km)	-0.025
D1 (1km)	0.330
D2 (1km)	0.277
D3 (1km)	0.234
E (1km)	0.332
F (1km)	2.519
Cv (Summer)	0.750
Cv (Winter)	0.840
Margin for Flood Risk Warning (mm)	300.0
Analysis Timestep	2.5 Second Increment (Extended)
DTS Status	OFF
DVD Status	ON
Inertia Status	ON

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440, 2160, 2880, 4320, 5760, 7200, 8640, 10080
Return Period(s) (years)	2, 30, 100
Climate Change (%)	0, 0, 40

PN	US/MH Name	Event	Water Surcharged Flooded						
			US/CL (m)	Level (m)	Depth (m)	Volume (m <sup>3</sup> )	Flow / Cap.		
S1.000	S1	15 minute 100 year Winter I+40%	49.200	49.138	1.138	0.000	1.30		
S1.001	S2	15 minute 100 year Winter I+40%	49.500	48.846	1.031	0.000	2.55		
S1.002	S3	960 minute 100 year Winter I+40%	49.500	48.017	0.356	0.000	0.08		
S2.000	S4	15 minute 100 year Winter I+40%	49.500	49.180	0.980	0.000	1.31		
S2.001	S5	15 minute 100 year Winter I+40%	49.400	48.856	0.850	0.000	2.73		
S2.002	S6	15 minute 100 year Winter I+40%	49.300	48.100	0.192	0.000	1.39		
S1.003	S4	960 minute 100 year Winter I+40%	49.300	48.017	1.834	0.000	0.10		

5 Manchester Square  
 London  
 W1U 3PD




Date 12/12/2022 14:37  
 File 104878 Phase 1B.MDX

Designed by MFox  
 Checked by

Innovyze Network 2020.1.3

100 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

PN	US/MH Name	Overflow (l/s)	Pipe Flow (l/s)	Status
S1.000	S1	94.4	FLOOD RISK	
S1.001	S2	182.1	SURCHARGED	
S1.002	S3	14.6	SURCHARGED	
S2.000	S4	95.5	SURCHARGED	
S2.001	S5	186.2	SURCHARGED	
S2.002	S6	282.8	SURCHARGED	
S1.003	S4	2.8	SURCHARGED	

Pell Frischmann		Page 1
5 Manchester Square London W1U 3PD		
Date 12/12/2022 15:07 File 104878 Phase 1C.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

STORM SEWER DESIGN by the Modified Rational Method

Design Criteria for Storm


Pipe Sizes STANDARD Manhole Sizes STANDARD

FEH Rainfall Model			
Return Period (years)	100	Maximum Time of Concentration (mins)	30
		Foul Sewage (l/s/ha)	0.000
FEH Rainfall Version	1999	Volumetric Runoff Coeff.	0.750
Site Location	GB 526100 184450 TQ 26100 84450	PIMP (%)	100
C (1km)	-0.025	Add Flow / Climate Change (%)	10
D1 (1km)	0.330	Minimum Backdrop Height (m)	1.500
D2 (1km)	0.277	Maximum Backdrop Height (m)	1.500
D3 (1km)	0.234	Min Design Depth for Optimisation (m)	1.200
E (1km)	0.332	Min Vel for Auto Design only (m/s)	1.00
F (1km)	2.519	Min Slope for Optimisation (1:X)	500
Maximum Rainfall (mm/hr)	50		

Designed with Level Soffits

Free Flowing Outfall Details for Storm

Outfall Pipe Number	Outfall Name	C. Level (m)	I. Level (m)	Min I. Level (m)	D,L (mm)	W (mm)
S1.003	S	49.320	45.455	0.000	0	0

Pell Frischmann		Page 2
5 Manchester Square London W1U 3PD		
Date 12/12/2022 15:07 File 104878 Phase 1C.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	


Simulation Criteria for Storm

Volumetric Runoff Coeff	0.750	Manhole Headloss Coeff (Global)	0.500	Inlet Coeffiecient	0.800
Areal Reduction Factor	1.000	Foul Sewage per hectare (l/s)	0.000	Flow per Person per Day (l/per/day)	0.000
Hot Start (mins)	0	Additional Flow - % of Total Flow	0.000	Run Time (mins)	60
Hot Start Level (mm)	0	MADD Factor * 10m <sup>3</sup> /ha Storage	2.000	Output Interval (mins)	1

Number of Input Hydrographs 0    Number of Offline Controls 0    Number of Time/Area Diagrams 0  
Number of Online Controls 1    Number of Storage Structures 1    Number of Real Time Controls 0

Synthetic Rainfall Details

Rainfall Model	FEH	E (1km)	0.332
Return Period (years)	100	F (1km)	2.519
FEH Rainfall Version	1999	Summer Storms	Yes
Site Location	GB 526100 184450 TQ 26100 84450	Winter Storms	No
C (1km)	-0.025	Cv (Summer)	0.750
D1 (1km)	0.330	Cv (Winter)	0.840
D2 (1km)	0.277	Storm Duration (mins)	30
D3 (1km)	0.234		

Pell Frischmann		Page 3
5 Manchester Square London W1U 3PD		
Date 12/12/2022 15:07 File 104878 Phase 1C.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

Online Controls for Storm


Hydro-Brake® Optimum Manhole: S6, DS/PN: S1.003, Volume (m³): 15.9

Unit Reference	MD-SHE-0071-3300-2400-3300	Sump Available	Yes
Design Head (m)	2.400	Diameter (mm)	71
Design Flow (l/s)	3.3	Invert Level (m)	45.497
Flush-Flo™	Calculated	Minimum Outlet Pipe Diameter (mm)	100
Objective	Minimise upstream storage	Suggested Manhole Diameter (mm)	1200
Application	Surface		

Control Points	Head (m)	Flow (l/s)	Control Points	Head (m)	Flow (l/s)
Design Point (Calculated)	2.400	3.3	Kick-Flo®	0.630	1.8
Flush-Flo™	0.307	2.2	Mean Flow over Head Range	-	2.4

The hydrological calculations have been based on the Head/Discharge relationship for the Hydro-Brake® Optimum as specified. Should another type of control device other than a Hydro-Brake Optimum® be utilised then these storage routing calculations will be invalidated

Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)	Depth (m)	Flow (l/s)
0.100	1.8	0.600	1.9	1.600	2.7	2.600	3.4	5.000	4.6	7.500	5.6
0.200	2.2	0.800	2.0	1.800	2.9	3.000	3.7	5.500	4.9	8.000	5.8
0.300	2.2	1.000	2.2	2.000	3.0	3.500	3.9	6.000	5.1	8.500	6.0
0.400	2.2	1.200	2.4	2.200	3.2	4.000	4.2	6.500	5.2	9.000	6.1
0.500	2.1	1.400	2.6	2.400	3.3	4.500	4.4	7.000	5.4	9.500	6.3


Pell Frischmann		Page 4
5 Manchester Square London W1U 3PD		
Date 12/12/2022 15:07 File 104878 Phase 1C.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

Storage Structures for Storm

Tank or Pond Manhole: S6, DS/PN: S1.003

Invert Level (m) 45.497

Depth (m)	Area (m <sup>2</sup> )	Depth (m)	Area (m <sup>2</sup> )	Depth (m)	Area (m <sup>2</sup> )
0.000	239.0	2.400	239.0	2.401	0.0

Pell Frischmann		Page 5
5 Manchester Square London W1U 3PD		
Date 12/12/2022 15:07 File 104878 Phase 1C.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

2 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

Simulation Criteria

Areal Reduction Factor	1.000	Manhole Headloss Coeff (Global)	0.500	MADD Factor * 10m <sup>3</sup> /ha Storage	2.000
Hot Start (mins)	0	Foul Sewage per hectare (l/s)	0.000	Inlet Coeffiecient	0.800
Hot Start Level (mm)	0	Additional Flow - % of Total Flow	0.000	Flow per Person per Day (l/per/day)	0.000

Number of Input Hydrographs	0	Number of Offline Controls	0	Number of Time/Area Diagrams	0
Number of Online Controls	1	Number of Storage Structures	1	Number of Real Time Controls	0


Synthetic Rainfall Details

Rainfall Model	FEH	D3 (1km)	0.234
FEH Rainfall Version	1999	E (1km)	0.332
Site Location	GB 526100 184450 TQ 26100 84450	F (1km)	2.519
C (1km)	-0.025	Cv (Summer)	0.750
D1 (1km)	0.330	Cv (Winter)	0.840
D2 (1km)	0.277		

Margin for Flood Risk Warning (mm)	300.0	DVD Status	ON
Analysis Timestep	2.5 Second Increment (Extended)	Inertia Status	ON
DTS Status			OFF

Profile(s)	Summer and Winter
Duration(s) (mins)	15, 30, 60, 120, 180, 240, 360, 480, 600, 720, 960, 1440, 2160, 2880, 4320, 5760, 7200, 8640, 10080
Return Period(s) (years)	2, 30, 100
Climate Change (%)	0, 0, 40



Pell Frischmann		Page 6
5 Manchester Square London W1U 3PD		
Date 12/12/2022 15:07 File 104878 Phase 1C.MDX	Designed by MFox Checked by	
Innovyze	Network 2020.1.3	

2 year Return Period Summary of Critical Results by Maximum Level (Rank 1) for Storm

US/MH	US/CL	Water Level	Surcharged Depth	Flooded Volume	Flow / Overflow Cap.	Pipe Flow	Status
PN Name	Event	(m)	(m)	(m <sup>3</sup> )	(1/s)	(1/s)	