

---

**From:**  
**Sent:** 05 February 2025 13:48  
**To:** Planning  
**Subject:** 3rd Party Planning Application - 2024/4840/P

[EXTERNAL EMAIL] Beware – This email originated outside Camden Council and may be malicious Please take extra care with any links, attachments, requests to take action or for you to verify your password etc.

London Borough of Camden  
Camden Town Hall  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

Our DTS Ref: 78208  
Your Ref: 2024/4840/P

5 February 2025

Dear Sir/Madam

Re: THE COURTYARD BUILDING 1-7 ALFRED PLACE, 22 STORE & 220-226 , TOTTENHAM COURT ROAD, LONDON, -, WC1E 7DF

**Waste Comments**

We would expect the developer to demonstrate what measures will be undertaken to minimise groundwater discharges into the public sewer. Groundwater discharges typically result from construction site dewatering, deep excavations, basement infiltration, borehole installation, testing and site remediation. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. Should the Local Planning Authority be minded to approve the planning application, Thames Water would like the following informative attached to the planning permission: "A Groundwater Risk Management Permit from Thames Water will be required for discharging groundwater into a public sewer. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures he will undertake to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 020 3577 9483 or by emailing [trade.effluent@thameswater.co.uk](mailto:trade.effluent@thameswater.co.uk). Application forms should be completed on line via <https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.thameswater.co.uk%2F&data=05%7C02%7Cplanning%40camden.gov.uk%7C19ede4e4187d4d7d2c1608dd45eba601%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638743600605096501%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIlwLjAuMDAwMCIsIlAiOiJXaW4zMilslkFOljoiTWFpbGlldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=m173BI3nIR0W%2Fn22dOm6A6QDnysgzymK8MwioSYxCCA%3D&reserved=0>. Please refer to the Wholesale; Business customers; Groundwater discharges section.

With regard to SURFACE WATER drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Management of surface water from new developments should follow Policy SI 13 Sustainable drainage of the London Plan 2021. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require

further information please refer to our website.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fhelp%2Fhome-improvements%2Fhow-to-connect-to-a-sewer%2Fsewer-connection-design&data=05%7C02%7Cplanning%40camden.gov.uk%7C19ede4e4187d4d7d2c1608dd45eba601%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638743600605126242%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIwLjAuMDAwMCIsIIAiOiJXaW4zMilslkFOljoitWFBpClslldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=1slbz4wZuKqco55gENPPwxzAY7c3aVGP7VQ0%2FI4ocRE%3D&reserved=0>

Thames Water would advise that with regard to WASTE WATER NETWORK and SEWAGE TREATMENT WORKS infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

#### Water Comments

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at [thameswater.co.uk/buildingwater](http://thameswater.co.uk/buildingwater).

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk) Visit us online

<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.thameswater.co.uk%2F&data=05%7C02%7Cplanning%40camden.gov.uk%7C19ede4e4187d4d7d2c1608dd45eba601%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638743600605148229%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIwLjAuMDAwMCIsIIAiOiJXaW4zMilslkFOljoitWFBpClslldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=RbIPquFGPBy9dMjlblzfwkP%2FbYFv%2BbU0wyiDtPtoYp4%3D&reserved=0>, follow us on twitter

<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.twitter.com%2Fthameswater&data=05%7C02%7Cplanning%40camden.gov.uk%7C19ede4e4187d4d7d2c1608dd45eba>

601%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638743600605169953%7CUnkn  
own%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOilwLjAuMDAwMCIslIAiOiJXaW4zM  
ilslkFOljoiTWFpbClldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=w6AulHS%2F4r2rY3WqqZU  
PWss%2BOjval%2FzdgefTsoXi1qk%3D&reserved=0 or find us on  
[https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.facebook.com%2Ftham  
eswater&data=05%7C02%7Cplanning%40camden.gov.uk%7C19ede4e4187d4d7d2c1608dd45e  
ba601%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638743600605191931%7CUn  
known%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOilwLjAuMDAwMCIslIAiOiJXaW4  
zMilslkFOljoiTWFpbClldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=xFg4Rc4kPV8Lyu0X%2  
FIG5UPIICkXIQ44db7SKaRQ4Mf0%3D&reserved=0](https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.facebook.com%2Ftham<br/>eswater&data=05%7C02%7Cplanning%40camden.gov.uk%7C19ede4e4187d4d7d2c1608dd45e<br/>ba601%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638743600605191931%7CUn<br/>known%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOilwLjAuMDAwMCIslIAiOiJXaW4<br/>zMilslkFOljoiTWFpbClldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=xFg4Rc4kPV8Lyu0X%2<br/>FIG5UPIICkXIQ44db7SKaRQ4Mf0%3D&reserved=0). We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.