



to discharge ground water to the public network, this would require a Groundwater Risk Management Permit from Thames Water. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures will be undertaken to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 02035779483 or by emailing [trade.effluent@thameswater.co.uk](mailto:trade.effluent@thameswater.co.uk). Application forms should be completed on line via <https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.thameswater.co.uk%2F&data=05%7C02%7Cplanning%40camden.gov.uk%7Cd815d3a84926477cac5708dd5a3da96e%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638765943093219124%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOilwLjAuMDAwMClslIAiOiJXaW4zMilslkFOljoiTWFpbClslldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=2J8bfMuUME4gKBME8swXJJ%2BF%2Fvn4sN%2BlqQ5clY%2BvYIU%3D&reserved=0>. Please refer to the Wholesale; Business customers; Groundwater discharges section.

#### Water Comments

The proposed development is located within 15m of a strategic water main. Thames Water request that the following condition be added to any planning permission. No piling shall take place until a piling method statement (detailing the depth and type of piling to be undertaken and the methodology by which such piling will be carried out, including measures to prevent and minimise the potential for damage to subsurface water infrastructure, and the programme for the works) and piling layout plan including all Thames Water clean water assets, the local topography and clearance between the face of the pile to the face of a pipe has been submitted to and approved in writing by the local planning authority in consultation with Thames Water. Any piling must be undertaken in accordance with the terms of the approved piling method statement and piling layout plan. Reason: The proposed works will be in close proximity to underground water utility infrastructure. Piling has the potential to impact on local underground water utility infrastructure. Please read our guide 'working near our assets' to ensure your workings will be in line with the necessary processes you need to follow if you're considering working above or near our pipes or other structures.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Flarger-scale-developments%2Fplanning-your-development%2Fworking-near-our-pipes&data=05%7C02%7Cplanning%40camden.gov.uk%7Cd815d3a84926477cac5708dd5a3da96e%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638765943093236633%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOilwLjAuMDAwMClslIAiOiJXaW4zMilslkFOljoiTWFpbClslldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=LAeB4G%2FEk8v38BVDa8Mux2vqYmoKFG%2BwTKVDkvh2kuw%3D&reserved=0> Should you require further information please contact Thames Water. Email: [developer.services@thameswater.co.uk](mailto:developer.services@thameswater.co.uk) Phone: 0800 009 3921 (Monday to Friday, 8am to 5pm) Write to: Thames Water Developer Services, Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB

Following initial investigations, Thames Water has identified an inability of the existing water network infrastructure to accommodate the needs of this development proposal. As such Thames Water request that the following condition be added to any planning permission. No development shall be occupied until confirmation has been provided that either:- all water network upgrades required to accommodate the additional demand to serve the development have been completed; or - a development and infrastructure phasing plan has been agreed with Thames Water to allow development to be occupied. Where a development and infrastructure phasing plan is agreed no occupation shall take place other than in accordance with the agreed development and infrastructure phasing plan. Reason - The development may lead to no / low water pressure and network reinforcement works are anticipated to be necessary to ensure that sufficient capacity is made available to accommodate additional demand anticipated from the new development" The developer can request information to support the discharge of this condition by visiting the Thames Water website at [thameswater.co.uk/preplanning](http://thameswater.co.uk/preplanning). Should the Local Planning Authority consider the above recommendation inappropriate or are unable to include it in the decision notice, it is important that the Local Planning Authority liaises with Thames Water Development Planning Department (e-mail: [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)) prior to the planning application approval.

There are water mains crossing or close to your development. Thames Water do NOT permit the building over or construction within 3m of water mains. If you're planning significant works near our mains (within 3m) we'll need to check that your development doesn't reduce capacity, limit repair or maintenance activities during and after construction, or inhibit the services we provide in any other way. The applicant is advised to read our guide working

near or diverting our pipes.

<https://eur03.safelinks.protection.outlook.com/?url=https%3A%2F%2Fwww.thameswater.co.uk%2Fdevelopers%2Farger-scale-developments%2Fplanning-your-development%2Fworking-near-our-pipes&data=05%7C02%7Cplanning%40camden.gov.uk%7Cd815d3a84926477cac5708dd5a3da96e%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638765943093252094%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWU%3D%3D%7C0%7C%7C%7C&sdata=ha%2B%2FoB8sT8yUwUF1t0Py9tw0w17kyhsu12gZKI3bXT8%3D&reserved=0>

Thames Water recommend the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

#### Supplementary Comments

Please submit a foundation/piling layout plan clearly indicating the locations of all foundation/piles to be installed on the development site. This plan should show the positions of the foundation/piles in relation to Thames Water clean water mains and sewers and local topography such as roads (please include road names), existing buildings and/or any other notable features. Thames Water require drawings indicating the location of all piling and the clearance between the face of the pile to the face of a pipe. If any basements intended to be constructed as part of the development, please clearly indicate the location and footprint. Without these drawings and cross-sectional details Thames Water will not be able to review your proposals and discharge your planning condition.

The Developer is also requested to confirm whether they have been in touch with Thames Water to discuss or arrange for the abandonment of any existing assets beneath the development site. Please give a short summary of any correspondence to date and any references they have been provided.

Plans of Thames Water apparatus can be obtained through our website at <https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.thameswater-propertysearches.co.uk%2F&data=05%7C02%7Cplanning%40camden.gov.uk%7Cd815d3a84926477cac5708dd5a3da96e%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638765943093267187%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWU%3D%3D%7C0%7C%7C%7C&sdata=au3Ojd330uyzlz2iFsnl6HQi2noUVed9AilFoKYU7Bo%3D&reserved=0>. Please use the following reference in all future correspondence: DTS 65166.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ  
Tel:020 3577 9998  
Email: devcon.team@thameswater.co.uk

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to devcon.team@thameswater.co.uk Visit us online <https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.thameswater.co.uk%2F&data=05%7C02>

%7Cplanning%40camden.gov.uk%7Cd815d3a84926477cac5708dd5a3da96e%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638765943093282163%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOilwLjAuMDAwMClslIAiOiJXaW4zMilslkFOljoiTWFpbClslldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=E5NguSrlI9FeGfCjt9CyFmljno3WpezrWwrPGW7t26g%3D&reserved=0 , follow us on twitter  
<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.twitter.com%2Fthameswater&data=05%7C02%7Cplanning%40camden.gov.uk%7Cd815d3a84926477cac5708dd5a3da96e%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638765943093297534%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOilwLjAuMDAwMClslIAiOiJXaW4zMilslkFOljoiTWFpbClslldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=WhuVBvZ3Z73IOoTTLXKVRKzJDvCf6yZ1vB8WAv754fo%3D&reserved=0> or find us on  
<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.facebook.com%2Fthameswater&data=05%7C02%7Cplanning%40camden.gov.uk%7Cd815d3a84926477cac5708dd5a3da96e%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638765943093313174%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOilwLjAuMDAwMClslIAiOiJXaW4zMilslkFOljoiTWFpbClslldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=8yw3d5zMgSkjGxzeG%2F27VltVCEENRLqzIzQ1DeAom8%3D&reserved=0>. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.