

Delete  
 Respond  
 All Apps  
 Move  
 Tags  
 Editing  
 Immersive  
 Translate  
 Zoom  
 Language  
 Zoom

### RE: Bourne Estate, 2025/0266/L



Ivan Bozhilov [Redacted]  
 To Nick Baxter  
 Cc Jack Norris; Steve Taylor; Andrew Cox;  
 Scott Smart; John Horton



13:05

**[EXTERNAL EMAIL]** Beware – This email originated outside Camden Council and may be malicious Please take extra care with any links, attachments, requests to take action or for you to verify your password etc.

Hi Nick,

As per our conversations last week – the Phase 3 glazing specification towards the relevant planning condition referenced with application ref:2025/0266/L is as per the sent Data Sheets and you can also summarise the double glazing with the following:

- Glass Specification – Doble glazed unit consisting of a 1 x layer of 4 Schott Restover glass panel(external), 12mm argon spacing and a 1 x layer of 4 Low E glass panel (internal face).

We hope that clarifies the exact specification for the physical samples submitted. Let us know if you'd require some further clarifications.

Kind Regards,  
 Ivan



**Ivan Bozhilov**  
 Design and Build Coordinator  
 tel: [Redacted]  
 mob: [Redacted]  
 web: [www.mulalley.co.uk](http://www.mulalley.co.uk)

**INVESTORS IN PEOPLE®**  
 We invest in people Platinum

We did it!  
 Officially accredited by Investors in People.  
 Because we make work better.

Registered Office: Teresa Gavin House, Woodford Avenue, Woodford Green, Essex IG8 8FA | Company No. 1534913  
 VAT Registration No. 345 7171 50

Consider the environment. Do you really need to print this email?

Email Disclaimer:

The information contained in this email including attachments are confidential and intended for the sole use of the individual or company to whom it is addressed. If you are not the intended recipient the use of this information by disclosure, copying or distribution is prohibited and strictly confidential