

# Block Compliance




|                  |                         |                |            |
|------------------|-------------------------|----------------|------------|
| Block Reference  | Norman Bromley          | Issued on Date | 29/09/2023 |
| Block Name       | Norman Bromley          |                |            |
| Calculation Type | New Build (As Designed) |                |            |

|                  |  |             |           |
|------------------|--|-------------|-----------|
| Assessor Details | Mr. Daniel Watt  | Assessor ID | AV75-0001 |
| Client           | Norman Bromley , Norman Bromley , Bridge House, Tonbridge, TN9 1DR |             |           |

| Block Compliance Report - DER   |                              |  |  |           |
|---------------------------------|------------------------------|--|--|-----------|
| Block Reference: Norman Bromley | Block Name: Norman Bromley   |  |  |           |
| Property-Assessment Reference   | Floor area (m <sup>2</sup> ) | DER (kgCO <sub>2</sub> /m <sup>2</sup> ) | TER (kgCO <sub>2</sub> /m <sup>2</sup> ) | % DER/TER |
| 001 - 001                       | 82.00                        | 4.02                                     | 15.57                                    | 74.18 %   |
| 002 - 001                       | 82.00                        | 4.22                                     | 15.57                                    | 72.90 %   |
| 101 - 001                       | 92.00                        | 3.36                                     | 13.73                                    | 75.53 %   |
| 102 - 001                       | 77.00                        | 2.90                                     | 12.12                                    | 76.07 %   |
| 103 - 001                       | 77.00                        | 2.90                                     | 12.12                                    | 76.07 %   |
| 104 - 001                       | 91.30                        | 3.13                                     | 11.91                                    | 73.72 %   |
| 201 - 001                       | 92.00                        | 3.14                                     | 12.49                                    | 74.86 %   |
| 303 - 001                       | 35.00                        | 3.68                                     | 17.18                                    | 78.58 %   |
| 304 - 001                       | 58.50                        | 3.01                                     | 12.99                                    | 76.83 %   |
| 305 - 001                       | 72.13                        | 3.12                                     | 12.96                                    | 75.93 %   |
| 401 - 001                       | 90.15                        | 3.26                                     | 13.00                                    | 74.92 %   |
| 402 - 001                       | 70.66                        | 3.14                                     | 13.17                                    | 76.16 %   |
| 403 - 001                       | 32.00                        | 4.01                                     | 18.73                                    | 78.59 %   |
| 404 - 001                       | 59.00                        | 3.19                                     | 13.54                                    | 76.44 %   |
| 405 - 001                       | 68.00                        | 3.75                                     | 14.34                                    | 73.85 %   |
| 501 - 001                       | 58.20                        | 5.03                                     | 16.90                                    | 70.24 %   |
| 502 - 001                       | 64.00                        | 4.17                                     | 16.85                                    | 75.25 %   |
| 503 - 001                       | 72.50                        | 3.90                                     | 15.84                                    | 75.38 %   |
| 202 - 001_Copy                  | 77.00                        | 2.90                                     | 12.12                                    | 76.07 %   |
| 302 - 001_Copy_Copy             | 77.00                        | 2.90                                     | 12.12                                    | 76.07 %   |
| 203 - 001_Copy                  | 77.00                        | 2.90                                     | 12.12                                    | 76.07 %   |
| 204 - 001_Copy                  | 91.30                        | 3.13                                     | 11.91                                    | 73.72 %   |


# Block Compliance



|   |                  |             |        |         |
|---|------------------|-------------|--------|---------|
| 301 - 001_Copy  | 92.00            | 3.14        | 12.49  | 74.86 % |
| Totals:   | 1687.74          | 78.90       | 319.77 |         |
| Average DER = 3.38 kgCO <sub>2</sub> /m <sup>2</sup>  | <b>% DER/TER</b> | <b>PASS</b> |        |         |
| Average TER = 13.59 kgCO <sub>2</sub> /m <sup>2</sup> | 75.11 %          |             |        |         |

| Block Compliance Report - DFEE  |                              |                               |                               |             |
|---------------------------------|------------------------------|-------------------------------|-------------------------------|-------------|
| Block Reference: Norman Bromley | Block Name: Norman Bromley   |                               |                               |             |
| Property-Assessment Reference   | Floor area (m <sup>2</sup> ) | DFEE (kWh/m <sup>2</sup> /yr) | TFEE (kWh/m <sup>2</sup> /yr) | % DFEE/TFEE |
| 001 - 001                       | 82.00                        | 44.22                         | 45.87                         | 3.58 %      |
| 002 - 001                       | 82.00                        | 44.22                         | 45.87                         | 3.58 %      |
| 101 - 001                       | 92.00                        | 36.31                         | 40.24                         | 9.76 %      |
| 102 - 001                       | 77.00                        | 27.12                         | 28.68                         | 5.46 %      |
| 103 - 001                       | 77.00                        | 27.12                         | 28.68                         | 5.46 %      |
| 104 - 001                       | 91.30                        | 32.69                         | 31.73                         | -3.02 %     |
| 201 - 001                       | 92.00                        | 32.66                         | 34.11                         | 4.26 %      |
| 303 - 001                       | 35.00                        | 27.07                         | 27.90                         | 2.99 %      |
| 304 - 001                       | 58.50                        | 25.53                         | 26.22                         | 2.62 %      |
| 305 - 001                       | 72.13                        | 29.79                         | 31.02                         | 3.98 %      |
| 401 - 001                       | 90.15                        | 34.53                         | 36.02                         | 4.14 %      |
| 402 - 001                       | 70.66                        | 30.27                         | 31.75                         | 4.68 %      |
| 403 - 001                       | 32.00                        | 30.41                         | 31.13                         | 2.32 %      |
| 404 - 001                       | 59.00                        | 28.29                         | 28.95                         | 2.30 %      |
| 405 - 001                       | 68.00                        | 36.51                         | 36.20                         | -0.85 %     |
| 501 - 001                       | 58.20                        | 55.03                         | 44.24                         | -24.38 %    |
| 502 - 001                       | 64.00                        | 42.34                         | 46.77                         | 9.47 %      |
| 503 - 001                       | 72.50                        | 39.75                         | 44.98                         | 11.63 %     |
| 202 - 001_Copy                  | 77.00                        | 27.12                         | 28.68                         | 5.46 %      |
| 302 - 001_Copy_Copy             | 77.00                        | 27.12                         | 28.68                         | 5.46 %      |
| 203 - 001_Copy                  | 77.00                        | 27.12                         | 28.68                         | 5.46 %      |

# Block Compliance



|  |                        |        |             |         |
|--|------------------------|--------|-------------|---------|
| 204 - 001_Copy   | 91.30                  | 32.69  | 31.73       | -3.02 % |
| 301 - 001_Copy   | 92.00                  | 32.66  | 34.11       | 4.26 %  |
| Totals:  | 1687.74                | 770.55 | 792.26      |         |
| Average DFEE = 33.64 kgCO <sub>2</sub> /m <sup>2</sup> | <b>%<br/>DFEE/TFEE</b> |        | <b>PASS</b> |         |
| Average TFEE = 34.70 kgCO <sub>2</sub> /m <sup>2</sup> | 3.07 %                 |        |             |         |

## Block Compliance Report - DPER

| Block Reference: Norman Bromley |                              | Block Name: Norman Bromley    |                               |             |
|---------------------------------|------------------------------|-------------------------------|-------------------------------|-------------|
| Property-Assessment Reference   | Floor area (m <sup>2</sup> ) | DPER (kWh/m <sup>2</sup> /yr) | TPER (kWh/m <sup>2</sup> /yr) | % DPER/TPER |
| 001 - 001                       | 82.00                        | 41.88                         | 83.37                         | 49.77 %     |
| 002 - 001                       | 82.00                        | 44.00                         | 83.37                         | 47.22 %     |
| 101 - 001                       | 92.00                        | 35.09                         | 73.29                         | 52.12 %     |
| 102 - 001                       | 77.00                        | 30.45                         | 64.84                         | 53.04 %     |
| 103 - 001                       | 77.00                        | 30.45                         | 64.84                         | 53.04 %     |
| 104 - 001                       | 91.30                        | 32.77                         | 63.57                         | 48.45 %     |
| 201 - 001                       | 92.00                        | 32.88                         | 66.66                         | 50.68 %     |
| 303 - 001                       | 35.00                        | 38.87                         | 93.06                         | 58.23 %     |
| 304 - 001                       | 58.50                        | 31.78                         | 69.80                         | 54.47 %     |
| 305 - 001                       | 72.13                        | 32.71                         | 69.42                         | 52.88 %     |
| 401 - 001                       | 90.15                        | 34.14                         | 69.41                         | 50.81 %     |
| 402 - 001                       | 70.66                        | 33.00                         | 70.57                         | 53.24 %     |
| 403 - 001                       | 32.00                        | 42.34                         | 101.54                        | 58.30 %     |
| 404 - 001                       | 59.00                        | 33.55                         | 72.74                         | 53.88 %     |
| 405 - 001                       | 68.00                        | 39.18                         | 76.92                         | 49.06 %     |
| 501 - 001                       | 58.20                        | 52.25                         | 90.78                         | 42.44 %     |
| 502 - 001                       | 64.00                        | 43.57                         | 90.40                         | 51.80 %     |
| 503 - 001                       | 72.50                        | 40.73                         | 84.86                         | 52.00 %     |
| 202 - 001_Copy                  | 77.00                        | 30.45                         | 64.84                         | 53.04 %     |
| 302 - 001_Copy_Copy             | 77.00                        | 30.45                         | 64.84                         | 53.04 %     |

# Block Compliance



|  |                    |             |         |         |
|--|--------------------|-------------|---------|---------|
| 203 - 001_Copy   | 77.00              | 30.45       | 64.84   | 53.04 % |
| 204 - 001_Copy   | 91.30              | 32.77       | 63.57   | 48.45 % |
| 301 - 001_Copy   | 92.00              | 32.88       | 66.66   | 50.68 % |
| Totals:  | 1687.74            | 826.64      | 1714.19 |         |
| Average DPER = 35.43 kgCO <sub>2</sub> /m <sup>2</sup> | <b>% DPER/TPER</b> | <b>PASS</b> |         |         |
| Average TPER = 72.78 kgCO <sub>2</sub> /m <sup>2</sup> | 51.32 %            |             |         |         |