



HOTEL ROOM	UNIT SUPPLY		BATHROOM EXTRACT		KITCHEN EXTRACT		TOTAL EXTRACT		ROOM CONNECTIONS	
	MIN	MAX	MIN	MAX	MIN	MAX	MIN	MAX	SUPPLY	EXTRACT
114	20	30	8	12	13	19	21	31	150x100	150x100
115	20	30	8	12	13	19	21	31	150x100	150x100
116	20	30	8	12	13	19	21	31	150x100	150x100
117	20	30	8	12	13	19	21	31	150x100	150x100
118	30	45	8	18	13	28	21	46	150x100	150x100
120	20	30	8	12	13	19	21	31	150x100	150x100
121	20	30	8	12	13	19	21	31	150x100	150x100
122	30	45	8	18	13	28	21	46	150x100	150x100
123	30	45	8	18	13	28	21	46	150x100	150x100
125	20	20	8	8	13	13	21	21	150x100	150x100
126	20	20	8	8	13	13	21	21	150x100	150x100
127	20	30	8	12	13	19	21	31	150x100	150x100
128	20	30	8	12	13	19	21	31	150x100	150x100
129	20	30	8	12	13	19	21	31	150x100	150x100
130	20	30	8	12	13	19	21	31	150x100	150x100
131	20	20	8	8	13	13	21	21	150x100	150x100
214	20	30	8	12	13	19	21	31	150x100	150x100
215	20	30	8	12	13	19	21	31	150x100	150x100
216	20	30	8	12	13	19	21	31	150x100	150x100
217	30	45	8	18	13	28	21	46	150x100	150x100
218	30	45	8	18	13	28	21	46	150x100	150x100
221	20	30	8	12	13	19	21	31	150x100	150x100
222	20	30	8	12	13	19	21	31	150x100	150x100
223	30	45	8	18	13	28	21	46	150x100	150x100
224	30	45	8	18	13	28	21	46	150x100	150x100
227	20	30	8	12	13	19	21	31	150x100	150x100
228	20	30	8	12	13	19	21	31	150x100	150x100
229	20	30	8	12	13	19	21	31	150x100	150x100
230	20	30	8	12	13	19	21	31	150x100	150x100
231	20	30	8	12	13	19	21	31	150x100	150x100
232	20	30	8	12	13	19	21	31	150x100	150x100
233	20	20	8	8	13	13	21	21	150x100	150x100
314	20	30	8	12	13	19	21	31	150x100	150x100
315	20	30	8	12	13	19	21	31	150x100	150x100
316	20	30	8	12	13	19	21	31	150x100	150x100
318	20	30	8	12	13	19	21	31	150x100	150x100
319	30	45	8	18	13	28	21	46	150x100	150x100
322	20	30	8	12	13	19	21	31	150x100	150x100
323	30	45	8	18	13	28	21	46	150x100	150x100
324	30	45	8	18	13	28	21	46	150x100	150x100
325	20	30	8	12	13	19	21	31	150x100	150x100
326	20	30	8	12	13	19	21	31	150x100	150x100
327	30	45	8	18	13	28	21	46	150x100	150x100
328	30	45	8	18	13	28	21	46	150x100	150x100
329	20	20	8	8	13	13	21	21	150x100	150x100
414	20	20	8	8	13	13	21	21	150x100	150x100
415	20	30	8	12	13	19	21	31	150x100	150x100
416	20	20	8	8	13	13	21	21	150x100	150x100
417	20	30	8	12	13	19	21	31	150x100	150x100
B14	20	30	8	12	13	19	21	31	150x100	150x100
B19	20	30	8	12	13	19	21	31	150x100	150x100
B20	20	30	8	12	13	19	21	31	150x100	150x100
B21	20	30	8	12	13	19	21	31	150x100	150x100
B23	20	20	8	8	13	13	21	21	150x100	150x100
B25	20	20	8	8	13	13	21	21	150x100	150x100
B26	20	20	8	8	13	13	21	21	150x100	150x100
B27	20	20	8	8	13	13	21	21	150x100	150x100
B34	20	30	8	12	13	19	21	31	150x100	150x100
G15	30	45	8	18	13	28	21	46	150x100	150x100
G18	30	45	8	18	13	28	21	46	150x100	150x100
G21	20	20	8	8	13	13	21	21	150x100	150x100
G22	20	20	8	8	13	13	21	21	150x100	150x100
G24	20	20	8	8	13	13	21	21	150x100	150x100
G25	20	30	8	12	13	19	21	31	150x100	150x100
G29	20	30	8	12	13	19	21	31	150x100	150x100


CORRIDORS SEE INDIVIDUAL CORRIDOR VENT RATES IN SCHEMATH Ø100 Ø100



FIRST FLOOR




GROUND FLOOR




BASEMENT


ROOF




FOURTH FLOOR




THIRD FLOOR




SECOND FLOOR



FIRST FLOOR




GROUND FLOOR




BASEMENT


ROOF




FOURTH FLOOR




THIRD FLOOR



SECOND FLOOR



FIRST FLOOR




GROUND FLOOR




BASEMENT


ROOF




FOURTH FLOOR




THIRD FLOOR




SECOND FLOOR



FIRST FLOOR




GROUND FLOOR




BASEMENT


ROOF




FOURTH FLOOR




THIRD FLOOR




SECOND FLOOR



FIRST FLOOR




GROUND FLOOR




BASEMENT

ROOF



FOURTH FLOOR



THIRD FLOOR

