



Typical Tree Protection Fencing Detail

PRELIMINARY TREE
IMPACT ASSESSMENT
TO BS 5837 (2012)

PRICE &
MYERS

Including Tree
Protection
Plan Notes

NOTE

The drawing suggests that the new development is outside the basic RPA for this tree.

BS5837 cl 4.6.2 suggests that account might need to be taken for asymmetric rooting due to site constraints such as existing buildings. This suggests that a true RPA for this tree might be shifted to the left on the plan as drawn, bringing the new developed area (shaded red) into the RPA.

However, with an overall RPA of 132 sqm, the encroachment of c.1.0sqm would be less than 1% and therefore likely to have negligible impact.

Job No. 31173 Page SK T01 Rev 2
Date Feb 2024 Eng AT Chd -

Job 8-9 Murray Street
revisions: v2 - tree protection plan measures added

Notes

* Do not scale for construction purposes.

all information contained in this drawing is sole copyright of hugh strange architects

project 8-9 Murray Street

drawing Proposed Ground Floor Plan

job. no. 63 dwg. no. 101 rev. A scale 1:100 @ A3 date Oct 2023

issued for Planning

hugh
strange
architects

www.hughstrange.com
020 8691 0494

