

[REDACTED]

---

**From:** BCTAdmin@thameswater.co.uk  
**Sent:** 09 April 2025 13:47  
**To:** Planning  
**Subject:** Informative Only Planning Application - 2025/1375/P

London Borough of Camden  
Camden Town Hall  
Argyle Street  
Euston Road  
London  
WC1H 8EQ

Our DTS Ref: 106772  
Your Ref: 2025/1375/P

9 April 2025

Dear Sir/Madam

Re: LAMORNA , DARTMOUTH PARK ROAD, LONDON, NW5 1SU

waste comments:

With regard to SURFACE WATER drainage, Thames Water would advise that if the developer follows the sequential approach to the disposal of surface water we would have no objection. Management of surface water from new developments should follow Policy SI 13 Sustainable drainage of the London Plan 2021. Where the developer proposes to discharge to a public sewer, prior approval from Thames Water Developer Services will be required. Should you require further information please refer to our website.

[REDACTED]

The proposed development is located within 15 metres of our underground waste water assets and as such we would like the following informative attached to any approval granted. "The proposed development is located within 15 metres of Thames Waters underground assets and as such, the development could cause the assets to fail if appropriate measures are not taken. Please read our guide 'working near our assets' to ensure your workings are in line with the necessary processes you need to follow if you're considering working above or near our pipes or other structures.

[REDACTED]

[REDACTED] Should you require further information please contact Thames Water. Email: developer.services@thameswater.co.uk Phone: 0800 009 3921 (Monday to Friday, 8am to 5pm) Write to: Thames Water Developer Services, Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB

Thames Water would advise that with regard to WASTE WATER NETWORK and SEWAGE TREATMENT WORKS infrastructure capacity, we would not have any objection to the above planning application, based on the information provided.

As required by Building regulations part H paragraph 2.36, Thames Water requests that the Applicant should incorporate within their proposal, protection to the property to prevent sewage flooding, by installing a positive pumped device (or equivalent reflecting technological advances), on the assumption that the sewerage network may surcharge to ground level during storm conditions. If as part of the basement development there is a proposal to discharge ground water to the public network, this would require a Groundwater Risk Management Permit from Thames Water. Any discharge made without a permit is deemed illegal and may result in prosecution under the provisions of the Water Industry Act 1991. We would expect the developer to demonstrate what measures will be undertaken to minimise groundwater discharges into the public sewer. Permit enquiries should be directed to Thames Water's Risk Management Team by telephoning 02035779483 or by emailing [trade.effluent@thameswater.co.uk](mailto:trade.effluent@thameswater.co.uk). Application forms should be completed on line via <https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.thameswater.co.uk%2F&data=05%7C02%7Cplanning%40camden.gov.uk%7Cb72e03ecdfff477407e108dd7764acaa%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638797996483700342%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIlwLjAuMDAwMCIslIAiOiJXaW4zMilslkFOljoiTWFpbGlldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=UnoLBufd7UjKzyJ5ydvBi20c%2BNKxZ4pjW6h0FLmxwMw%3D&reserved=0>. Please refer to the Wholesale; Business customers; Groundwater discharges section.

water comments:

If you are planning on using mains water for construction purposes, it's important you let Thames Water know before you start using it, to avoid potential fines for improper usage. More information and how to apply can be found online at [thameswater.co.uk/buildingwater](http://thameswater.co.uk/buildingwater).

On the basis of information provided, Thames Water would advise that with regard to water network and water treatment infrastructure capacity, we would not have any objection to the above planning application. Thames Water recommends the following informative be attached to this planning permission. Thames Water will aim to provide customers with a minimum pressure of 10m head (approx 1 bar) and a flow rate of 9 litres/minute at the point where it leaves Thames Waters pipes. The developer should take account of this minimum pressure in the design of the proposed development.

Yours faithfully  
Development Planning Department

Development Planning,  
Thames Water,  
Maple Lodge STW,  
Denham Way,  
Rickmansworth,  
WD3 9SQ  
Tel:020 3577 9998  
Email: [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk)

This is an automated email, please do not reply to the sender. If you wish to reply to this email, send to [devcon.team@thameswater.co.uk](mailto:devcon.team@thameswater.co.uk) Visit us online <https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.thameswater.co.uk%2F&data=05%7C02%7Cplanning%40camden.gov.uk%7Cb72e03ecdfff477407e108dd7764acaa%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638797996483715052%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIlwLjAuMDAwMCIslIAiOiJXaW4zMilslkFOljoiTWFpbGlldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=UnoLBufd7UjKzyJ5ydvBi20c%2BNKxZ4pjW6h0FLmxwMw%3D&reserved=0>

MDAwMClslIAiOiJXaW4zMilslkFOIjoiTWfPbClslldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=SHzG%2B5GLmZazRxwj5eLo8thAWOH1DpkkVGGZySO8RCM%3D&reserved=0 , follow us on twitter  
<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.twitter.com%2Fthameswater&data=05%7C02%7Cplanning%40camden.gov.uk%7Cb72e03ecdfff477407e108dd7764acaa%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638797996483729704%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIwLjAuMDAwMClslIAiOiJXaW4zMilslkFOIjoiTWfPbClslldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=9lhGsHhVNZd6jezlOBH0OVQ1Tbpb%2Ffa0SorxiyfeY0s%3D&reserved=0> or find us on  
<https://eur03.safelinks.protection.outlook.com/?url=http%3A%2F%2Fwww.facebook.com%2Fthameswater&data=05%7C02%7Cplanning%40camden.gov.uk%7Cb72e03ecdfff477407e108dd7764acaa%7C5e8f4a342bdb4854bb42b4d0c7d0246c%7C0%7C0%7C638797996483744692%7CUnknown%7CTWFpbGZsb3d8eyJFbXB0eU1hcGkiOnRydWUsIlYiOiIwLjAuMDAwMClslIAiOiJXaW4zMilslkFOIjoiTWfPbClslldUljoyfQ%3D%3D%7C0%7C%7C%7C&sdata=T4gKGNABNrwkuGBQZLFJuNHDCPWxWgxZhPrC1ACc8AI%3D&reserved=0>. We're happy to help you 24/7.

Thames Water Limited (company number 2366623) and Thames Water Utilities Limited (company number 2366661) are companies registered in England and Wales, both are registered at Clearwater Court, Vastern Road, Reading, Berkshire RG1 8DB. This email is confidential and is intended only for the use of the person it was sent to. Any views or opinions in this email are those of the author and don't necessarily represent those of Thames Water Limited or its subsidiaries. If you aren't the intended recipient of this email, please don't copy, use, forward or disclose its contents to any other person – please destroy and delete the message and any attachments from your system.