


Service	Service Ref	System	Manufacturer	Plant	Location	Model	DIMENSIONS (WEIGHT)
AC	0.01	COLD ROOM	MITSUBISHI	COLD ROOM CONDENSER	ROOFLANT	CR-MP1M22028P000	1055X430X819 103
AC	0.02	FREEZER	MITSUBISHI	FREEZER CONDENSER	ROOFLANT	NG-PQM0881P000	1055X430X819 102
AC	0.03	R134A AC	MITSUBISHI	AC OUTDOOR CONDENSER	ROOFLANT	PUE-M2501W42	1050X330X1338 138
AC	0.04	R134A AC	MITSUBISHI	AC OUTDOOR CONDENSER	ROOFLANT	PUE-M2501W42	1050X330X1338 138

450X450 EFFLUX VELOCITY BETWEEN 12M/S-15M/S

ANTI VIBRATION MOUNTS TO BE USED TO SUPPORT DUCTWORK

This side of line detail obscured

Scale Bar
1:50



NOTES

DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS MUST BE CHECKED/VERIFIED ON SITE.

THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE LATEST ARCHITECTURAL, STRUCTURAL & BUILDING SERVICES DRAWINGS & SPECIFICATIONS.

ALL DIMENSIONS ARE IN MILLIMETERS UNLESS NOTED OTHERWISE. ALL LEVELS ARE IN METERS UNLESS NOTED OTHERWISE.

ANY DISCREPANCIES SHOULD BE BROUGHT TO THE ATTENTION. IF IN DOUBT, ASK.

THIS DRAWING MUST NOT BE USED FOR INSTALLATION PURPOSES. THE CONTRACTOR SHALL PRODUCE INSTALLATION DRAWINGS.

ALL FIRE DAMPER POSITIONS TO BE CONFIRMED BY ARCHITECT /BUILDING CONTROL.

ACCESS PANELS THROUGH SOLID CEILINGS REQUIRED FOR MECHANICAL SERVICES ACCESS. MECHANICAL CONTRACTOR TO CONFIRM FINAL LOCATIONS AND NUMBER TO SUIT INSTALLED SERVICES.

ACCESS PANELS TO BE FITTED TO DUCTWORK FOR ACCESS TO FDS

CLEAR UNOBSTRUCTED ACCESS MUST BE MAINTAINED TO HIGH LEVEL HRUs, FANS, VALVES, DAMPERS AND ACCESS PANELS PROVIDED FOR INSTALLATION AND FUTURE MAINTENANCE.

WHERE INVERT LEVELS HAVE BEEN INDICATED THESE ARE BASED ON THE DESIGN INFORMATION AND ARE APPROX. ALL LEVELS / CO-ORDINATION ARE SUBJECT TO SITE VALIDATION AND WORKING DRAWING PRODUCTION.

ATTENUATION REQUIREMENTS TO BE IN ACCORDANCE WITH THE PROJECT ACOUSTIC REPORT.

ALL SERVICES WHEREVER POSSIBLE ARE TO BE LOCATED WITHIN THE CEILING VOIDS OR PARTITIONS. ANY VISIBLE SERVICES ARE TO BE HIGHLIGHTED TO AND AGREED WITH THE ARCHITECT.

TECHNICAL SUBMISSIONS ARE TO BE ISSUED TO THE ARCHITECT BY CONTRACTOR FOR ANY VISIBLE SERVICE SUCH AS GRILLES, AC UNITS SENSORS /CONTROLLERS, BOOSTER SETS ETC FOR SIGN OFF.

FOR APPROVAL

A	For Approval	21/03/2025

Revision Notes



synecore
ELECTRICAL REFRIGERATION MECHANICAL

Synecore Ltd
Unit 1
Conqueror Court
Sittingbourne, Kent
ME10 5BH
Tel: 01795 509 509
Mobile: 07734 559 981
E-Mail: sales@synecore.co.uk
Web: www.synecore.co.uk

CLIENT

PROJECT

110/113 Tottenham Ct Rd,
London W1T 5AF

TITLE

ROOF LEVEL ELEVATION B-B
PLANT LAYOUT

Drawn By	DB	Checked By	PR	Approved By	--
Scale	1:50 @ A1	Drawing No.	7762-HVAC-102	Rev	A
Date	21/03/2025				