

| Application N | Consultees Name | Recipient Address | Received | Comment | Response |
|---------------|--|---|---------------------|---------|---|
| 2025/1412/L | Richard Simpson for Primrose Hill CAAC | 12A Manley Street London NW1 8LT NW1 8LT | 19/04/2025 11:14:02 | COMMNT | <p>PRIMROSE HILL CONSERVATION AREA ADVISORY COMMITTEE 12A Manley Street, London NW1 8LT</p> <p>16 April 2025</p> <p>11 Gloucester Crescent NW1 7DS 2025/1412/L</p> <p>No objection in principle, subject to the following.</p> <p>We would want to see a detail showing the edge detail at the junction between the 'Technatorch' bitumen felt roof system proposed and the zinc covering to the dormer cheeks, which is to be retained.</p> <p>We regret that the opportunity is not being taken to replace the existing dormer window itself with a window more appropriate to the Listed Building, and with enhanced energy efficiency. We also note that there is no mention of enhanced insulation to the recovered dormer roof.</p> <p>Richard Simpson FSA, Chair PHCAAC.</p> |
