

## Project name

**16 Whitfield Street - Refurbished BE GREEN**

As designed

Date: Fri Mar 14 17:29:20 2025

## Administrative information

## Building Details

Address: 16 Whitfield Street - Refurbished BE GREEN,  
London, W1T 2RA

## Certifier details

Name: Luke Taylor

Telephone number: 07887792272

Address: 150 Hutton Road, Shenfield, CM15 8NL

## Certification tool

Calculation engine: SBEM

Calculation engine version: v6.1.e.2

Interface to calculation engine: DesignBuilder SBEM

Interface to calculation engine version: v7.3.1

BRUKL compliance module version: v6.1.e.1

Foundation area [m<sup>2</sup>]: 3172.64The CO<sub>2</sub> emission and primary energy rates of the building must not exceed the targets

The building does not comply with England Building Regulations Part L 2021

Target CO <sub>2</sub> emission rate (TER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	2.47
Building CO <sub>2</sub> emission rate (BER), kgCO <sub>2</sub> /m <sup>2</sup> .annum	5.69
Target primary energy rate (TPER), kWh <sub>PE</sub> /m <sup>2</sup> .annum	25.75
Building primary energy rate (BPER), kWh <sub>PE</sub> /m <sup>2</sup> .annum	62.21
Do the building's emission and primary energy rates exceed the targets?	BER > TER    BPER > TPER

## The performance of the building fabric and fixed building services should achieve reasonable overall standards of energy efficiency

Fabric element	U <sub>a-Limit</sub>	U <sub>a-Calc</sub>	U <sub>i-Calc</sub>	First surface with maximum value
Walls*	0.26	0.35	0.35	3rd Floor - Office_W_9
Floors	0.18	0.17	0.2	0 Basement - FM office_S_3
Pitched roofs	0.16	-	-	No heat loss pitched roofs
Flat roofs	0.18	0.18	0.35	0 Basement - FM office_R_5
Windows** and roof windows	1.6	1.4	1.4	3rd Floor - Office_G_10
Rooflights***	2.2	-	-	No external rooflights
Personnel doors^	1.6	2.2	2.2	2nd Floor - Office_D_27
Vehicle access & similar large doors	1.3	-	-	No external vehicle access doors
High usage entrance doors	3	-	-	No external high usage entrance doors

U<sub>a-Limit</sub> = Limiting area-weighted average U-values [W/(m<sup>2</sup>K)]U<sub>i-Calc</sub> = Calculated maximum individual element U-values [W/(m<sup>2</sup>K)]U<sub>a-Calc</sub> = Calculated area-weighted average U-values [W/(m<sup>2</sup>K)]

\* Automatic U-value check by the tool does not apply to curtain walls whose limiting standard is similar to that for windows.

\*\* Display windows and similar glazing are excluded from the U-value check.    \*\*\* Values for rooflights refer to the horizontal position.

^ For fire doors, limiting U-value is 1.8 W/m<sup>2</sup>K

NB: Neither roof ventilators (inc. smoke vents) nor swimming pool basins are modelled or checked against the limiting standards by the tool.

Air permeability	Limiting standard	This building
m <sup>3</sup> /(h.m <sup>2</sup> ) at 50 Pa	8	8

## Building services

For details on the standard values listed below, system-specific guidance, and additional regulatory requirements, refer to the Approved Documents.

Whole building lighting automatic monitoring & targeting with alarms for out-of-range values	NO
Whole building electric power factor achieved by power factor correction	>0.95

### 1- REYQ16U VRV

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	4.3	6.3	-	1.9	0.89
<b>Standard value</b>	2.5*	5	N/A	2^	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

### 2- REYQ12U VRV

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	4.7	6.5	-	1.9	0.89
<b>Standard value</b>	2.5*	5	N/A	2^	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

### 3- REYQ18U VRV

	Heating efficiency	Cooling efficiency	Radiant efficiency	SFP [W/(l/s)]	HR efficiency
<b>This system</b>	4.4	6.2	-	1.9	0.89
<b>Standard value</b>	2.5*	5	N/A	2^	N/A
<b>Automatic monitoring &amp; targeting with alarms for out-of-range values for this HVAC system</b>					NO
* Standard shown is for all types >12 kW output, except absorption and gas engine heat pumps.					
^ Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.					

### 1- POU

	Water heating efficiency	Storage loss factor [kWh/litre per day]
<b>This building</b>	1	-
<b>Standard value</b>	1	N/A

### Zone-level mechanical ventilation, exhaust, and terminal units

ID	System type in the Approved Documents
A	Local supply or extract ventilation units
B	Zonal supply system where the fan is remote from the zone
C	Zonal extract system where the fan is remote from the zone
D	Zonal balanced supply and extract ventilation system
E	Local balanced supply and extract ventilation units
F	Other local ventilation units
G	Fan assisted terminal variable air volume units
H	Fan coil units
I	Kitchen extract with the fan remote from the zone and a grease filter
NB: Limiting SFP may be increased by the amounts specified in the Approved Documents if the installation includes particular components.	



Zone name	SFP [W/(l/s)]									HR efficiency	
ID of system type	A	B	C	D	E	F	G	H	I		
Standard value	0.3	1.1	0.5	2.3	2	0.5	0.5	0.4	1	Zone	Standard
0 Basement - WC Shower	-	-	0.4	-	-	-	-	-	-	-	N/A
0 Basement - WC	-	-	0.4	-	-	-	-	-	-	-	N/A
0 Basement - Shower Room	-	-	0.4	-	-	-	-	-	-	-	N/A
2nd Floor - Toilet	-	-	-	-	1.9	-	-	-	-	0.89	N/A
2nd Floor - Staircase	-	-	-	-	1.9	-	-	-	-	0.89	N/A
2nd Floor - Staircase	-	-	-	-	1.9	-	-	-	-	0.89	N/A
3rd Floor - WC	-	-	-	-	1.9	-	-	-	-	0.89	N/A

General lighting and display lighting		General luminaire	Display light source	
Zone name		Efficacy [lm/W]	Efficacy [lm/W]	Power density [W/m²]
	Standard value	95	80	0.3
3rd Floor - Office		120	-	-
0 Basement - FM office		120	-	-
0 Basement - Office		120	-	-
0 Ground Floor - Affordable Office		120	-	-
0 Ground Floor - Reception		120	15	9
2nd Floor - Office		120	-	-
1st Floor - Office		120	-	-
0 Basement - Circulation		120	-	-
0 Basement - WC Shower		120	-	-
0 Basement - Booster Tank		120	-	-
0 Basement - WC		120	-	-
0 Basement - Shower Room		120	-	-
0 Basement - Staircase		120	-	-
0 Basement - Cycle Store		120	-	-
0 Basement - Staircase		120	-	-
0 Basement - Staircase		120	-	-
0 Ground Floor - Cycle Store		120	-	-
0 Ground Floor - Staircase		120	-	-
0 Ground Floor - Staircase		120	-	-
0 Ground Floor - Staircase		120	-	-
2nd Floor - Toilet		120	-	-
2nd Floor - Staircase		120	-	-
2nd Floor - Staircase		120	-	-
1st Floor - WC		120	-	-
1st Floor - Staircase		120	-	-
1st Floor - Toilet		120	-	-
1st Floor - Staircase		120	-	-
3rd Floor - Staircase		120	-	-
3rd Floor - WC		120	-	-
3rd Floor - Staircase		120	-	-

**The spaces in the building should have appropriate passive control measures to limit solar gains in summer**

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
3rd Floor - Office	NO (-20.9%)	YES
0 Basement - FM office	N/A	N/A
0 Basement - Office	N/A	N/A
0 Ground Floor - Affordable Office	N/A	N/A
0 Ground Floor - Reception	YES (+13.4%)	YES
2nd Floor - Office	NO (-18.7%)	YES
1st Floor - Office	NO (-24.5%)	YES

**Regulation 25A: Consideration of high efficiency alternative energy systems**

Were alternative energy systems considered and analysed as part of the design process?	YES
Is evidence of such assessment available as a separate submission?	YES
Are any such measures included in the proposed design?	YES

# Technical Data Sheet (Actual vs. Notional Building)

## Building Global Parameters

	Actual	Notional
Floor area [m <sup>2</sup> ]	3615.2	3615.2
External area [m <sup>2</sup> ]	5212	5212
Weather	LON	LON
Infiltration [m <sup>3</sup> /hm <sup>2</sup> @ 50Pa]	8	3
Average conductance [W/K]	2072.74	1612.9
Average U-value [W/m <sup>2</sup> K]	0.4	0.31
Alpha value* [%]	16.55	19.55

\* Percentage of the building's average heat transfer coefficient which is due to thermal bridging

## Building Use

% Area	Building Type
	Retail/Financial and Professional Services
	Restaurants and Cafes/Drinking Establishments/Takeaways
100	<b>Offices and Workshop Businesses</b>
	General Industrial and Special Industrial Groups
	Storage or Distribution
	Hotels
	Residential Institutions: Hospitals and Care Homes
	Residential Institutions: Residential Schools
	Residential Institutions: Universities and Colleges
	Secure Residential Institutions
	Residential Spaces
	Non-residential Institutions: Community/Day Centre
	Non-residential Institutions: Libraries, Museums, and Galleries
	Non-residential Institutions: Education
	Non-residential Institutions: Primary Health Care Building
	Non-residential Institutions: Crown and County Courts
	General Assembly and Leisure, Night Clubs, and Theatres
	Others: Passenger Terminals
	Others: Emergency Services
	Others: Miscellaneous 24hr Activities
	Others: Car Parks 24 hrs
	Others: Stand Alone Utility Block

## Energy Consumption by End Use [kWh/m<sup>2</sup>]

	Actual	Notional
Heating	0.98	1.11
Cooling	6.32	4.55
Auxiliary	8.2	7.05
Lighting	13.49	9.53
Hot water	15.4	15.4
Equipment*	37.59	37.59
<b>TOTAL**</b>	<b>44.39</b>	<b>37.65</b>

\* Energy used by equipment does not count towards the total for consumption or calculating emissions.

\*\* Total is net of any electrical energy displaced by CHP generators, if applicable.

## Energy Production by Technology [kWh/m<sup>2</sup>]

	Actual	Notional
Photovoltaic systems	2.1	20.17
Wind turbines	0	0
CHP generators	0	0
Solar thermal systems	0	0
<i>Displaced electricity</i>	<i>2.1</i>	<i>20.17</i>

## Energy & CO<sub>2</sub> Emissions Summary

	Actual	Notional
Heating + cooling demand [MJ/m <sup>2</sup> ]	140.52	107.45
Primary energy [kWh <sub>PE</sub> /m <sup>2</sup> ]	62.21	25.75
Total emissions [kg/m <sup>2</sup> ]	5.69	2.47



HVAC Systems Performance										
System Type	Heat dem MJ/m2	Cool dem MJ/m2	Heat con kWh/m2	Cool con kWh/m2	Aux con kWh/m2	Heat SSEFF	Cool SSEER	Heat gen SEFF	Cool gen SEER	
[ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
Actual	13.5	113.4	0.9	8	9	4.05	3.95	4.3	6.3	
Notional	13	92.5	1.4	5.8	8.2	2.64	4.4	----	----	
[ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
Actual	29.8	70	1.9	4.8	8.9	4.43	4.08	4.7	6.5	
Notional	14	60.3	1.5	3.8	7	2.64	4.4	----	----	
[ST] Variable refrigerant flow, [HS] ASHP, [HFT] Electricity, [CFT] Electricity										
Actual	14.6	106.4	1	7.6	9	4.15	3.89	4.4	6.2	
Notional	11.1	84.5	1.2	5.3	7.8	2.64	4.4	----	----	
[ST] No Heating or Cooling										
Actual	268.9	27.9	0	0	2.4	0	0	0	0	
Notional	180	22.3	0	0	2	0	0	----	----	

### Key to terms

Heat dem [MJ/m2]	= Heating energy demand
Cool dem [MJ/m2]	= Cooling energy demand
Heat con [kWh/m2]	= Heating energy consumption
Cool con [kWh/m2]	= Cooling energy consumption
Aux con [kWh/m2]	= Auxiliary energy consumption
Heat SSEFF	= Heating system seasonal efficiency (for notional building, value depends on activity glazing class)
Cool SSEER	= Cooling system seasonal energy efficiency ratio
Heat gen SSEFF	= Heating generator seasonal efficiency
Cool gen SSEER	= Cooling generator seasonal energy efficiency ratio
ST	= System type
HS	= Heat source
HFT	= Heating fuel type
CFT	= Cooling fuel type