

Application ref: 2024/0012/P
Contact: Edward Hodgson
Tel: 020 7974 8186
Email: Edward.Hodgson@camden.gov.uk
Date: 21 May 2025

Development Management
Regeneration and Planning
London Borough of Camden
Town Hall
Judd Street
London
WC1H 9JE

Phone: 020 7974 4444

planning@camden.gov.uk
www.camden.gov.uk/planning

Savills
33 Margaret Street
London
W1G 0JD

Dear Sir/Madam

DECISION

Town and Country Planning Act 1990 (as amended)

Full Planning Permission Granted Subject to a Section 106 Legal Agreement

Address:
194 Goldhurst Terrace
London
NW6 3HN

Proposal:

Demolition of single storey side extensions and erection of three storey side extension, together with excavation of part basement and lightwells to create 8no. flats and associated external alterations to roof and windows. Relocation and rebuilding of existing detached garage and single storey side and rear extensions to create 1no. house together with basement excavation.

Drawing Nos:

Existing Drawings: Site Location Plan L.01, EX.01, EX.02, EX.03, EX.04, EX.05, EX.06, EX.07 A, EX.08 A, EX.09, EX.10, EX.11 A EX.12, EX.13, EX.14, EX.15, EX.16

Proposed Drawings: P.01 C, P.02 D, P.03 C, P.04 C, P.05 C, P.06 C, P.07 A, P.08 C, P.09 C, P.10 C, P.11 B, P.12 B, P.13 A, P.14 A, P.15 B, P.16 A, P.17 C, P.18 A

Supporting Documents: Basement Impact Assessment (rev 3, dated Sept 2024), Flood Risk Assessment and SUDS strategy (C3146-R1-REV-G), C3146-03 Rev A, Nocturnal Bat Roost Survey, Preliminary Ecological Appraisal and Preliminary Roost Assessment (version 4), Energy & Sustainability Report, Tree Protection Plan, Arboricultural Impact Assessment (20/12/2023), Internal Daylight and Sunlight within Development Report (Jan 2024), Garage Relocation Method Statement, Heritage Impact Assessment, Planning Statement, Cover Letter, Daylight/Sunlight Assessment (Dec 2023)

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby permitted shall be carried out in accordance with the following approved plans:

Existing Drawings: Site Location Plan L.01, EX.01, EX.02, EX.03, EX.04, EX.05, EX.06, EX.07 A, EX.08 A, EX.09, EX.10, EX.11 A EX.12, EX.13, EX.14, EX.15, EX.16

Proposed Drawings: P.01 C, P.02 D, P.03 C, P.04 C, P.05 C, P.06 C, P.07 A, P.08 C, P.09 C, P.10 C, P.11 B, P.12 B, P.13 A, P.14 A, P.15 B, P.16 A, P.17 C, P.18 A

Supporting Documents: Basement Impact Assessment (rev 3, dated Sept 2024), Flood Risk Assessment and SUDS strategy (C3146-R1-REV-G), C3146-03 Rev A, Nocturnal Bat Roost Survey, Preliminary Ecological Appraisal and Preliminary Roost Assessment (version 4), Energy & Sustainability Report, Tree Protection Plan, Arboricultural Impact Assessment (20/12/2023), Internal Daylight and Sunlight within Development Report (Jan 2024), Garage Relocation Method Statement, Heritage Impact Assessment, Planning Statement, Cover Letter, Daylight/Sunlight Assessment (Dec 2023)

Reason: For the avoidance of doubt and in the interest of proper planning.

- 3 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies D1 and D2 of the London Borough of Camden Local Plan 2017.

- 4 No development other than demolition and enabling works shall not commence until such time as a suitably qualified chartered engineer with membership of the appropriate professional body has been appointed to inspect, check for compliance with the design (as approved by the local planning authority and building control body) and monitor the critical elements of both permanent and temporary basement construction works throughout their duration. Details of the appointment and the appointee's responsibilities shall be submitted to and approved in writing by the local planning authority prior to the commencement of development. Any subsequent change or reappointment shall be confirmed forthwith for the duration of the construction works.

Reason: To ensure proper consideration of the structural stability of neighbouring buildings and to safeguard the appearance and character of the immediate area in accordance with the requirements of policies D1, D2 and A5 of the London Borough of Camden Local Plan 2017.

- 5 The development shall not be carried out other than in strict accordance with the methodologies, recommendations and requirements of the Basement Impact Assessment (Axiom Structures, Rev P3 dated Sept 2024) hereby approved, and the confirmation at the detailed design stage that the damage impact assessment would be limited to Burland Category 1.

Reason: To ensure proper consideration of the structural stability of neighbouring buildings and to safeguard the appearance and character of the immediate area in accordance with the requirements of policies D1, D2 and A5 of the London Borough of Camden Local Plan 2017.

- 6 Prior to the commencement of construction/demolition works on site, tree protection measures shall be installed in accordance with approved Tree Protection Plan. The protection shall then remain in place for the duration of works on site and works should be undertaken in line with the approved arboricultural method statement, unless otherwise agreed in writing by the local authority.

Reason: To ensure that the development will not have an adverse effect on existing trees and in order to maintain the character and amenity of the area in accordance with the requirements of policies A2 and A3 of the London Borough of Camden Local Plan 2017.

- 7 No development other than demolition and enabling work shall take place until full details of hard and soft landscaping and means of enclosure of all un-built, open areas have been submitted to and approved by the local planning authority in writing. [Such details shall include details of any proposed replacement planting and post planting maintenance, earthworks including grading, mounding and other changes in ground levels.] The relevant part of the works shall not be carried out otherwise than in accordance with the details thus approved.

Reason: To ensure that the development achieves a high quality of landscaping which contributes to the visual amenity and character of the area in accordance with the requirements of policies A2, A3, A5, D1 and D2 of the London Borough of Camden Local Plan 2017.

- 8 All hard and soft landscaping works shall be carried out in accordance with the approved landscape details by not later than the end of the planting season

following completion of the development. Any trees or areas of planting which, within a period of 5 years from the completion of the development, die, are removed or become seriously damaged or diseased, shall be replaced as soon as is reasonably possible and, in any case, by not later than the end of the following planting season, with others of similar size and species, unless the local planning authority gives written consent to any variation.

Reason: To ensure that the landscaping is carried out within a reasonable period and to maintain a high quality of visual amenity in the scheme in accordance with the requirements of policies A2, A3, A5, D1 and D2 of the London Borough of Camden Local Plan 2017.

- 9 Prior to first occupation of the development a plan showing details of bat box locations and types suitable for pipistrelle bats to be accommodated shall be submitted to and approved in writing by the local planning authority. The boxes shall be installed in accordance with the approved plans prior to the occupation of the development and thereafter retained.

Reason: In order to secure appropriate features to conserve and enhance wildlife habitats and biodiversity measures within the development, in accordance with the requirements of the London Plan 2021 and Policies A3 and CC2 of the London Borough of Camden Local Plan 2017.

- 10 The development hereby approved shall achieve a maximum internal water use of 110litres/person/day. The dwelling/s shall not be occupied until the Building Regulation optional requirement has been complied with.

Reason: To ensure the development contributes to minimising the need for further water infrastructure in an area of water stress in accordance with Policies CC1, CC2, CC3 of the London Borough of Camden Local Plan 2017.

- 11 Before the relevant part of the work is begun, detailed drawings, or samples of materials as appropriate, in respect of the following, shall be submitted to and approved in writing by the local planning authority:

a) Details including sections at 1:10 of all windows (including jambs, head and cill), external doors and gates;

b) Manufacturer's specification details of all facing materials (to be submitted to the Local Planning Authority) and samples of those materials (to be provided on site).

The relevant part of the works shall be carried out in accordance with the details thus approved and all approved samples shall be retained on site during the course of the works.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies D1 and D2 of the London Borough of Camden Local Plan 2017.

- 12 Prior to occupation, details of secure and covered cycle storage area for 18

cycles shall be submitted to and approved by the local planning authority. The approved facility shall thereafter be provided in its entirety prior to the first occupation of any of the new units, and permanently retained thereafter.

Reason: To ensure the development provides adequate cycle parking facilities in accordance with the requirements of policy T1 of the London Borough of Camden Local Plan 2017.

- 13 Prior to commencement of development excluding demolition and enabling works, full details in respect of the living roof in the area indicated on the approved roof plan shall be submitted to and approved by the local planning authority. The details shall include:
- i. a detailed scheme of maintenance
 - ii. sections at a scale of 1:20 with manufacturers details demonstrating the construction and materials used
 - iii. full details of planting species and density

The living roofs shall be fully provided in accordance with the approved details prior to first occupation and thereafter retained and maintained in accordance with the approved scheme.

Reason: In order to ensure the development undertakes reasonable measures to take account of biodiversity and the water environment in accordance with policies D1, D2 and A3 of the London Borough of Camden Local Plan 2017.

- 14 Prior to commencement of works (excluding demolition and enabling works), details, drawings and data sheets showing the location, Seasonal Performance Factor of at least 2.5 and Be Green stage carbon saving of the ground source heat pumps and associated equipment to be installed on the building, shall have been submitted to and approved by the Local Planning Authority in writing. The measures shall include the installation of a metering details including estimated costs to occupants and commitment to monitor performance of the system post construction. A site-specific lifetime maintenance schedule for each system, including safe access arrangements, shall be provided. The equipment shall be installed in full accordance with the details approved by the Local Planning Authority and permanently retained and maintained thereafter.

Reason: To ensure the development provides adequate on-site renewable energy facilities in accordance with the requirements of policy CC1 of the London Borough of Camden Local Plan 2017.

- 15 No lights, meter boxes, flues, vents or pipes, and no telecommunications equipment, alarm boxes, television aerials or satellite dishes shall be fixed or installed on the external face of the buildings, without the prior approval in writing of the Council.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policies D1 and D2 of the Camden Local Plan 2017

- 16 Prior to commencement of above ground development and excluding demolition and enabling works, full details in respect of the following shall be submitted to and approved in writing by the Local Planning Authority:
- a. Flood Risk Emergency Plan should be prepared in accordance with the aims and objectives of the ADEPT/Environment Agency Flood Risk Emergency Plans for New Development guidance and submitted to the Local Planning Authority and approved in writing. The details should include flood warning and alarm system in accordance with the approval.
 - b. The proposed internal water efficiency and/or water recycling equipment to ensure that the development will pose no additional impact on adjoining sites or the existing drainage infrastructure; and
 - c. the proposed measures to ensure the development has been designed to mitigate flood risk and cope with potential flooding in accordance with the approval. These measures should include at the minimum:
 - No air vents on the basements that have lightwells above,
 - glass walls (with flood proof grade/flood glazing) surrounding the basement lightwells,
 - electricity consumer unit and mains connection point, and all water, electricity and gas metres, boiler units and ancillary devices to be located 1000mm above basement floor level,
 - installation of non return valves for the basement and ground floors,
 - adequate sealing of joints between internal units, and
 - flood proof doors and windows on the basement floors at the front and rear of the site.

Reason: To reduce impact of the development and ensure it is resilient to climate change in accordance with policies CC2, CC3 and A5 of the London Borough of Camden Local Plan 2017

- 17 Prior to commencement of above-ground development and excluding demolition and enabling works, full details of the sustainable drainage system no less than 15.5m³ of water storage capacity, including details of wall mounted rainwater harvesting, green blue roofs, and below-ground attenuation tank shall be submitted to and approved in writing by the local planning authority. Such a system should be designed to accommodate all storms up to and including a 1:100 year storm with a 40% provision for climate change such that flooding does not occur in any part of a building or in any utility plant susceptible to water, or on any part of the entire development site for up to and including a 1:30 year storm.

The details shall demonstrate a site run-off rate conforming to not more than 0.5l/s approved by the Local Planning Authority. An up to date drainage statement, SuDS pro-forma, a lifetime maintenance plan and supporting evidence should be provided including:

- The proposed SuDS or drainage measures including storage capacities
- The proposed surface water discharge rates or volumes

Systems shall thereafter be retained and maintained in accordance with the

approved details.

Reason: To reduce the rate of surface water run-off from the buildings and limit the impact on the storm-water drainage system in accordance with policies CC2 and CC3 of the London Borough of Camden Local Plan 2017 and Policy SI 13 of the London Plan 2021.

- 18 All non-Road mobile Machinery (any mobile machine, item of transportable industrial equipment, or vehicle - with or without bodywork) of net power between 37kW and 560kW used on the site for the entirety of the construction phase of the development hereby approved shall be required to meet Stage IIIB of EU Directive 97/68/EC. The site shall be registered on the NRMM register for the construction phase of the development.

Reason: To safeguard the amenities of the adjoining occupiers, the area generally and contribution of developments to the air quality of the borough in accordance with the requirements of policies G1, A1, CC1 and CC4 of the London Borough of Camden Local Plan 2017.

- 19 The sustainability, energy efficiency and renewable energy measures shall be carried out in accordance with the approved Energy and Sustainability Report (version 4 dated 15/01/2024).

Reason: Reason: To ensure the proposal is energy efficient and sustainable in accordance with policy CC1 and CC2 of the London Borough of Camden Local Plan 2017.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts that cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Judd St, Kings Cross, London NW1 2QS (tel: 020-7974 6941).
- 2 All works should be conducted in accordance with the Camden Minimum Requirements - a copy is available on the Council's website (search for 'Camden Minimum Requirements' at www.camden.gov.uk) or contact the Council's Noise and Licensing Enforcement Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444)

Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You must secure the approval of the Council's Noise and Licensing Enforcement Team prior to undertaking such activities outside these hours.

- 3 This approval does not authorise the use of the public highway. Any requirement to use the public highway, such as for hoardings, temporary road

closures and suspension of parking bays, will be subject to approval of relevant licence from the Council's Streetworks Authorisations & Compliance Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No 020 7974 4444). Licences and authorisations need to be sought in advance of proposed works. Where development is subject to a Construction Management Plan (through a requirement in a S106 agreement), no licence or authorisation will be granted until the Construction Management Plan is approved by the Council.

- 4 You are advised that Section 44 of the Deregulation Act 2015 [which amended the Greater London Council (General Powers) Act 1973]] only permits short term letting of residential premises in London for up to 90 days per calendar year. The person who provides the accommodation must be liable for council tax in respect of the premises, ensuring that the relaxation applies to residential, and not commercial, premises.
- 5 Your attention is drawn to the fact that there is a separate legal agreement with the Council which relates to the development for which this permission is granted. Information/drawings relating to the discharge of matters covered by the Heads of Terms of the legal agreement should be marked for the attention of the Planning Obligations Officer, Sites Team, Camden Town Hall, Argyle Street, WC1H 8EQ.
- 6 You are reminded of the need to provide adequate space for internal and external storage for waste and recyclables. For further information contact Council's Environment Services (Waste) on 020 7974 6914/5 or see the website <http://www.camden.gov.uk/ccm/content/environment/waste-and-recycling/twocolumn/new-recycling-rubbish-and-reuse-guide.en>.
- 7 Biodiversity Net Gain (BNG) Informative (1/2):

The effect of paragraph 13 of Schedule 7A to the Town and Country Planning Act 1990 ("1990 Act") is that planning permission granted in England is subject to the condition ("the biodiversity gain condition") that development may not begin unless:

- (a) a Biodiversity Gain Plan has been submitted to the planning authority, and
- (b) the planning authority has approved the plan.

The local planning authority (LPA) that would approve any Biodiversity Gain Plan (BGP) (if required) is London Borough of Camden.

There are statutory exemptions and transitional arrangements which mean that the biodiversity gain condition does not always apply. These are summarised below, but you should check the legislation yourself and ensure you meet the statutory requirements.

Based on the information provided, this will not require the approval of a BGP before development is begun because it was submitted before 12th February 2024.

++ Summary of transitional arrangements and exemptions for biodiversity gain condition

The following are provided for information and may not apply to this permission:

1. The planning application was made before 12 February 2024.
2. The planning permission is retrospective.
3. The planning permission was granted under section 73 of the Town and Country Planning Act 1990 and the original (parent) planning permission was made or granted before 12 February 2024.
4. The permission is exempt because of one or more of the reasons below:
 - It is not “major development” and the application was made or granted before 2 April 2024, or planning permission is granted under section 73 and the original (parent) permission was made or granted before 2 April 2024.
 - It is below the de minimis threshold (because it does not impact an onsite priority habitat AND impacts less than 25 square metres of onsite habitat with biodiversity value greater than zero and less than 5 metres in length of onsite linear habitat).
 - The application is a Householder Application.
 - It is for development of a “Biodiversity Gain Site”.
 - It is Self and Custom Build Development (for no more than 9 dwellings on a site no larger than 0.5 hectares and consists exclusively of dwellings which are Self-Build or Custom Housebuilding).
 - It forms part of, or is ancillary to, the high-speed railway transport network (High Speed 2).

8 Biodiversity Net Gain (BNG) Informative (2/2):

+ Irreplaceable habitat:

If the onsite habitat includes Irreplaceable Habitat (within the meaning of the Biodiversity Gain Requirements (Irreplaceable Habitat) Regulations 2024) there are additional requirements. In addition to information about minimising adverse impacts on the habitat, the BGP must include information on

compensation for any impact on the biodiversity of the irreplaceable habitat. The LPA can only approve a BGP if satisfied that the impact on the irreplaceable habitat is minimised and appropriate arrangements have been made for compensating for any impact which do not include the use of biodiversity credits.

++ The effect of section 73(2D) of the Town and Country Planning Act 1990

If planning permission is granted under section 73, and a BGP was approved in relation to the previous planning permission ("the earlier BGP"), the earlier BGP may be regarded as approved for the purpose of discharging the biodiversity gain condition on this permission. It will be regarded as approved if the conditions attached (and so the permission granted) do not affect both the post-development value of the onsite habitat and any arrangements made to compensate irreplaceable habitat as specified in the earlier BGP.

++ Phased development

In the case of phased development, the BGP will be required to be submitted to and approved by the LPA before development can begin (the overall plan), and before each phase of development can begin (phase plans). The modifications in respect of the biodiversity gain condition in phased development are set out in Part 2 of the Biodiversity Gain (Town and Country Planning) (Modifications and Amendments) (England) Regulations 2024

- 9 This proposal may be liable for the Mayor of London's Community Infrastructure Levy (CIL) and the Camden CIL. Both CILs are collected by Camden Council after a liable scheme has started, and could be subject to surcharges for failure to assume liability or submit a commencement notice PRIOR to commencement. We issue formal CIL liability notices setting out how much you may have to pay once a liable party has been established. CIL payments will be subject to indexation in line with construction costs index. You can visit our planning website at www.camden.gov.uk/cil for more information, including guidance on your liability, charges, how to pay and who to contact for more advice. Camden adopted new CIL rates in October 2020 which can be viewed at the above link.
- 10 You are advised the developer and appointed / potential contractors should take the Council's guidance on Construction Management Plans (CMP) into consideration prior to finalising work programmes and must submit the plan using the Council's CMP pro-forma; this is available on the Council's website at <https://beta.camden.gov.uk/web/guest/construction-management-plans> or contact the Council's Planning Obligations Team, 5 Pancras Square c/o Town Hall, Judd Street London WC1H 9JE (Tel. No. 020 7974 4444). No development works can start on site until the CMP obligation has been discharged by the Council and failure to supply the relevant information may mean the council cannot accept the submission as valid, causing delays to

scheme implementation. Sufficient time should be afforded in work plans to allow for public liaison, revisions of CMPs and approval by the Council.

- 11 The Health and Safety Executive (HSE) states that work-related stress and poor mental health should be treated with the same significance as risks of poor physical health and injury. The Council views this as particularly pertinent to the construction industry, a predominantly male environment where the risk of suicide is around 3.5 times higher than men in general. Approximately one-third of construction workers report increased levels of anxiety every day. The Council strongly encourages developers of major construction sites to sign up to one of two construction industry led initiatives, Building Mental Health (Building Mental Health - Home) or Mates in Mind (Home Page), train a proportionate number of staff in Mental Health First Aid, and offer drop-in sessions/or spaces at construction sites for workers.

The Council will support the construction industry working in Camden with an offer of free Mental Health First Aid and other training, and information on local resources and signposting to sources of help.


In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with the National Planning Policy Framework. The council publishes its adopted policies online, along with detailed Camden Planning Guidance. It also provides advice on the website for submitting applications and offers a pre-application advice service.

You can find advice about your rights of appeal at:

<https://www.gov.uk/appeal-planning-decision>.

If you submit an appeal against this decision you are now eligible to use the new [submission form](#) (Before you start - Appeal a planning decision - GOV.UK).

Yours faithfully



Daniel Pope
Chief Planning Officer