

CONTAMINATION STATEMENT IN SUPPORT OF PLANNING APPLICATION FOR A NEW EYFS FACILITY AT GOSPEL OAK PRIMARY SCHOOL

19.12.2013

During the site investigation works asbestos contamination was discovered (page 20 of the Ground Investigation Report section 8.4) in one of the trial pits, however the extent of the contamination has not been confirmed.

In line with the Reports recommendations Camden have appointed an Asbestos Surveyor to carry out an asbestos survey in January 2014 with recommendations on remediation measures required for either the encapsulation of the asbestos or its removal.

Apart from the asbestos the Report did not find any other contaminants of concern.