

New rolled lead ridge (RF01) New breathable weatherproof membrane (W13) Inline Roof Vent Redland Rapid Roof Vent[–] or Similar New Plasterboard ceiling New foil backed rigid insulation Existing truses retained shown dotted Existing single skin brick wall 80 mm Rigid insulation 89 mm studwork Single layer of plasterboard

Exsiting timber floorboards carefully lifted and relaid following upgrade works. New floorboards to match where required

25 mm Cavity

New high density joist strips-New acoustic insulation -Corofil LFS or similar New fire-rated insulation -Corofil CF or similar

New galvanised steel carrier brackets and supports

New plasterboard ceiling

Floor build up: To exceed Part B & Part E Airborne & Impact Sound requirements as described on Table 1a.

·····



