

**Proposed Climate
Control System**

**Eleanor Palmer Primary School
Lupton Street, London NW5 2JA**

Environmental Noise Assessment



Author: Phil Huffer B.Sc. (Hons) MIOA
Principal Consultant

Doc Ref: 102479.ph.Issue1



Environmental Noise Assessment Proposed Climate Control System	
Project Address:	Eleanor Palmer Primary School Lupton Street London NW5 2JA
Project Reference:	102479

Issue/Revision Record			
Issue:	Date:	Remarks:	Author:
1	20/06/2013	First Issue	Phil Huffer

	Signature:	Print:	Title:	Date:
Author:		Phil Huffer	Principal Consultant	20/06/2013
Reviewer:		Andy Dodd	Consultant	20/06/2013

1. INTRODUCTION

- 1.1 Acoustics Plus Ltd (APL) is an independent firm of multi-disciplinary acoustic engineers. APL is a registered member of The Association of Noise Consultants (ANC) and the author is a corporate member of The Institute of Acoustics (IOA).
- 1.2 APL has been instructed by the Applicant, Eleanor Palmer Primary School, to consider and advise upon the noise implications of a proposed installation of a climate control system.
- 1.3 The proposed climate control system will consist of two outdoor air condenser units that will be mounted on the northern elevation of the proposed new ecospace outdoor structure.
- 1.4 It is understood the Local Planning Authority (LPA) require further information on noise levels from the proposed installation in order to fully assess the potential noise impact upon the surrounding neighbourhood. This report provides the response to the LPA, on behalf of the Applicant.

2. BASELINE SITUATION

- 2.1 The Application Site (the “site”) is situated at Lupton Street, London, NW5 2JA.
- 2.2 The site is a one form entry (30 children per year group) state funded non-selective community primary school for ages 3 -11, in the London Borough of Camden. The site is located at the junction of Lupton Street and Raveley Street, as shown in Diagram 1.




Diagram 1

- 2.3 It is proposed to remove an existing nursery store and replace it with an ecospace outdoor structure (see Diagram 2).




Diagram 2

- 2.4 As part of this proposal, it is the intention to provide mechanical climate control within the new building, which will require the installation of 2No. external air source heat pumps.
- 2.5 These heat pumps will be wall mounted on the northern façade of the new structure.
- 2.6 The nearest noise sensitive façade belongs to the first floor windows of No.1 Raveley St (as indicated on Figure 6). It should be noted that the neighbour of No.1 Raveley Street at 112 Fortress Road already has an existing wall mounted air source heat pump fixed to its front elevation (see Figure 8). The distance from the location of the nearest noise sensitive façade to the proposed location of the units was determined from laser measurements to be 22m.
- 2.7 Information in regard of the noise level from the air condenser units has been provided by Daikin HVAC (copy of the data sheet is provided in Appendix A). The units are itemised below:
- (a) 2No. Daikin RXS35

3. NOISE OUTLINE

3.1 In order to produce an environmental noise assessment, consideration must be given to the locality of the installation.

3.2 Measurements of background noise were obtained over a 24 hour period in a courtyard adjacent to the nursery school playground. Given the dominant source of background noise (in the absence of children playing) is likely to be traffic noise from Fortress Road, this position was deemed to be reflective of background noise levels experienced at the nearest noise sensitive façade.

3.3 The particulars of the measurement exercise are recorded below:

Date: 18th – 19th June 2013
 Start Time: 16:04 hrs.
 Location: courtyard adjacent to playground
 Weather: No wind, no precipitation.

3.4 The measurements carried out during the exercise are recorded below:

L₉₀ percentile level (dB re 20µPa) at 15 minute intervals

3.5 The measurements obtained during the exercise are presented in Appendix B.

3.6 For the sake of clarity, the lowest measured background noise over the anticipated operational hours of the condenser units is highlighted. As the units will be utilised for climate control of a school building, it is anticipated that the operational hours will be on a demand basis during the hours 08:00-18:00hrs.

3.7 Information regarding the noise levels not to be exceeded by the installation was extracted from the LPA (London Borough of Camden) Local Development Framework 2010-2025 Section DP28 Noise and Vibration:

Table E: Noise levels from plant and machinery at which planning permission will not be granted

Noise description and location of measurement	Period	Time	Noise level
Noise at 1 metre external to a sensitive façade	Day, evening and night	0000-2400	5dB(A) <LA90
Noise that has a distinguishable discrete continuous note (whine, hiss, screech, hum) at 1 metre external to a sensitive façade.	Day, evening and night	0000-2400	10dB(A) <LA90
Noise that has distinct impulses (bangs, clicks, clatters, thumps) at 1 metre external to a sensitive façade.	Day, evening and night	0000-2400	10dB(A) <LA90
Noise at 1 metre external to sensitive façade where LA90>60dB	Day, evening and night	0000-2400	55dB _{L_{Aeq}} '

3.8 The noise level of the condenser units was established from the data sheet provided (Appendix A) as follows:

(a) 2No. Daikin RXS35 @ 48dBA @ 1m (per unit)

4. EQUIPMENT

4.1 All measurements were obtained using the following equipment:

- Svantek Svan Type 948 Class 1 Serial No. 6988
- Rion Calibrator Type NC-74 Class 1 Serial No. 00410215

4.2 The relevant equipment carries full and current traceable calibration. The equipment, where necessary, was calibrated prior to and after the measurements were carried out.

5. CALCULATIONS

5.1 Given the proposed location of the condensing units, the propagation of noise from the condensing units to the noise sensitive façade opposite has been considered. The distance from the units to the nearest noise sensitive façade was determined as 22m.

5.2 Given the manufacturers stated noise output was determined from measurements obtained in an anechoic chamber, a correction of 3dB was added to the noise output of the units. This accounted for the reflecting plane behind the units as the units are proposed to be wall mounted.

5.3 The calculation exercise can be shown in Table 1 below. The distance attenuation is based on point source propagation.

Scenario	Noise level (dBA)
1No. Daikin RXS35 unit @ 1m	48
2No. Daikin RXS35 unit @ 1m	51 [48+3]
Reflecting plane correction (+3dB)	54 [51+3]
Point source propagation over 22m	-27 [20Log ₁₀ (22)]
Predicted level at nearest façade	27 [54-27]

Table 1

5.4 In order to comply with the requirements of the LPA, any noise from the proposed installation of two condensing units should not exceed a level of 30 dBA (10dB below the lowest measured background noise over the operational hours of the units).

- 5.5 The lowest measured background noise level was 40dB L_{A90} that occurred during the hours 14:19 – 14:34hrs on 19th August 2011.

6. CONCLUSION

- 6.1 The foregoing assessment indicates that the proposed installation will meet the requirements imposed by the LPA. Further mitigation measures will not be required.

Figures

Eleanor Palmer Primary School and surrounding area



Figure 1



Figure 2

Approximate
proposed
location of
plant (on end
wall of new
structure)



Figure 3



Figure 4




Figure 5



Figure 6

Nearest noise
sensitive
facade




Figure 7





Figure 8

Appendix A

9 Sound data

9 - 1 Sound Pressure Spectrum



Appendix B

Background noise measurements obtained at Eleanor Palmer Primary School,

Address	Time	Measurement Time	LAeq	LAmx	LAmn	LA90
1	18/06/2013 16:04	0:15:00	54	78	39	43
2	18/06/2013 16:19	0:15:00	50	78	38	42
3	18/06/2013 16:34	0:15:00	53	79	39	43
4	18/06/2013 16:49	0:15:00	54	79	38	42
5	18/06/2013 17:04	0:15:00	51	67	38	43
6	18/06/2013 17:19	0:15:00	52	82	38	42
7	18/06/2013 17:34	0:15:00	48	66	38	41
8	18/06/2013 17:49	0:15:00	50	75	38	41
9	18/06/2013 18:04	0:15:00	51	67	37	41
10	18/06/2013 18:19	0:15:00	53	70	37	41
11	18/06/2013 18:34	0:15:00	45	61	36	39
12	18/06/2013 18:49	0:15:00	51	73	35	40
13	18/06/2013 19:04	0:15:00	49	70	36	40
14	18/06/2013 19:19	0:15:00	51	69	36	41
15	18/06/2013 19:34	0:15:00	51	69	36	40
16	18/06/2013 19:49	0:15:00	51	66	36	40
17	18/06/2013 20:04	0:15:00	46	65	36	39
18	18/06/2013 20:19	0:15:00	50	69	35	39
19	18/06/2013 20:34	0:15:00	49	68	35	37
20	18/06/2013 20:49	0:15:00	51	71	34	38
21	18/06/2013 21:04	0:15:00	54	88	36	40
22	18/06/2013 21:19	0:15:00	54	73	36	39
23	18/06/2013 21:34	0:15:00	43	54	34	37
24	18/06/2013 21:49	0:15:00	46	66	35	38
25	18/06/2013 22:04	0:15:00	54	80	34	37
26	18/06/2013 22:19	0:15:00	44	57	35	38
27	18/06/2013 22:34	0:15:00	44	61	35	37
28	18/06/2013 22:49	0:15:00	51	69	34	36
29	18/06/2013 23:04	0:15:00	42	54	33	35
30	18/06/2013 23:19	0:15:00	42	56	32	34
31	18/06/2013 23:34	0:15:00	41	60	30	33
32	18/06/2013 23:49	0:15:00	40	52	31	34
33	19/06/2013 00:04	0:15:00	41	59	31	34
34	19/06/2013 00:19	0:15:00	41	53	32	34
35	19/06/2013 00:34	0:15:00	40	51	29	31
36	19/06/2013 00:49	0:15:00	39	54	30	32
37	19/06/2013 01:04	0:15:00	40	61	28	30
38	19/06/2013 01:19	0:15:00	42	66	29	31
39	19/06/2013 01:34	0:15:00	38	51	28	30
40	19/06/2013 01:49	0:15:00	39	52	29	31
41	19/06/2013 02:04	0:15:00	37	50	29	31
42	19/06/2013 02:19	0:15:00	40	61	29	30
43	19/06/2013 02:34	0:15:00	40	56	28	31
44	19/06/2013 02:49	0:15:00	39	60	29	30
45	19/06/2013 03:04	0:15:00	39	55	28	31
46	19/06/2013 03:19	0:15:00	39	53	29	31

Background noise measurements obtained at Eleanor Palmer Primary School,

Address	Time	Measurement Time	LAeq	LAmx	LAmn	LA90
47	19/06/2013 03:34	0:15:00	39	54	29	31
48	19/06/2013 03:49	0:15:00	40	55	30	33
49	19/06/2013 04:04	0:15:00	42	59	31	33
50	19/06/2013 04:19	0:15:00	42	69	30	33
51	19/06/2013 04:34	0:15:00	39	52	30	32
52	19/06/2013 04:49	0:15:00	39	55	29	32
53	19/06/2013 05:04	0:15:00	39	55	28	31
54	19/06/2013 05:19	0:15:00	43	57	31	33
55	19/06/2013 05:34	0:15:00	42	68	31	33
56	19/06/2013 05:49	0:15:00	46	64	32	34
57	19/06/2013 06:04	0:15:00	51	70	31	34
58	19/06/2013 06:19	0:15:00	49	65	34	37
59	19/06/2013 06:34	0:15:00	54	83	40	45
60	19/06/2013 06:49	0:15:00	51	63	36	41
61	19/06/2013 07:04	0:15:00	45	57	37	39
62	19/06/2013 07:19	0:15:00	49	68	39	41
63	19/06/2013 07:34	0:15:00	48	65	38	40
64	19/06/2013 07:49	0:15:00	54	83	37	40
65	19/06/2013 08:04	0:15:00	50	65	37	42
66	19/06/2013 08:19	0:15:00	55	81	36	42
67	19/06/2013 08:34	0:15:00	51	67	36	42
68	19/06/2013 08:49	0:15:00	50	65	40	43
69	19/06/2013 09:04	0:15:00	50	65	39	42
70	19/06/2013 09:19	0:15:00	52	77	40	44
71	19/06/2013 09:34	0:15:00	49	67	39	42
72	19/06/2013 09:49	0:15:00	47	64	39	42
73	19/06/2013 10:04	0:15:00	50	66	39	43
74	19/06/2013 10:19	0:15:00	50	68	39	43
75	19/06/2013 10:34	0:15:00	50	69	40	43
76	19/06/2013 10:49	0:15:00	53	76	42	45
77	19/06/2013 11:04	0:15:00	52	75	40	43
78	19/06/2013 11:19	0:15:00	49	66	39	43
79	19/06/2013 11:34	0:15:00	52	69	40	44
80	19/06/2013 11:49	0:15:00	58	90	39	42
81	19/06/2013 12:04	0:15:00	48	67	38	42
82	19/06/2013 12:19	0:15:00	49	68	39	43
83	19/06/2013 12:34	0:15:00	53	69	41	45
84	19/06/2013 12:49	0:15:00	55	76	41	46
85	19/06/2013 13:04	0:15:00	59	76	46	50
86	19/06/2013 13:19	0:15:00	54	83	40	45
87	19/06/2013 13:34	0:15:00	47	70	39	43
88	19/06/2013 13:49	0:15:00	52	70	39	42
89	19/06/2013 14:04	0:15:00	51	73	35	42
90	19/06/2013 14:19	0:15:00	52	76	36	40
91	19/06/2013 14:34	0:15:00	46	60	38	41