



N.B. Due to the smaller difference between finished and sdb levels in Coram Arcade no screed will be required in the area noted on drawing 8031




EDGE CONDITION 1*
- SHOP FRONT

- 1) granite 400x400mm sqs. spec ref 025/113 thickness 60mm
- 2) Cement based bedding layer 20mm - constant thickness 025/140
- 3) external screed - fall formed in the layer M10/1 is M10/21
- 4) existing waterproof removed within 200mm of perimeter junction and on to any vertical surface it laps
- 5) Waterproofing layer J31/1/10 bonded to existing floor or except of perimeter where the substrate will be the concrete slab
- 6) 1) surface mounted termination to be used on vertical face
- 6.2) Slab Pro-3 section or similar approved
- 7) continuous 60mm flexcell self joint to perimeter, the entire depth of build up.




EDGE CONDITION 2*
- DOOR THRESHOLD




EDGE CONDITION 3*
- CONCRETE JUNCTION


- 8) Slab Top 122 mill Spec ref 026/310 to provide flush substrate for waterproofing
- 9) granite slitting bonded to vertical face with hydrotech high bonding PU adhesive 6.5kg or similar approved




EDGE CONDITION 4*
- BOUNDARY TO RETAINING SURFACE




EDGE CONDITION 5 -
JUNCTION TO FRAMED GLASS CURTAIN WALL FRAME




EDGE CONDITION 6 - FREE PT
- EXPOS




EDGE CONDITION 7 -
SUPERMARKET NON-CONCRETE COLUMN BASE




DETAIL 8 - MOVEMENT JOINT THROUGH PAVING BUILD UP



DETAIL 9 - MULTI-SLOT DRAIN



DETAIL 10 - FRAMES FOR POSTS, LIGHT COLUMNS ETC



DETAIL 8* - CORAM ARCADE JUNCTION

consultants

notes

Do not scale this drawing
All dimensions to be checked by the Contractor where construction proceeds
This drawing is the copyright of Walters Gray International LP and shall not be in any way used or reproduced without their prior written consent.

rev date by app description

A	APR 13	SFG	CG	UPDATES TO COMMENTS, SPEC, REFS ADDED	location
B	22/01/13	SFG	CG	ADDITIONAL NOTE AND DETAIL FOR CORAM ARCADE	
C	28/01/13	SFG	CG	DETAIL, DIMENSIONS AS COORDINATED FOLLOWING INTERNAL REVIEW + COMMENTS	

WGI

ISSUED FOR
TENDER

Walters Gray International LP
Colechurch House, 1 London Bridge Walk, LONDON, SE1 2BX
Tel: 020 7940 8400 Fax: 020 7940 8444 mail@wgi.co.uk

Project Title
BRUNSWICK CENTRE

Drawing Title
PIAZZA LEVEL DETAILS

Typed Title	Drawing No.	Revision
112033	D3000	C

Typed Title	Drawing No.	Revision
112033	D3000	C