



25\_03

## SLAB EDGE DETAIL

SCALE 1:5 @ A3

### KEY:

- ① 50mm GYVLON SCREED BY LAFARGE -OR SIMILA APPROVED WITH UNDER FLOOR HEATING PIPES IMBEDDED-ON 20mm THERMAL INSULATION ON 5mm RESILIENT LAYER
- ② POLYESTER POWDER COATED FRAMED DOUBLE GLAZED SCREEN\*\*FIXED BY S.S. BRACKETS TO"CASTIN" CHANNEL . BOLT SPECIFICATION AND BRACKETING SPACING BY SPECILAIST DESIGNER.
- ③ POLYESTER POWDER COATED ALUMINIUM PRESSING CILL FIXED TO GLAZED SCREEN FRAME.COLOUR TO MATCH SCREEN FRAME
- ④ METSEC "C" SECTION FORMING A BOX -FIXED TO R.C. SLAB ALONG GLAZED SCREED OPENING - FILLED WITH THERMAL INSULATION
- ⑤ RUBEROID-OR SIMILAR APPROVED - HIGH PERFORMANCE DPC LAID OVER RUBEROID PRO BREATHER MEMBRANE
- ⑥ STEEL PROFILE TO S.E. DETAILS FIXED TO THE SLAB TO SUPPORT THE SET FORWARD WINDOW
- ⑦ FACING BRICKS LAID TO SOLDIER COURSE STACK BOND
- ⑧ REINFORCED CONCRETE SLAB
- ⑨ FIRE STOP
- ⑩ JOINTING TAPE TO SEAL JUNCTION BETWEEN R.C. FLOOR AND PLASTERBOARD
- ⑪ METSEC FRAME CONSTRUCTION WITH 2 LAYERS OF 15MM SOUNDBLOCK PLASTERBOARDS FINISHED WITH 2mm SKIMCOAT ON INTERNAL FACE. 13mm CEMENT BOARD FIXED ON THE CAVITY SIDE TO RECEIVE 100mm KINGSPAN INSULATION BOARD AND BREATHING MEMBRANE ON CAVITY SIDE

### NOTE:\*\*

SOME FRAMES MAY REQUIRE TRIPLE GLAZING TO SOUND ENG. SPEC.  
THIS DRAWING TO BE READ IN CONJUNCTION WITH DRW.12387\_40\_04

CAST IN ANGLE DETAIL TO S.E.

REV BY	DATE	CHK	DESCRIPTION
STATUS			
FOR CONSTRUCTION			
CONTRACTOR			
WILLMOTT DIXON			
PROJECT			
TWYMAN HOUSE			
CLIENT			
TAYLOR WIMPEY CENTRAL LONDON			
DRAWING TITLE			
TYPICAL WINDOW CILL DETAIL GLAZED SCREEN SET FORWARD			
DATE CREATED	DATE AMENDED	SCALE	
22.02.13	22.02.13	1:5@A3	
DRAWN BY	AMENDED BY	CHECKED	
NA	MBRZEZINSKA	MB	
DRAWING NO & REVISION			
12387_40_03-D1			

The Quadrangle,  
180 Wardour Street,  
London W1F 8FY  
T +44 (0)20 7287 1153  
F +44 (0)20 7287 3675  
www.sprunt.net

sprunt