

Mr Mark Scott  
Willingale Associates  
56 Clerkenwell Road  
London  
Middlesex  
EC1M 5PX

Application Ref: **2012/6048/P**  
Please ask for: **John Nicholls**  
Telephone: 020 7974 **2843**

9 January 2013

Dear Sir/Madam

## **DECISION**

Town and Country Planning Act 1990 (as amended)  
Town and Country Planning (Development Management Procedure) Order 2010  
Town and Country Planning (Applications) Regulations 1988

### **Full Planning Permission Granted**

Address:  
**45 Heath Street**  
**London**  
**NW3 6UA**

Proposal:  
Installation of rooflight in rear roofslope and the enlargement of two windows on the rear elevation of Flat 1 facing an internal lightwell in connection with residential dwellings Class C3.

Drawing Nos: Site location plan, (NW3\_45HS\_) EX01A, EX02A, EX03A, EX04A, PP01A, PP02A, PP03A, PP04A

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.



Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy CS14 of the London Borough of Camden Local Development Framework Core Strategy and policy DP24 and DP25 of the London Borough of Camden Local Development Framework Development Policies.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans: Site location plan, (NW3\_45HS\_) EX01A, EX02A, EX03A, EX04A, PP01A, PP02A, PP03A, PP04A

Reason: For the avoidance of doubt and in the interest of proper planning.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 6941).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website <http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 3 Reasons for granting permission.

The proposed development is in general accordance with the London Borough of Camden Local Development Framework Core Strategy, with particular regard to policies CS5 and CS14 and the London Borough of Camden Local Development Framework Development Policies, with particular regard to policies DP24, DP25 and DP26. For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officer report.

In dealing with the application, the Council has sought to work with the applicant in a positive and proactive way in accordance with paragraphs 186 and 187 of the National Planning Policy Framework.

**Disclaimer**

***This is an internet copy for information purposes. If you require a copy of the signed original please telephone Contact Camden on (020) 7974 4444***