



...sustainable building services solutions

# craven house

plant noise assessment report

...sustainable building services solutions

# PLANT NOISE ASSESSMENT REPORT

[illegible]



SCHRODERS

CRAVEN HOUSE

...sustainable building services solutions

## PLANT NOISE ASSESSMENT REPORT

### CONTENTS

**1.0 INTRODUCTION**

**2.0 DESIGN NOISE CRITERIA**

**3.0 PLANT NOISE ASSESSMENT**

**4.0 CONCLUSION**

**APPENDIX A - CALCULATION SHEETS**



## 1.0 INTRODUCTION

MTT has been commissioned to undertake a noise assessment of the new extract fans and air handling units proposed to be installed at Craven House, 121 Kingsway, London WC2. The plant is to be installed externally at 1<sup>st</sup> and 6<sup>th</sup> floor roof levels; all as shown on the Architects drawings. Additionally it should be noted that the fans will be fitted with in-line duct attenuators to reduce noise transmission to atmosphere.

The purpose of the assessment is to ascertain whether the proposed new plant will achieve the design noise criteria detailed in the MTT Environmental Noise Survey Report dated 29<sup>th</sup> September 2011 (summarised as follows), and thereby satisfy the planning requirements of the local planning authority (London Borough of Camden)



## 2.0 DESIGN NOISE CRITERIA

The London Borough of Camden current noise emission criteria in relation to this site states that;

"Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment are in operation. Where it is anticipated that any plant/equipment will have noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum), and/or if there are distinct impulses (bangs, clicks, clatters, thumps) special attention should be given to reducing the noise levels from that piece of plant/equipment at any sensitive facade to at least 10dB(A) below the LA90, expressed in dB(A)"

To conform to the above criteria and in accordance with the **MTT** environmental noise survey report dated 29<sup>th</sup> September 2011, noise from the proposed plant installations should not exceed the following values.

|                                             |                         |
|---------------------------------------------|-------------------------|
| Daytime plant operation (07:00 to 23:00hrs) | - 49.9 L <sub>Aeq</sub> |
| 24hour plant operation                      | - 47.1 L <sub>Aeq</sub> |

Note: These levels must be achieved cumulatively with all plant operating, and as measured at 1 metre external to the nearest noise sensitive facades.

**3.0 PLANT NOISE ASSESSMENT****MECHANICAL PLANT DETAILS AND NOISE DATA****Plant located at 1st floor roof level**

|                           | <b>63</b> | <b>125</b> | <b>250</b> | <b>500</b> | <b>1K</b> | <b>2K</b> | <b>4K</b> | <b>8K</b> |
|---------------------------|-----------|------------|------------|------------|-----------|-----------|-----------|-----------|
| <b>1.0 EF02</b>           |           |            |            |            |           |           |           |           |
| Fan outlet SWL            | 80        | 75         | 62         | 58         | 62        | 57        | 54        | 49        |
| Attenuator insertion loss | 1         | 1          | 2          | 4          | 7         | 9         | 7         | 5         |
| <b>2.0 SF-B/04</b>        |           |            |            |            |           |           |           |           |
| Fan inlet SWL             | 64        | 62         | 60         | 58         | 57        | 55        | 52        | 48        |
| Attenuator insertion loss | 5         | 7          | 10         | 18         | 26        | 28        | 23        | 20        |

**Plant located at 6<sup>th</sup> floor roof level**

|                           | <b>63</b> | <b>125</b> | <b>250</b> | <b>500</b> | <b>1K</b> | <b>2K</b> | <b>4K</b> | <b>8K</b> |
|---------------------------|-----------|------------|------------|------------|-----------|-----------|-----------|-----------|
| <b>3.0 EF01</b>           |           |            |            |            |           |           |           |           |
| Fan outlet SWL            | 85        | 80         | 79         | 80         | 75        | 68        | 68        | 63        |
| Attenuator insertion loss | 1         | 2          | 3          | 6          | 8         | 8         | 6         | 4         |
| <b>4.0 SF-05/02</b>       |           |            |            |            |           |           |           |           |
| Fan inlet SWL             | 62        | 67         | 67         | 61         | 54        | 51        | 46        | 53        |
| Attenuator insertion loss | 4         | 6          | 12         | 25         | 32        | 32        | 26        | 20        |
| <b>5.0 SF-06/03</b>       |           |            |            |            |           |           |           |           |
| Fan inlet SWL             | 64        | 62         | 60         | 58         | 57        | 55        | 52        | 48        |
| Attenuator insertion loss | 5         | 7          | 10         | 18         | 26        | 28        | 23        | 20        |

**Nearest noise sensitive properties**

The nearest noise sensitive properties are considered to be the residential flats in Newton Street, the facade of which is approximately 40 metres away from fan item EF-01, and 50 metres away from the remaining fans. Additionally it should be noted that there is no line of sight between the fans at 1<sup>st</sup> floor roof level and the flats, due to the shielding provided by the edge of the development building.

**CALCULATIONS**

Detailed calculations for all plant items are contained within the appendix attached to this report, with the resultant noise levels at the nearest flats summarised as follows:

| PLANT<br>REFERENCE        | DISTANCE TO<br>NEAREST WINDOW | RESULTANT<br>NOISE LEVEL |
|---------------------------|-------------------------------|--------------------------|
| EF-02                     | 50m                           | 7dBA                     |
| SF-B/04                   | 50m                           | 0dBA                     |
| EF-01                     | 40m                           | 32dBA                    |
| SF-05/02                  | 50m                           | 3dBA                     |
| SF-06/03                  | 50m                           | 0dBA                     |
| <b>TOTAL</b>              |                               | <b>32dBA</b>             |
| Facade correction         |                               | +3dB                     |
| TOTAL                     |                               | <b>35dBA</b>             |
| <b>Daytime Criteria</b>   |                               | <b>49.9dBA</b>           |
| Margin of safety          |                               | <b>14.9dBA</b>           |
| <b>Nighttime criteria</b> |                               | <b>47.1dBA</b>           |
| Margin of safety          |                               | <b>12.1dBA</b>           |



#### 4.0 CONCLUSION

A plant noise assessment of the proposed new equipment to be installed at Craven House, 121 Kingsway, has been carried out.

It has been established that based upon the proposed plant selections and locations, and with fan noise control measures incorporated, the design noise criterion will be achieved, and therefore the requirements of the local planning authority (London Borough of Camden) will be achieved.



SCHRODERS

CRAVEN HOUSE

...sustainable building services solutions

## PLANT NOISE ASSESSMENT REPORT

### APPENDIX A - CALCULATION SHEETS



|                         | ATMOSPHERE              |     |     |     | SIDE | ANALYSIS |    |    |               |           |            |
|-------------------------|-------------------------|-----|-----|-----|------|----------|----|----|---------------|-----------|------------|
|                         | OCTAVE BAND CENTRE FREQ |     |     |     |      |          |    |    |               |           |            |
|                         | 63                      | 125 | 250 | 500 | 1K   | 2K       | 4K | 8K |               |           |            |
| SWL                     | 80                      | 75  | 62  | 58  | 62   | 57       | 54 | 49 |               |           |            |
| BENDS                   | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | BEND W/QTY |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | BEND W/QTY |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | BEND W/QTY |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | BEND W/QTY |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | BEND W/QTY |
| RECTANGULAR DUCTS       | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | DUCT W/L   |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | DUCT W/L   |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | DUCT W/L   |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | DUCT W/L   |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | DUCT W/L   |
| CIRCULAR DUCTS          | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | DUCT W/L   |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | DUCT W/L   |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | DUCT W/L   |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | DUCT W/L   |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | 0             | 0         | DUCT W/L   |
| EQUIPMENT LOSSES        | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  |               |           |            |
| BUILDING EDGE           | 10                      | 10  | 10  | 10  | 10   | 10       | 10 | 10 |               |           |            |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  | M2            |           |            |
| GRILLE END REFLECTION   | 14                      | 9   | 5   | 2   | 0    | 0        | 0  | 0  | 0.00          | CENTRE    |            |
| SYSTEM ATTENUATION      | 24                      | 19  | 15  | 12  | 10   | 10       | 10 | 10 | 0.05          | OMNI      |            |
| SWL AT GRILLE           | 56                      | 56  | 47  | 46  | 52   | 47       | 44 | 39 | 0.00          | JUNC 2    |            |
| DIRECTIVITY             | 0                       | 0   | 1   | 3   | 4    | 5        | 5  | 6  | 0.00          | JUNC 3    |            |
| DISTANCE TO LISTENER    | 45                      | 45  | 45  | 45  | 45   | 45       | 45 | 45 | 50.00         | METERS    |            |
| SPL AT LISTENER         | 11                      | 11  | 3   | 4   | 11   | 7        | 4  | 0  | 0             | ANGLE     |            |
| NOISE CRITERION         | 59                      | 48  | 40  | 34  | 30   | 27       | 25 | 23 | NR 30         | CRITERION |            |
| ALLOWANCE               | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  |               |           |            |
| REQUIRED INSERTION LOSS | 0                       | 0   | 0   | 0   | 0    | 0        | 0  | 0  |               |           |            |
| ATTENUATOR DIL          | 1                       | 1   | 2   | 4   | 7    | 9        | 7  | 5  | CA25S MELINEX |           |            |
| ATTENUATED SPL          | 10                      | 10  | 1   | 0   | 4    | -2       | -3 | -5 |               |           |            |
| ATTENUATED NOISE LEVEL  | 4 NR                    |     |     |     |      |          |    |    |               |           |            |
| ATTENUATED NOISE LEVEL  | 7 Dba                   |     |     |     |      |          |    |    |               |           |            |

|                         | ATMOSPHERE              |     |     |     | SIDE | ANALYSIS |     |    |       |   |            |  |
|-------------------------|-------------------------|-----|-----|-----|------|----------|-----|----|-------|---|------------|--|
|                         | OCTAVE BAND CENTRE FREQ |     |     |     |      |          |     |    |       |   |            |  |
|                         | 63                      | 125 | 250 | 500 | 1K   | 2K       | 4K  | 8K |       |   |            |  |
| SWL                     | 62                      | 67  | 67  | 61  | 54   | 51       | 46  | 53 |       |   |            |  |
| BENDS                   | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | BEND W/QTY |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | BEND W/QTY |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | BEND W/QTY |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | BEND W/QTY |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | BEND W/QTY |  |
| RECTANGULAR DUCTS       | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | DUCT W/L   |  |
| CIRCULAR DUCTS          | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 | DUCT W/L   |  |
| EQUIPMENT LOSSES        | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 |            |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | 0     | 0 |            |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  | M2    |   |            |  |
| GRILLE END REFLECTION   | 9                       | 5   | 2   | 0   | 0    | 0        | 0   | 0  | 0.00  |   | CENTRE     |  |
| SYSTEM ATTENUATION      | 9                       | 5   | 2   | 0   | 0    | 0        | 0   | 0  | 0.20  |   | OMNI       |  |
| SWL AT GRILLE           | 53                      | 62  | 65  | 61  | 54   | 51       | 46  | 53 | 0.00  |   | JUNC 2     |  |
| DIRECTIVITY             | 1                       | 1   | 2   | 3   | 4    | 6        | 6   | 6  | 0.00  |   | JUNC 3     |  |
| DISTANCE TO LISTENER    | 45                      | 45  | 45  | 45  | 45   | 45       | 45  | 45 | 50.00 |   | METERS     |  |
| SPL AT LISTENER         | 9                       | 18  | 22  | 19  | 13   | 12       | 7   | 14 | 0     |   | ANGLE      |  |
| NOISE CRITERION         | 59                      | 48  | 40  | 34  | 30   | 27       | 25  | 23 | NR 30 |   | CRITERION  |  |
| ALLOWANCE               | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  |       |   |            |  |
| REQUIRED INSERTION LOSS | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0  |       |   |            |  |
| ATTENUATOR DIL          | 4                       | 6   | 12  | 25  | 32   | 32       | 26  | 20 | SIL   |   |            |  |
| ATTENUATED SPL          | 5                       | 12  | 10  | -6  | -19  | -20      | -19 | -6 |       |   |            |  |
|                         |                         |     |     |     |      |          |     |    |       |   |            |  |
| ATTENUATED NOISE LEVEL  | 2 NR                    |     |     |     |      |          |     |    |       |   |            |  |
| ATTENUATED NOISE LEVEL  | 3 Dba                   |     |     |     |      |          |     |    |       |   |            |  |

**PROJECT: CRAVEN HOUSE, 121 KINGSWAY**

NOISE UNTREATED: 18 NR  
21 dB'A'

## OCTAVE BAND CENTRE FREQ

[illegible]

|                         | ATMOSPHERE              |     |     |     | SIDE | ANALYSIS |     |     |       |           |            |  |
|-------------------------|-------------------------|-----|-----|-----|------|----------|-----|-----|-------|-----------|------------|--|
|                         | OCTAVE BAND CENTRE FREQ |     |     |     |      |          |     |     |       |           |            |  |
|                         | 63                      | 125 | 250 | 500 | 1K   | 2K       | 4K  | 8K  |       |           |            |  |
| SWL                     | 64                      | 62  | 60  | 58  | 57   | 55       | 52  | 48  |       |           |            |  |
| BENDS                   | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | BEND W/QTY |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | BEND W/QTY |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | BEND W/QTY |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | BEND W/QTY |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | BEND W/QTY |  |
| RECTANGULAR DUCTS       | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | DUCT W/L   |  |
| CIRCULAR DUCTS          | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | DUCT W/L   |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | 0     | 0         | DUCT W/L   |  |
| EQUIPMENT LOSSES        | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   |       |           |            |  |
| BUILDING EDGE           | 10                      | 10  | 10  | 10  | 10   | 10       | 10  | 10  |       |           |            |  |
|                         | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   | M2    |           |            |  |
| GRILLE END REFLECTION   | 14                      | 9   | 5   | 2   | 0    | 0        | 0   | 0   | 0.00  | CENTRE    |            |  |
| SYSTEM ATTENUATION      | 24                      | 19  | 15  | 12  | 10   | 10       | 10  | 10  | 0.05  | OMNI      |            |  |
| SWL AT GRILLE           | 40                      | 43  | 45  | 46  | 47   | 45       | 42  | 38  | 0.00  | JUNC 2    |            |  |
| DIRECTIVITY             | 0                       | 0   | 1   | 3   | 4    | 5        | 5   | 6   | 0.00  | JUNC 3    |            |  |
| DISTANCE TO LISTENER    | 45                      | 45  | 45  | 45  | 45   | 45       | 45  | 45  | 50.00 | METERS    |            |  |
| SPL AT LISTENER         | -5                      | -2  | 1   | 4   | 6    | 5        | 2   | -1  | 0     | ANGLE     |            |  |
| NOISE CRITERION         | 59                      | 48  | 40  | 34  | 30   | 27       | 25  | 23  | NR 30 | CRITERION |            |  |
| ALLOWANCE               | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   |       |           |            |  |
| REQUIRED INSERTION LOSS | 0                       | 0   | 0   | 0   | 0    | 0        | 0   | 0   |       |           |            |  |
| ATTENUATOR DIL          | 5                       | 7   | 10  | 18  | 26   | 28       | 23  | 20  | SIL   |           |            |  |
| ATTENUATED SPL          | -10                     | -9  | -9  | -14 | -20  | -23      | -21 | -21 |       |           |            |  |
| ATTENUATED NOISE LEVEL  | -13                     | NR  |     |     |      |          |     |     |       |           |            |  |
| ATTENUATED NOISE LEVEL  | -11                     | Dba |     |     |      |          |     |     |       |           |            |  |