Ref: PJB6614/11167

Date: 2 November 2012



Nick Foyle Willmott Dixon Housing Ltd Hitchin Road Shefford Beds SG17 5JS



Dear Nick

#### **CHESTER BALMORE - NOISE RELATED PLANNING CONDITION NUMBER 13**

As you know, Spectrum have investigated the environmental noise levels affecting the above development and analysed the requirements for discharging the Council's planning condition number 13 in relation to plant noise. This was reported in our technical letter PJB6506/11167 dated 14 August, 2012.

Following this, the Environmental Protection Department of Camden Council contacted me to say that, although they accepted the conclusions of the report, they did not accept planning submissions for plant noise that included analysis based on numerical noise models. Instead, they wished to see a 'manual' calculation of plant noise emission.

Following your instruction for us to carry out this work, we have undertaken this exercise, as detailed below.

#### 1. PLANT DETAILS AND LAYOUT

The mechanical consultant for this project has provided noise data for the proposed equipment which was shown in Attachment 8 of our original submission and is duplicated here. This includes both overall and octave band noise levels. The plant layout is also shown in Attachment 8. All of the plant areas are at basement level in the Raydon building and have no direct air path to external areas (such as via a wall or door louvres). All ventilation for the equipment in the plant rooms is, therefore, provided by fan units ducted directly into and out of the plant rooms. Attachment 8 shows that the inlet and outlet louvres to these ducts are at high level in the ground floor façade of the building facing Raydon Street.

The nearest residences to these louvre locations are at first floor above the duct louvres, as shown in the Raydon Street façade drawing (Attachment 9 of our original submission, also attached). These are significantly acoustically screened from the louvres by elements of the building itself (such as balconies).

#### 1.1 Calculation Method

Calculations of duct-borne noise transmission have been carried out using the methods and data described in Section 7 of "Noise Control in Building Services" by Sound Research Laboratories (Pergamon, 1988). Calculations of environmental noise emission from the louvres has taken into account:

- Sound power level emanating from each louvre
- Spherical spreading (distance attenuation)
- Directivity effects

- Diffraction effects (barrier screening)
- Reflection effects
- Sound power to sound pressure conversion

The results of this analysis are shown in Attachment 3. These agree to a good extent with the original numerical noise model calculations, despite being undertaken using a different method.

This shows that the most affected location is predicted to have an Laeq of 28 dB, which is in compliance with Condition 13's requirements. It should be remembered that the assessment procedure described above compares the noise level from all equipment operating at maximum possible duty with the minimum background noise level, as situation which would rarely occur. At other times, the difference between the noise rating level and the background noise level would be lower, leading to a lower risk of noise disturbance.

Accordingly, environmental noise from the proposed mechanical services at this development is acoustically acceptable.

#### 2. CONCLUSION

The revised information provided above and within the attachments confirm that the acoustic requirements set out in Conditions13 of permission 2010/5478/P will be met. It is recommended that this report be forwarded to Camden Council toward discharging these conditions.

If you have any questions or require further information, please don't hesitate to contact me.

Yours sincerely


Phill Banks

**Principal Consultant** 


PJB6614/11167 Page 2 of 2

#### PERFORMANCE - ECOSMART SQURBO EXTRACT

## Ecosmart Squrbo Extract Unit



#### Casing



Code descriptions

ESSE Extract units

ESSE 2-WP



- 1. ESSE = Ecosmart Squrbo extract fan
- 2. Case Size/Curve Reference
- 3. WP = Weatherproof enclosure

EF-R-OI

#### **ECOSMART SQURBO EXTRACT UNITS**

**ELECTRICAL & SOUND** 

				Motor Power	FLC	SC	Data		Power leve Band mid		10000				Breakout
Curve	Code	Phase	RPM	(kW)	(amps)	(amps)	Туре	125	250	500	1K	2K	4K	8K	dBA@3n
1	ESSE 1	1	2724	0.043	0.32	0.32	1	63	59	63	50	45	37	27	30
	2034						0	68	62	65	51	48	44	34	30
2	ESSE2	1	2285	0.075	0.34	0.34	1	64	64	66	57	52	57	37	34
_							0	71	66	68	61	56	65	44	34
3	ESSE3	1	2544	0.15	0.72	0.72	1	70	75	75	66	63	57	49	42
	23323						0	76	75	76	70	69	66	55	42
4	ESSE4	1	2313	0.17	0.92	0.92	1	70	75	75	66	64	61	58	43
•							0	76	75	79	69	69	63	65	43
ς.	ESSES	1	2313	0.17	0.92	0.92	1	74	70	73	68	66	64	60	43
	23523						0	78	69	77	73	72	70	66	43
6	ESSE6	1	1110	0.66	2.95	2.95	1	71	67	59	60	56	51	46	45
	2320		0				1	76	74	73	73	71	67	62	45

The electrical and sound information in the table is nominal Breakout dBA@3m is spherical, free field SC = FLC due to soft starting control.

029 2085 8200


Unit has facility to operate motorised damper fan frost protection. I = Induct inlet. O = Induct outlet.

Please note: With Ecosmart, Ecosmart BMS & Ecosmart Commissioning options the units are pre-programmed with a soft start facility.

# SUPPLY & EXTRACT ECOSMART - SQURBO EXTRACT TECHNICAL INFORMATION



#### **DIMENSIONS - ECOSMART SQURBO EXTRACT**



#### **DIMENSIONS (mm) & WEIGHTS** Fixing ctrs Weight ABCDEFGHJ (Kg) ESSE1 160 230 640 125 150 150 330 140 115 7.4 ESSE2 185 302 630 150 150 150 330 140 150 8.1 235 350 700 200 150 150 330 140 170 ESSE3 13 285 350 672 250 150 150 330 140 170 ESSE4 13.8 ESSE5 350 400 726 315 150 150 330 140 200 15.2


430 682 700 400 175 150 330 140 200

Extract - No heater

# E B

# WIRING - ECOSMART SQURBO EXTRACT

# ESSE1-5 Extract



<sup>\*</sup> Motor electrical supply, 1=1 phase (230V, 50Hz) 3=3phase (400V, 50Hz).

## Fläkt Woods Limited

# Combination Data Sheet

JM Aerofoil



Project Name : Chester Balmore

Quotation Number : JH442-Chester Balmore

Customer : Couch Perry Wllkes Birmingham

Fan Code 31JM/16/2/5/10 Fan Diameter / Size 315 mm Blades 2840 rpm Fan Speed Velocity 3.4 m/s Blade Angle 10° Form of Running Fan Casing Long

0.25m³/s @ 150 Pa (static) 0.27m³/s @ 245 Pa (static) Requested Duty Actual Duty

Outlet Dynamic Pressure

Idling Loss\* 66 Pa **DutyShaft Power** 0.142 kW Max Shaft Power 0.181 kW Total Efficiency 47 %

Motor Frame BT9 Motor Efficiency IE1 0.580 kW Motor Rating Full Load Current 1.45 A Starting Current 5.7A MotorMounting Electrical Supply 380-420 Volts 50 Hz 3 Phase

Start Type DOL Motor Winding Standard Standard All Enclosure

Fan Efficiency
Fan +Motor Efficiency 47.2% 26.7% 0.94 W/(I/s) SFP value

**Energy Consumption** 502 kWh (2000 h/year)

Running Cost / Year £45

1.2 kg/m³ / 20 °C / 0 m / 50% RH Non Smoke Venting Air Density Smoke Venting Product Number DX341202

Date: Fan Code


**TEXT** MACE


FANUS

EF-R-CR

: Friday, February 3, 2012 : 31JM/16/2/5/10

Item Reference:





	50u	na Sp	pectru	IM (H	Z)					Overall
	63	125	250	500	1k	2k	4k	8k	Lw*	LpA @ 3 m**
Inlet*	71	75	80	79	83	76	71	63	87	65
Outlet*	73	75	82	79	83	76	71	65	87	65
Breakout*	63		62	59	59	47	45	41	68	41
* Lw dB re 10	) -12 W							**	dBA re	2x10 <sup>-5</sup> Pa

Selection includes run / standby in series losses. Sound levels could be up to 5 dB higher than those stated, dependant on fan spacing. Terms and Conditions: This offer is made subject to the terms and conditions detailed on the accompanying letter.

Description Qty Unit Price Price 31JM/16/2/5/10 2 £ 568 £1136 Fan Accessories (Quantities per Fan) Set of Mounting Feet (2) (AS021102) £ 12 £ 24 Rubber in ShearAnti Vibration Mounts (set of 4) (AS032422) £ 15 £30 Matching Flange (DA408238) 2 £ 20 £ 80 Flex connector c/w2 clips (less Flanges) (AS040315) 2 £ 27 £ 108 Thermostat included included Estimated Despatch: 1 Days TOTAL PRICEFAN AND ACCESSORIES (leadtimes subject to parts availability) £1378

Axial Way		Website: www.flaktwoods.com
Colchester, Essex, CO45ZD		Email: jo.hook@flaktwoods.com
Tel: +44 (0) 1206 222555 Fax: +44 (0) 120	06 222777	Copyright Fläkt Woods Group 2003 - 2012
Printed on 03 February 2012	Page 4 of 5	Selection Engine: 2.7.4.8a(1)(LIK 3.5.0)

## Fläkt Woods Limited

# Combination Data Sheet

JM Aerofoil



Project Name : Chester Balmore

Quotation Number : JH442-Chester Balmore

Customer : Couch Perry Wllkes Birmingham

Fan Code Fan Diameter / Size Blades Fan Speed Velocity

315 mm SUPPU 2840 rpm FAINS 4.8 m/s Blade Angle 14° Form of Running R SF-201 Fan Casing Long

0.35m³/s @ 150 Pa (static) 0.37m³/s @ 260 Pa (static) Requested Duty Actual Duty Outlet Dynamic Pressure 14 Pa

79 Pa Idling Loss\*

**DutyShaft Power** 0.196 kW Max Shaft Power 0.229 kW Total Efficiency 52 %

Motor Frame BT9 Motor Efficiency IE1 Motor Rating 0.580 kW Full Load Current 1.45 A Starting Current 5.7A MotorMounting Pad

380-420 Volts 50 Hz 3 Phase **Electrical Supply** 

Start Type Motor Winding Standard Enclosure Standard All

Fan Efficiency 52.2% Fan +Motor Efficiency 31.7% SFP value 0.86 W/(I/s)


645 kWh (2000 h/year) **Energy Consumption** 


Running Cost / Year

1.2 kg/m3/20 °C/0 m / 50% RH Air Density Smoke Venting Non Smoke Venting

Product Number DX341202 Date: : Friday, February 3, 2012 Fan Code : 31JM/16/2/5/14

Item Reference:






	-	_	-	IIII (L						Overall
	63	125	250	500	1k	2k	4k	8k	Lw*	LpA @ 3 m**
Inlet*	70	74	79	78	79	74	69	63	85	62
Outlet*	72	75	82	78	80	74	70	63	86	62
Breakout*	62	61	62	58	56	45	44	39	67	40
* Lw dB re 10	<sup>-12</sup> W							**	dBA re	2x10 -5 Pa


Selection includes run / standby in series losses. Sound levels could be up to 5 dB higher than those stated, dependant on fan spacing. Terms and Conditions: This offer is made subject to the terms and conditions detailed on the accompanying letter.

2 Nº

Description	Qty	Unit Price	Price
Fan			
31JM/16/2/5/14	2	£ 568	£1136
Fan Accessories (Quantities per Fan)			
Set of Mounting Feet (2) (AS021102)	1	£ 12	£ 24
Rubber in ShearAnti Vibration Mounts (set of 4) (AS032422)	1	£ 15	£ 30
Matching Flange (DA408238)	2	£ 20	£ 80
Flex connector c/w2 clips (less Flanges) (AS040315)	2	£ 27	£ 108
Thermostat	1	included	included
Estimated Despatch :1 Days			
TOTAL PRICEFAN AND ACCESSORIES (leadtimes subject to parts ava	ilability)		£1378

Axial Way Website: www.flaktwoods.com Colchester, Essex, CO45ZD Email: jo.hook@flaktwoods.com Tel: +44 (0) 1206 222555 Fax: +44 (0) 1206 222777 Copyright Fläkt Woods Group 2003 - 2012 Printed on 03 February 2012 Page 2 of 5 Selection Engine: 2.7.4.8a(1)(UK.3.5.0)





- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE PARTICULAR PROJECT SPECIFICATION AND ALL RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS.
- THIS DRAWING IS FOR DESIGN PURPOSES ONLY. THE BUILDING SERVICES SUB-CONTRACTOR IS RESPONSIBLE FOR THE PREPARATION OF ALL INSTALLATION DRAWINGS AND BUILDER'S WORK DETAILS AS DESCRIBED WITHIN THE CPW SPECIFICATION.
- ALL VOLUME CONTROL DAMPERS TO BE OPPOSED BLADE (UNLESS STATED OTHERWISE)
- 4. ALL DUCTWORK SHALL BE IN ACCORDANCE WITH DW 144/DW154
- 5. ALL DUCTWORK BENDS TO HAVE TURNING VANES.
- NR RATINGS REFER TO ONE METRE FROM TERMINATION POINT WITH ALL EQUIPMENT OPERATING AT FULL CAPACITY.
- REFER TO SPECIFICATION FOR DETAILS OF FANS, GRILLES, ATTENUATORS AND DIFFUSERS.
- ALL EXTERNAL LOUVRES / TERMINATIONS TO BE RAL COLOUR AND FINISH IN ACCORDANCE WITH ARCHITECTS DECLINOSULENTS
- REQUIREMENTS.
- 9 THE MAIN CONTRACTOR SHALL POVIDE ACCESS PANELS WITHIN THE CEILING CONSTRUCTION TO ALLOW ACCESS (FOR COMMISSIONING AND MAINTENANCE PURPOSES) TO VCD'S, SD'S, FD'S & AD'S.
- VCD's, SD's, FD's & AD's.

  10 THE CO-ORDINATION SHOWS DESIGN INTENT FOR CRITICAL AREAS THEY ARE NOT CONSTRUCTION DRAWINGS, AND THEREFORE DO NOT SHOW ALL BENDS, TEE SETS ETC., THAT TMAY BE NECESSARY TO LOCATE SERVICES CORRECTLY TO AVOID CLASHES AND MAXIMIZE MAINTENANCE ACCESS. THE BUILDING SERVICES CONTRACTOR IS NEVERTHELESS DEEMED TO HAVE INCLUDED ALL SUCH MATERIALS ETC. AS REQUIRED TO PRODUCE A COMPLETE, FULLY CO-ORDINATED LAYOUT FOR THE MECHANICAL AND ELECTRICAL SERVICES. SHOULD ASPECT RATIO CHANGES OF DUCTWORK BE NEEDED TO ACHIEVE A FULLY CO-ORDINATED LAYOUT OR TO FIT WITHIN THE BUILDING STRUCTURE AND AVAILABLE CEILING VOID, THESE SHALL BE DEEMED TO HAVE BEEN INCLUDED WITHIN THE BUILDING STRUCTURE AND AVAILABLE CEILING WITHIN THE BUILDING SERVICES CONTRACTOR'S TENDER
- 11. ALL GRILLES TO BE CO-ORDINATED WITH THE CEILING AND LIGHTING AND OTHER SERVICES LAYOUTS.
- 12. THE BUILDING SERVICES CONTRACTOR SHALL INCLUDE FOR ALL SECONDARY STEELWORK NECESSARY FOR DUCTWORK SUPPORS ETC.
- 13. ALL DUCTWORK THAT PASSES THROUGH A FIRE BARRIER/ COMPARTMENT SHALL BE COMPLETE WITH INTUMESCENT FIRE COLLAR. THE CONTRACTOR SHALL REFER TO THE FIRE PLANS FROM THE ARCHITECT, IN CONJUNCTION WITH CPW DRAWINGS.
- 14 MAX & P FOR LOUVRE = 15 Pg AT DESIGN/NOISE CRITERIA.
- 15. ALL WORKS TO CONFORM TO ISO14001

P3 FEB 12 QA/COMMENTS AND ARCHITECTURAL UPDATES INCORPORATED

P2 09/12/11 UPDATED TO REFLECT LATEST ARCHITCTURAL LAYOUT

COUCH PERRY & WILKES

FOR COMMENT

WILLMOTT DIXON HOUSING

RAYDON BLOCK (R1-R7) - GROUND FLOOR (01) VENTILATION SERVICES LAYOUT


1:50 @ A1

OCTOBER 2011

11128/M/Ra302 W/Ra302

Xref-Raydon(R1-R7) 01

P3



#### NOTES:

- THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE PARTICULAR PROJECT SPECIFICATION AND ALL RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS.
- 2 THIS DRAWING IS FOR DESIGN PURPOSES ONLY. THE BUILDING SERVICES SUB-CONTRACTOR IS RESPONSIBLE FOR THE PREPARATION OF ALL INSTALLATION DRAWINGS AND BUILDER'S WORK DETAILS AS DESCRIBED WITHIN THE CPW SPECIFICATION.
- ALL VOLUME CONTROL DAMPERS TO BE OPPOSED BLADE (UNLESS STATED OTHERWISE)
- 4. ALL DUCTWORK SHALL BE IN ACCORDANCE WITH DW 144/DW154
- 5. ALL DUCTWORK BENDS TO HAVE TURNING VANES.
- 6. NR RATINGS REFER TO ONE METRE FROM TERMINATION POINT WITH ALL EQUIPMENT OPERATING AT FULL CAPACITY.
- REFER TO SPECIFICATION FOR DETAILS OF FANS, GRILLES, ATTENUATORS AND DIFFUSERS.
- ALL EXTERNAL LOUVRES / TERMINATIONS TO BE RAL COLOUR AND FINISH IN ACCORDANCE WITH ARCHITECTS REQUIREMENTS.
- THE MAIN CONTRACTOR SHALL POWIDE ACCESS PANELS WITHIN THE CEILING CONSTRUCTION TO ALLOW ACCESS (FOR COMMISSIONING AND MAINTENANCE PURPOSES) TO VOD'S, SD'S, FD'S & AD'S.
- THE CO-ORDINATION SHOWS DESIGN INTENT FOR CRITICAL AREAS THEY ARE NOT CONSTRUCTION DRAWNOS, AND THEREFORE DO NOT SHOW ALL BENDS, TEE SETS ETC. THAT MAY BE NECESSARY TO LOCATE SERVICES CORRECTLY TO AVOID CLASHES AND MAXIMIZE MAINTENANCE ACCESS. THE BUILDING SERVICES CONTRACTOR IS NEVERTHELESS DEBMED TO HAVE INCLUDED ALL SUCH MATERIALS ETC. AS REQUIRED TO PRODUCE A COMPLETE, FULLY CO-ORDINATED LAYOUT FOR THE MECHANICAL AND ELECTRICAL SERVICES. SHOULD ASPECT RATIO CHANGES OF DUCTWORK BE NEEDED TO ACHIEVE A FULLY CO-ORDINATED LAYOUT OR TO FIT WITHIN THE BUILDING STRUCTURE AND AVAILABLE CEILING VOID, THESS SHALL BE DEEMED TO HAVE BEEN INCLUDED WITHIN THE BUILDING SERVICES CONTRACTOR'S TENDER
- ALL GRILLES TO BE CO-ORDINATED WITH THE CEILING AND LIGHTING AND OTHER SERVICES LAYOUTS.
- THE BUILDING SERVICES CONTRACTOR SHALL INCLUDE FOR ALL SECONDARY STEELWORK NECESSARY FOR DUCTWORK SUPPOTS ETC.
- 13. ALL DUCTWORK THAT PASSES THROUGH A FIRE BARRIER/ COMPARTMENT SHALL BE COMPLETE WITH INTUMESCENT FIRE COLLAR THE CONTRACTOR SHALL REFER TO THE FIRE PLANS FROM THE ARCHITECT, IN CONJUNCTION WITH CPW DRAWNES.
- 14 MAX & P FOR LOUVRE = 15 Pg AT DESIGN/NOISE CRITERIA.
- 15. ALL WORKS TO CONFORM TO ISO14001.

P3 FEB 12 GA / COMMENTS AND ARCHITECHTURAL UPDATES INCORPORAT

P2 09/12/11 UPDATED TO REPLECT LATEST ARCHITECTURAL LAYOUT



FOR COMMENT

WILLMOTT DIXON HOUSING

CHESTER BALMORE

RAYDON BLOCK (R7-R9) - BASEMENT (00) VENTILATION SERVICES LAYOUT


1:50 0 A1

OCTOBER 2011

11128/M/Rb301

Xref-Raydon(R7-R9) 00

P3



- 1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE PARTICULAR PROJECT SPECIFICATION AND ALL RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS.
- 2. THIS DRAWING IS FOR DESIGN PURPOSES ONLY. THE BUILDING SERVICES SUB-CONTRACTOR IS RESPONSIBLE FOR THE PREPARATION OF ALL INSTALLATION DRAWINGS AND BUILDER'S WORK DETAILS AS DESCRIBED WITHIN THE CPW SPECIFICATION.
- 3 ALL VOLUME CONTROL DAMPERS TO BE OPPOSED BLADE
- ALL DUCTWORK SHALL BE IN ACCORDANCE WITH DW 144/DW154
- 5 ALL DUCTWORK BENDS TO HAVE TURNING VANES
- NR RATINGS REFER TO ONE METRE FROM TERMINATION POINT WITH ALL EQUIPMENT OPERATING AT FULL CAPACITY.
- REFER TO SPECIFICATION FOR DETAILS OF FANS, GRILLES, ATTENUATORS AND DIFFUSERS.
- B ALL EXTERNAL LOUVRES / TERMINATIONS TO BE RAL COLOUR AND FINISH IN ACCORDANCE WITH ARCHITECTS REQUIREMENTS
- 9, THE MAIN CONTRACTOR SHALL POVIDE ACCESS PANELS WITHIN THE CELLING CONSTRUCTION TO ALLOW ACCESS (FOR COMMISSIONING AND MAINTENANCE PURPOSES) TO VCD's, SD's, FD's & AD's
- VLD 5, SUS, FUS & AUS

  10. THE CO-ORDINATION SHOWS DESIGN INTENT FOR CRITICAL AREAS THEY ARE NOT CONSTRUCTION DRAWINGS, AND THEREFORE DO NOT SHOW ALL BENDS, TEE SETS ETC, THAT MAY BE NECESSARY TO LOCATE SERVICES CORRECTLY TO AVOID CLASHES AND MAXIMIZE MAINTENANCE ACCESS. THE BUILDING SERVICES CONTRACTOR IS NEVERTHELESS DEEMED TO HAVE INCLUDED ALL SUCH MATERIALS ETC. AS REQUIRED TO PRODUCE A COMPLETE, FULLY CO-ORDINATED LAYOUT FOR THE MECHANICAL AND ELECTRICAL SERVICES. SHOULD ASPECT RATIO CHANGES OF DUCTWORK BE NEEDED TO ACHEVE A FULLY CO-ORDINATED LAYOUT OR TO FIT MITHIN THE BUILDING STRUCTURE AND AVAILABLE CEILING VOID, THESE SHALL BE DEEMED TO HAVE BEEN INCLUDED WITHIN THE BUILDING STRUCTURE AND AVAILABLE CEILING VOID, THESE SHALL BE DEEMED TO HAVE BEEN INCLUDED WITHIN THE BUILDING SERVICES CONTRACTOR'S TENDER. WITHIN THE BUILDING SERVICES CONTRACTOR'S TENDER.
- 12. THE BUILDING SERVICES CONTRACTOR SHALL INCLUDE FOR ALL SECONDARY STEELWORK NECESSARY FOR DUCTWORK SUPPOTS ETC.
- 13. ALL DUCTWORK THAT PASSES THROUGH A FIRE BARRIER/ COMPARTMENT SHALL BE COMPLETE WITH INTUMESCENT FIRE COLLAR THE CONTRACTOR SHALL REFER TO THE FIRE PLANS FROM THE ARCHITECT, IN CONJUNCTION WITH CPW DRAWNOS.
- 14. MAX & P FOR LOUVRE = 15 Pa AT DESIGN/NOISE
- 15 ALL WORKS TO CONFORM TO ISO14001


PA MAY "12 VALUE ENGINEERING AND GENERAL LIPOLITES INCOMPORATES P3 FEB 12 GA/COMMENTS AND ARCHITECTURAL SPOATES INCORPORATED


P2 09/12/11 UPDATED TO REFLECT LATEST ARCHITECTURAL LAYOUT

A THE REST OF THE PARTY OF THE

RAYDON BLOCK (R1-R7) - BASEMENT (00) VENTILATION SERVICES LAYOUT

11128/M/Ra301





## Attachment 3 - 2 pages Environmental Noise Propagation Model Total plant noise level outside residence

 $\textbf{Model Description:} \ \ \textbf{Chester Balmore - Plant room extract / inlet noise breakout}$ 

**Receptor Location:** First floor of Raydon Block - As indicated

#### **Plant Ducted To**

External Louvres	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	dB(A)
Cleaners Cupboard Extract Fan							
Type ESSE 2							
Sound Power Level as per manuf. data	71	66	68	61	56	65	
Right angle bend losses			4	16	16	14	
Termination loss	8	4	1				
Duct Loss	6	5	3	2	2	2	
Sound power at louvre	65	61	61	43	38	49	60
Basement Plantroom Input Fans							
Type 31JM/16/2/5/14							
Sound Power Level (per unit)	75	82	78	80	74	70	
Total Sound Power Level with manuf. spectrum	78	85	81	83	77	73	
Right angle bend losses	0	0	25	40	20	15	
Termination loss	8	4	1				
Silencer Insertion Loss	4	8	13	16	13	10	
Duct Loss	3	2	1	1	1	1	
Sound power at louvre	63	71	41	26	43	47	63
Basement Plantroom Extract Fans							
Type 31JM/16/2/5/10							
Sound Power Level (per unit)	75	82	79	83	76	71	
Total Sound Power Level with manuf. spectrum	78	85	82	86	79	74	
Right angle bend losses			3	15	15	12	
Termination loss	8	4	1				
Silencer Insertion Loss	9	29	32	44	46	38	
Duct Loss	6	5	3	2	2	2	
Sound power at louvre	55	47	43	25	16	22	44

Noise propagation from louvres to residence - Receiver 1A as per original report

	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	dB(A)
Component 1 - Source A							
Cleaners Cupboard Extract Fan							
Sound power at louvre	65	61	61	43	38	49	
Directivity Loss	2	4	5	6	7	7	
Screening Loss	6	8	10	12	13	16	
Distance loss ( 13m)	23	23	23	23	23	23	
Sound Power to Sound Pressure Conversion	8	8	8	8	8	8	
Subtotal	26	18	15	-6	-13	-5	15
Component 2 - Source B							
Basement Plantroom Input Fans							
Sound power at louvre	63	71	41	26	43	47	
Directivity Loss	2	3	4	5	6	6	
Screening Loss	5	6	8	10	12	14	
Distance loss ( 10m)	20	20	20	20	20	20	
Sound Power to Sound Pressure Conversion	8	8	8	8	8	8	
Subtotal	28	34	1	-17	-3	-1	26
Component 3 - Source C							
Basement Plantroom Extract Fans							
Sound power at louvre	55	47	43	25	16	22	
Directivity Loss	2	3	4	5	6	6	
Screening Loss	2	4	6	7	8	8	
Distance loss ( 3m)	10	10	10	10	10	10	
Sound Power to Sound Pressure Conversion	5	5	5	5	5	5	
Subtotal	36	25	18	-2	-13	-7	22
Overall Lp at Residence	37.0	34.6	19.8	-0.4	-2.2	1.2	27
Noise Level criterion at Residence (LA90,5r	nin - 5 dB)						28
· · · · · · · · · · · · · · · · · · ·							
Excess over criterion							-1

# Attachment 3 - 2 pages Noise propagation from louvres to residence - Receiver 2A as per original report

	125Hz	250Hz	500Hz	1kHz	2kHz	4kHz	dB(A)
Component 1 - Source A							
Cleaners Cupboard Extract Fan							
Sound power at louvre	65	61	61	43	38	49	
Directivity Loss	2	3	4	5	6	6	
Screening Loss	6	8	10	13	16	18	
Distance loss (5m)	14	14	14	14	14	14	
Sound Power to Sound Pressure Conversion	8	8	8	8	8	8	
Subtotal	35	28	25	3	-6	3	25
Component 2 - Source B							
Basement Plantroom Input Fans							
Sound power at louvre	63	71	41	26	43	47	
Directivity Loss	2	4	5	6	7	7	
Screening Loss	6	8	10	13	16	18	
Distance loss ( 8m)	18	18	18	18	18	18	
Sound Power to Sound Pressure Conversion	8	8	8	8	8	8	
Subtotal	29	33	0	-19	-6	-4	25
Component 3 - Source C							
Basement Plantroom Extract Fans							
Sound power at louvre	55	47	43	25	16	22	
Directivity Loss	2	4	5	6	7	7	
Screening Loss	6	8	10	12	13	16	
Distance loss ( 13m)	23	23	23	23	23	23	
Sound Power to Sound Pressure Conversion	8	8	8	8	8	8	
Subtotal	16	4	-3	-24	-35	-32	2
Overall Lp at Residence	36.0	34.2	25.0	3.0	-3.0	3.8	28
Naise Level eritories et Besidons - / 1800 Fr	wim FdD\						20
Noise Level criterion at Residence (LA90,5r	nın - 5 ab)						28
Excess over criterion							0