



10 PANELS CONNECTED TO FLAT 4

REMAINING PANELS CONNECTED TO COMMUNAL SYSTEM

FLAT 4 => 10 PANELS @ 250W = 2.5 kWp
 COMMUNAL SYSTEM => 31 PANELS @ 250W = 7.75 kWp

Eyre Street Hill (Below)



PROPOSED ROOF PLAN



This layout is preliminary and for development use only and will require approval of local authorities with building control.
 All dimensions approximate based on preliminary survey and subject to measured site survey after strip out.
 All proposed structural and mechanical alterations by any of the building are subject to an-qualified engineer and BMS. clearance.



| no. | Date | Revised/By/Approved |
|-----|------|---------------------|
| | | |
| | | |

| | | | |
|----------|---------------------------------------|------------|---------|
| PROJECT | 3-11 EYRE STREET HILL LONDON EC1R 5ET | | |
| DESIGNER | MR SINGH | | |
| SCALE | 1:50 @ A1 | DATE | JUNE 09 |
| DRAWN BY | CB/JL | CHECKED BY | A |
| URG NO. | 253A(PA)105 | | |

DRAWING TITLE
PROPOSED ROOF PLAN

general practice architects & designers
 gpard ltd, 8 colton sq, london, ec1r 5et
 t: 020 7830 0253 f: 020 7830 8220
 e-mail: info@gpard.com
 web: www.gpard.com