

Our Ref: HT: 17143/JJS/tsl

21 March 2012

Brian Lamden
Brian Lamden Associates
35C North Row
London
W1K 6DH

By post and email at:
blam@brianlamden.com

Dear Brian

**RE: 12, 13 AND 14 BLOOMSBURY SQUARE
RELOCATION OF CONDENSERS**


We have been informed that the proposed location of the condensers of the above site has changed. We have reviewed and assessed the new location based on Samuely Construction Structural Engineers drawing 3786-01 dated January 2012.

We reference to our Environmental Noise Survey and Plant Noise Assessment Report 17143/PNA1 dated 15 April 2011, we have previously advised acoustic enclosures or the re-selection for the condensers to be installed on 12 and 14 Bloomsbury Square. We understand the choice of noise mitigation is acoustic enclosures.

The new scheme would require that all 3No. condensers are housed in acoustic enclosures to the same specification i.e. 47dBA measured at 1m in all directions.

We trust the enclosed is clear and of assistance. Should you have any queries please do not hesitate to contact us.

Yours sincerely
for HANN TUCKER ASSOCIATES



John Smethurst



Hann Tucker Associates

Consultants in Acoustics
Noise and Vibration Control

Duke House 1-2 Duke Street
Woking Surrey GU21 5BA

(T) +44 (0)1483 770595
(F) +44 (0)1483 729565
(E) enquiries@hantucker.co.uk
(W) www.hantucker.co.uk

Directors

Stuart G Morgan CEng MIMechE MCIBSE FIOA (Chairman)
Simon R Hancock BEng(Hons) CEng MCIBSE FIOA (Managing)
John L Gibbs MIOA(D) MSEE CEnv
John R Ridpath BSc(Hons) MIOA

Associates:

Teli Chinelis BSc(Hons) PgDip CEng MIOA MIMechE MCIBSE
Robin O Wood BEng(Hons) MIOA
Andrew D Ferner BSc(Hons) MIOA
Andrew G Jameson BSc(Hons) MIOA

