



NOTES:

- THIS DRAWING IS THE PROPERTY OF HITEK CONSULTANTS LIMITED AND IS PROTECTED UNDER THE COPYRIGHTS DESIGN AND PATENTS ACT 1988. ALL RIGHTS RESERVED. THIS DRAWING IS ISSUED ON CONDITION THAT IT IS NOT COPIED, REPRINTED OR REPRODUCED, WHOLLY OR IN PART, WITHOUT THE CONSENT OF HITEK CONSULTANTS LIMITED.
- DO NOT SCALE FROM THIS DRAWING. ALL DIMENSIONS AND SETTING OUT TO BE TAKEN FROM ARCHITECTURAL DRAWINGS.
- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE ARCHITECTS, STRUCTURAL ENGINEERS AND ALL OTHER SERVICES DRAWINGS AND SPECIFICATIONS.
- THE INFORMATION CONTAINED ON THIS DRAWING HAS BEEN PRODUCED FROM A NON DESTRUCTIVE VISUAL SURVEY AND RECORD DOCUMENTATION ONLY. IT IS THE CONTRACTORS RESPONSIBILITY TO VERIFY ALL INFORMATION PRIOR TO ANY SERVICES BEING ISOLATED AND STRIPPED OUT.
- LIGHTING TO BE WIRED USING TRUNKING AND UPVC CONDUITS, AND ROUTED THROUGH JOISTED FLOOR VOIDS USING 6242B CABLES (COLOUR TO HARMONISED STANDARDS) AND SLIDE TYPE PLUG-IN CEILING HOSES. PART OF BASEMENT TO BE CARRIED OUT IN LSF SINGLE CORE 6419 CABLES.
- LIGHTING CONTROL SYSTEMS TO BE BY SETSQUARE AS DETAILED ON THE DRAWINGS. THE ELECTRICAL CONTRACTOR IS TO ALLOW FOR SETSQUARE TO COMMISSION THE INSTALLATION WHEN COMPLETE THIS WILL PROVIDE THE CLIENT WITH A THREE YEAR GUARANTEE TO THE EQUIPMENT.
- ALL ACCESSORIES TO BE MK WHITE LOGIC RANGE WITH THE EXCEPTION OF THE GROUND FLOOR RECEPTION, GALLERY AREAS, AND STAIRCASES WHICH ARE TO BE MK EDGE RANGE ANTIQUE BRONZE FINISH UNLESS STATED OTHERWISE.
- THE ELECTRICAL CONTRACTOR ON COMPLETION OF THE FIRE ALARM WORKS ARE TO EMPLOY THE SERVICES OF THE SYSTEM MAINTAINER HONEYWELL BUILDING SOLUTIONS CONTACT PAUL CHARLES 07789 836197 TO RE-COMMISSION THE SYSTEM.
- ALL SMOKE DETECTOR COVERS USED DURING THE WORKS TO PREVENT FALSE ALARMS ARE TO BE REMOVED FROM THE SMOKE DETECTORS ON COMPLETION OF THE PROJECT WORKS.
- ALL LIGHTING ACCESSORIES TO BE MK WHITE LOGIC GRID SWITCH RANGE WITH THE EXCEPTION OF DIMMER SWITCHES WHICH ARE TO BE SETSQUARE RD WHITE. AREAS SUCH AS GROUND FLOOR RECEPTION, GALLERY AREAS AND STAIRCASES ARE TO BE MK EDGE RANGE ANTIQUE BRONZE FINISH UNLESS STATED OTHERWISE.
- FOR SCHEDULE OF LUMINAIRES REFER TO ELECTRICAL SPECIFICATION.
- SMALL POWER TO BE WIRED USING GALVANISED TRUNKING AND 20mm UPVC CONDUIT, OR ROUTED THROUGH JOISTED FLOOR VOID USING 6242B CABLE (COLOURS TO HARMONISED STANDARDS). PART OF BASEMENT TO BE CARRIED OUT USING LSF SINGLE CORE 6419 CABLES.
- ALL LIGHT SWITCHES, SOCKETS, SPURS ETC. ARE TO BE SUITABLY LABELLED USING D740 MACHINE OR SIMILAR DETAILING CIRCUIT REFERENCE.
- ALL UNSTRUCT SUPPORTS TO HAVE END CAPS FITTED AND DROP RODS OUT BACK AS FAR AS POSSIBLE AND PROTECTION CAPS FITTED.
- ELECTRICAL CONTRACTORS TO CO-ORDINATE ALL MECHANICAL AND ELECTRICAL SERVICES TO ENSURE ALL SERVICES SUITABLY INTEGRATE TO PREVENT ANY CLASHES AND ALLOW FOR ANY FUTURE MAINTENANCE ACCESS.

Rev	Date	Details	By	Chd
D	MAY 2012	REVISED AS INDICATED	TTJ	TTJ
C	APR 2012	REVISED AS INDICATED	TTJ	TTJ
B	MAR 2012	INTRUDER ALARMS, ACCESS CONTROLS AND PANIC ALARMS REVISED	TTJ	TTJ
A	FEB 2012	CONSTRUCTION ISSUE GENERALLY REVISED AS INDICATED	TTJ	TTJ

HITEK
Consultants

Hitek Consultants Ltd
Chartered Building Services Consulting Engineers
Barn A, The Stables
Parsonage Farm
Hollow Hill Lane
Iver, Bucks
SLO 0JW

T 01753 650 310
T 0844 880 5701
F 0844 880 5722
E info@hitekconsultants.co.uk
enquiries@hitekconsultants.co.uk
www.hitekconsultants.co.uk

Project
**53 GORDON SQUARE
LONDON
WC1H 0PD**

Client
SCHOOL OF ORIENTAL & AFRICAN STUDIES

Architect
TUFFIN FERRABY TAYLOR

Title
**GROUND FLOOR
PROPOSED SMALL POWER &
ANCILLARY SERVICES LAYOUT**

Scale	1:50 @ A1	Drawing no.	5154/E301
Date	AUG 2011	Revision	D
Designed	TTJ	Chd ref	5154E301D
Drawn	CMW	Checked	TTJ

THIS DRAWING REMAINS THE PROPERTY OF HITEK CONSULTANTS LIMITED. COPIES OF THIS DRAWING OR PARTS THEREOF ARE PROHIBITED WITHOUT EXPRESS PERMISSION.