A CONTRACTOR OF THE PROPERTY O

Our Ref: HT: 17143/JJS/tsl

21 March 2012

Brian Lamden Brian Lamden Associates 35C North Row London W1K 6DH

By post and email at: ohlam@brianlamden.com

Dear Brian

RE: 12, 13 AND 14 BLOOMSBURY SQUARE RELOCATION OF CONDENSERS

We have been informed that the proposed location of the condensers of the above site has changed. We have reviewed and assessed the new location based on Samuely Construction Structural Engineers drawing 3786-01 dated January 2012.

We reference to our Environmental Noise Survey and Plant Noise Assessment Report 17143/PNA1 dated 15 April 2011, we have previously advised acoustic enclosures or the reselection for the condensers to be installed on 12 and 14 Bloomsbury Square. We understand the choice of noise mitigation is acoustic enclosures.

The new scheme would require that all 3No. condensers are housed in acoustic enclosures to the same specification i.e. 47dBA measured at 1m in all directions.

We trust the enclosed is clear and of assistance. Should you have any queries please do not hesitate to contact us.

Yours sincerely

for HANN TUCKER ASSOCIATES

John Smethurst

## **Hann Tucker Associates**

Consultants in Acoustics Noise and Vibration Control

Duke House 1-2 Duke Street Woking Surrey GU21 5BA

(T) +44 (0)1483 770595

(F) +44 (0)1483 729565

(E) enquiries@hanntucker.co.uk

(W) www.hanntucker.co.uk

Directors:

Stuart G Morgan CEng MIMechE MCIBSE FIOA (Chairman) Simon R Hancock BEng(Hons) CEng MCIBSE FIOA (Managing) John L Gibbs MIOA(D) MSEE CEnv John R Ridpath BSc(Hons) MIOA

Associates:

Teli Chinelis BSc(Hons) PgDip CEng MIOA MIMechE MCIBSE Robin O Wood BEng(Hons) MIOA Andrew D Fermer BSc(Hons) MIOA Andrew G Jameson BSc(Hons) MIOA