

Highgate Road (ADF) 16.01.12

Floor Ref.	Room Ref.	Room Use	Window Ref.	ADF Existing	ADF Proposed	Req'd Value	Pass/Fail
------------	-----------	----------	-------------	--------------	--------------	-------------	-----------

Proposed

Ground	R5	Bedroom	W7	0.81	0.57	1.0	PASS
			W8	0.83	0.81		
				1.64	1.38		
Ground	R6	Bedroom	W9	3.57	2.71	1.0	PASS
				3.57	2.71		
Ground	R7	Kitchen	W10	2.20	0.24	2.0	PASS
			W20	1.89	2.09		
			W21	0.09	0.10		
			W22	0.11	0.11		
			4.29	2.54			
Ground	R8	Kitchen	W12	1.74	1.51	2.0	PASS
			W16	1.97	2.25		
			W17	0.09	0.09		
			W18	0.10	0.11		
			3.91	3.96			
Ground	R9	Bedroom	W12	3.92	3.39	1.0	PASS
				3.92	3.39		
Ground	R10	Bedroom	W13	1.55	1.35	1.0	PASS
				1.55	1.35		
Ground	R11	Bedroom	W14	4.10	2.71	1.0	PASS
				4.10	2.71		
Ground	R12	Bedroom	W15	3.97	4.74	1.0	PASS
				3.97	4.74		
Ground	R13	Bedroom	W16	4.32	4.92	1.0	PASS
				4.32	4.92		
Ground	R14	Bedroom	W23	5.47	6.12	1.0	PASS
				5.47	6.12		
Ground	R15	Bedroom	W24	5.97	6.79	1.0	PASS
				5.97	6.79		
Ground	R16	Bedroom	W25	3.65	3.53	1.0	PASS
				3.65	3.53		
First	R1	Kitchen	W9	2.72	2.34	2.0	PASS
			W10	3.12	2.43		
			5.84	4.77			
First	R2	Kitchen	W11	3.05	2.35	2.0	PASS
			W12	2.99	2.25		
			6.04	4.60			