



DRAWING STATUS

FOR COMMENT

DO NOT SCALE FROM DRAWING

NOTES

See equipment schedules for heating/cooling loads and equipment details.

All secondary supply ductwork, including plenum boxes are to be thermally insulated.

Condense pipework is to connect to local soil stack/pipe.

Positions of room controllers TBC

All supply ductwork to be thermally insulated. See M001 for supply air schematic

- LEGEND
- EXTRACT GRILLE
 - SUPPLY GRILLE
 - FRIDGE PIPE TRAY
 - TRAY RISER FB/TA
 - BRANCH SELECTOR BOX
 - VRV CONTROL
 - SWITCHED FUSED SPUR
 - FIRE DAMPER C/W ACCESS DOOR
 - VOLUME CONTROL DAMPER
 - REFRIGERANT PIPE

B	Terraces VRV System added	08.03.11
A	FCUs ceiling mounted	18.02.11
REV	DESCRIPTION	DATE

Building Services (Beds) Limited

M & E Contractors
Unit 15 Riboon Way
Progress Park
Luton LU4 9UR
Tel: 01582 565544 Fax: 01582 565566
www.buildingservicesbeds.co.uk

DHP
PROPERTY CONSULTANTS

243 Brooklands Road
Weybridge
Surrey KT13 0RH
Tel: 01932 850100
Fax: 01932 841800
Email: business@dhpuk.co.uk
Web: www.dhpuk.co.uk

PROJECT NAME
**Bloomsbury Publishing
49-51 Bedford Square
London
WC1B 3DP**

DRAWING TITLE
**FIRST FLOOR
HIGH LEVEL
MECHANICAL SERVICES
LAYOUT**

SCALE 1:50@A1	DRAWN BY NB CHECKED BY MD	DATE 11.02.11 DATE 11.02.11
-------------------------	--	--

PROJECT
11002

DWG No M104	REV No B
-----------------------	--------------------