

For continuation refer to drawing  
no. ARUP-50-DR-B10A

For continuation refer to drawing  
no. ARUP-50-DR-B10B

For continuation refer to drawing  
no. ARUP-50-DR-B10D

- Notes:-
- This drawing represents design intent but the final built layout is subject to coordination by the architect.
  - This drawing is to be read in conjunction with all Electrical, Mechanical, Public Health, Structural and Architectural drawings.
  - Refer to schematics for ductwork sizes, pipework sizes and volume flow rates.
  - All ductwork terminating in dampers or open ends must be finished with 60% free area insect mesh with maximum hole size 1mm unless otherwise specified.

800x500 transforms to 7100 at HL  
Smoke extract to atmosphere


REFER TO DRAWING No.  
ARUP-51-DR-B10X  
FOR SERVICES IN THIS AREA

| Issue           | Date     | By | Chkd | Appd |
|-----------------|----------|----|------|------|
| C1              | 26/08/11 | RW | AD   | AS   |
| Construction    |          |    |      |      |
| T3              | 17/03/11 | MO | AD   | AS   |
| Tender          |          |    |      |      |
| T2              | 24/02/11 | MO | AD   | AS   |
| Tender          |          |    |      |      |
| T1              | 28/01/11 | MO | AD   | AS   |
| For Information |          |    |      |      |
| O1              | 17/08/10 | TB | AD   | AS   |
| Stage E         |          |    |      |      |

**ARUP**  
13 Fenny Street  
London W1T 4BG  
Tel +44 (0)20 7591 1531 Fax +44 (0)20 7591 3024  
www.arup.com

Client  
**The British Museum**

Job Title  
**British Museum  
World Conservation and  
Exhibitions Centre**



Drawing Title  
**Mechanical Services  
Level B1 Layout  
Sheet C**

Scale of A0: 1:50

Discipline: Mechanical

Job No: 124020  
Drawing No: ARUP-50-DR-B10C

Drawing Status: Construction

Issue: C1