

- Notes:-
1. This drawing represents design intent but the final built layout is subject to coordination by the architect.
 2. This drawing is to be read in conjunction with all Electrical, Mechanical, Public Health, Structural and Architectural drawings.
 3. Refer to schematics for ductwork sizes, pipework sizes and volume flow rates.
 4. All ductwork terminating in dampers or open ends must be finished with 60% free area insect mesh with maximum hole size 1mm unless otherwise specified.


C1	26/08/11	RW	AD	AS
T3	17/03/11	MO	AD	AS
T2	24/02/11	MO	AD	AS
T1	28/01/11	MO	AD	AS
O1	17/08/10	TB	AD	AS
Issue	Date	By	Chkd	Appd

ARUP

13 Finsbury Street
London EC2A 3PB
Tel: +44 (0)20 7551 1531 Fax: +44 (0)20 7551 3024
www.arup.com

Client
The British Museum

Job Title
**British Museum
World Conservation and
Exhibitions Centre**



Drawing Title
**Mechanical Services
Level B2 Layout
Sheet A**

Scale at A0
1:50

Discipline
Mechanical

Job No.
124020

Drawing Status
Construction

Drawing No.
ARUP-50-DR-B20A

Issue
C1