

Notes

Grille performance at proposed mounting height to be tested by contractor off-site. Mock-up should suitable sized to test longest through and should include mock luminaires cable tray and and other services that may affect performance.


C1	26/08/11	RW	AD	AS
Construction				
T3	13/05/11	MO	AD	AS
Tender Addendum				
T2	17/03/11	MO	AD	AS
Tender				
T1	24/02/11	MO	AD	AS
Tender				
Issue	Date	By	Chkd	Appd

ARUP

13 Finsbury Street
London EC2A 1ED
Tel: +44 (0)20 7566 1000 Fax: +44 (0)20 7566 3024
www.arup.com

Client
The British Museum

Job Title
British Museum
World Conservation and
Exhibitions Centre



Drawing Title
Mechanical Services
Building 5
Section - East

Scale of A0
1:50

Discipline
Combined

Job No
124020

Drawing Status
Construction

Drawing No
ARUP-50-DR-SC01

Issue
C1