



NOTES

- For connections to all Air Handling Units, Close Control Units, VAV, RWH and Fan Coil Units refer to Detail A unless otherwise shown on drawing.
- Follow manufacturers' guidance for exact installation arrangement.

DETAIL A

DETAIL B

DETAIL C

DETAIL D

In addition to Detail A, CCUs at Level B2 shall include automatic valve shut-off system linked to leak detection below each unit.

C1	26/08/11	TB	AD	AS
Construction				
T4	10/05/11	RW	AD	AS
Tender addendum				
T3	17/03/11	MO	AD	AS
Tender				
T2	24/02/11	MO	AD	AS
Tender				
T1	28/01/11	MO	AD	AS
For Information				
01	14/08/09	RW	AD	AS
Stage D Issue				
Issue	Date	By	Chkd	Appd

ARUP

13 Finsbury Street  
London EC2A 4ED  
Tel: +44 (0)20 7556 1531 Fax: +44 (0)20 7556 3024  
www.arup.com

Client  
The British Museum

Job Title  
British Museum  
World Conservation and  
Exhibitions Centre

Key Plan

Drawing Title  
Mechanical Services  
Low Temperature Hot Water  
Schematic  
Sheet 2 of 2

Scale at A0  
N.T.S.

Discipline  
Mechanical

Job No  
124020

Drawing Status  
Construction

Drawing No  
ARUP-50-DR-SM11

Issue  
C1