



Notes
All grilles of linear slot type customised for bottom entry ductwork. Dummy slots required between active slots to give continuous finish.
For ductwork between VAV boxes and grilles refer to ARUP-50-DR-SC01 and ARUP-50-DR-SC02.
For science areas (greyed out) see ARUP-50-DR-SM47.

C1	26/08/11	RW	AD	AS
Construction				
T4	13/05/11	RW	AD	AS
Tender Addendum				
T3	17/03/11	RW	AD	AS
Tender				
T2	24/02/11	RW	AD	AS
Tender				
T1	28/01/11	RW	AD	AS
For Information				
01	31/07/09	RW	AD	AS
Stage D Issue				
Issue	Date	By	Chkd	Appd

ARUP

13 Finsbury Street
London EC2A 4ES
Tel +44 (0)20 7500 1531 Fax +44 (0)20 7500 3024
www.arup.com

Client
The British Museum

Job Title
British Museum
World Conservation and
Exhibitions Centre

Key Plan

Drawing Title
Mechanical Services
General Air Handling Schematic
Offices
Building 5

Scale at A0
N.T.S.

Discipline
Mechanical

Job No
124020
Drawing Status
Construction

Drawing No
ARUP-50-DR-SM41

Issue
C1