



- Notes
- 1. All exhaust ductwork from dehumidifiers to be stainless steel.
 - 2. All dust extract arms to have individual filter. Refer to data sheets
 - 3. C1 Note removed
 - 4. Supply air from CCU ducted to H/L supply grilles.
 - 5. Filter unit including HEPA filter
 - 6. Duct constriction instead of damper for commissioning (to avoid dust build-up) to be sized by contractor.
- Legend:
- ↺ User operated manual Damper
 - ⊙ Fume/dust extract VAV box
 - ⊞ CPD Constant pressure regulating damper

C1	26/08/11	RW	AD	AS
Construction				
T4	13/05/11	MO	AD	AS
Tender Addendum				
T3	17/03/11	MO	AD	AS
Tender				
T2	24/02/11	MO	AD	AS
Tender				
T1	28/01/11	MO	AD	AS
For Information				
02	03/08/10	RLP	AD	AS
Stage E Issue				
01	14/08/09	RW	AD	AS
Stage D Issue				
Issue	Date	By	Chkd	Appd

ARUP

13 Finsbury Street
London EC2M 7TS
Tel: +44 (0)20 7550 1531 Fax: +44 (0)20 7550 3024
www.arup.com

Client

The British Museum

Job Title

British Museum
World Conservation and
Exhibitions Centre

Drawing Title

Mechanical Services
General Air Handling Schematic
Conservation and Offices
Building 1

Scale of A0

N.T.S.

Discipline

Mechanical

Job No

124020

Drawing No

ARUP-50-DR-SM42

Issue

C1

Construction

J:\120000\124020\124020-BM-WC-Conservation-General-Air-Handling-Schematic-Drawing.dwg 31 Aug 2011 16:42:11 16 48818307 VCD 4833 8886 7192 CUC3B101 Rev00000