Notes

1. Refer to architects drawings for setting out.
2. This drawing is to be read in conjunction with all Electrical, Mechanical, Public Health, Structural & Architectural drawings.
3. Where no luminaires are indicated cross refer to 63- series drawings.
4. Motorised fire dampers are indicated on mechanical layouts. Allow for a single phase power supply (fused connection unit) to each.
5. Leak detection probes requiredto all cavities in basement levels. Extent to be confirmed during stage F. Make allowance for a probe and power supply every 20m artound perimeter.

Issue	Date	By	Chkd	Appd
C1	26/08/11	IM	DAD	AS
Construction				
T4	13/05/11	IM	AD	AS
Tender Addendum				
T3	17/03/11	MRC	DAD	AS
Tender				
T2	24/02/11	MRC	DAD	AS
Tender				
T1	28/01/11	MC	AD	AS
For Information				
01	17/08/10	MC	AD	AS
Stage E				

ARUP

13 Fitzroy Street
London W1T 4BQ
Tel +44 (0)20 7636 1531 Fax +44 (0)20 7580 3924
www.arup.com

Client
The British Museum

Job Title
British Museum
World Conservation and Exhibitions Centre

Key Plan

Drawing Title
Electrical Services
Level 5 Layout - High Level

Sheet F Building 1, 2 & 5

Scale at A0 1:100

Discipline Electrical

Job No **124020**

Drawing Status **Construction**

Drawing No. **ARUP-60-DR-052F**

Issue **C1**

Do not scale

© Arup

J:\100000\124000\124020 British Museum\4 Internal Data\03 Drawings\01 Issue Drawings\E\ARUP-RD-DR-052F Wed 2 Sep 2011 16:36:05 sc C264CF29-AC56-4CAF-8A14-60D3A63A0A1F pcp arkwright8