



Notes

1. Refer to architects drawings for setting out.
2. This drawing is to be read in conjunction with all Electrical, Mechanical, Public Health, Structural & Architectural drawings.
3. Where no luminaires are indicated cross refer to G5-series drawings.
4. Motorised fire dampers are indicated on mechanical layouts. Allow for a single phase power supply (fused connection unit) to each.
5. Leak detection probes required to all cavities in basement levels. Extent to be confirmed during stage F. Make allowance for a probe and power supply every 20m around perimeter.

C1	26/08/11	IM	DAD	AS
Construction				
T4	13/05/11	IM	AD	AS
Tender Addendum				
T3	17/03/11	MRC	DAD	AS
Tender				
T2	24/02/11	MRC	DAD	AS
Tender				
T1	28/01/11	MC	AD	AS
For Information				
01	17/08/10	MC	AD	AS
Stage E				
Issue	Date	By	Chkd	Appd

## ARUP

13 Finsbury Street  
London EC2A 1ED  
Tel: +44 (0)20 7551 1511 Fax: +44 (0)20 7551 3024  
www.arup.com

Client  
**The British Museum**

Job Title  
**British Museum  
World Conservation and  
Exhibitions Centre**

Key Plan

Drawing Title  
**Electrical Services  
Level 5 Layout - High Level**

Sheet G Building 3 and 4

Scale at A0  
1:50

Discipline  
**Electrical**

Job No  
**124020**

Drawing Status  
**Construction**

Drawing No  
**ARUP-60-DR-052G**

Sheet  
**C1**