



- Notes
1. Refer to architects drawings for setting out.
  2. This drawing is to be read in conjunction with all Electrical, Mechanical, Public Health, Structural & Architectural drawings.
  3. Where no luminaires are indicated cross refer to 65-series drawings.
  4. Motorised fire dampers are indicated on mechanical layouts. Allow for a single phase power supply (fused connection unit) to each.
  5. Leak detection probes required to all cavities in basement levels. Extent to be confirmed during stage F. Make allowance for a probe and power supply every 20m around perimeter.

C1	26/08/11	IM	DAD	AS
Construction				
T3	17/03/11	MRC	DAD	AS
Tender				
T2	24/02/11	MRC	DAD	AS
Tender				
T1	28/01/11	MC	AD	AS
For Information				
01	17/08/10	MC	AD	AS
Stage E				
Issue	Date	By	Chkd	Appd

ARUP

13 Finsbury Street  
London EC2A 1EJ  
Tel: +44 (0)20 7580 1551 Fax: +44 (0)20 7580 3024  
www.arup.com

Client  
The British Museum

Job Title  
British Museum  
World Conservation and  
Exhibitions Centre

Key Plan

Drawing Title  
Electrical Services  
Roof Layout

Sheet B Building 2 and 3

Scale at A0  
1:50

Discipline  
Electrical

Job No  
124020

Drawing Status  
Construction

Drawing No  
ARUP-60-DR-RF2B

Issue  
C1