

- Notes:-
1. This drawing represents design intent but the final built layout is subject to coordination by the architect.
 2. This drawing is to be read in conjunction with all Electrical, Mechanical, Public Health, Structural and Architectural drawings.
 3. Refer to schematics for ductwork sizes, pipework sizes and volume flow rates.
 4. All ductwork terminating in dampers or open ends must be finished with 60% free area insect mesh with maximum hole size 1mm unless otherwise specified.


C1	26/08/11	RW	AD	AS
Construction				
T3	19/05/11	MO	AD	AS
Tender Addendum				
T2	17/03/11	MO	AD	AS
Tender				
T1	24/02/11	MO	AD	AS
Tender				
Issue	Date	By	Chkd	Appd

ARUP

13 Finsbury Street
London EC2A 1EJ
Tel: +44 (0)20 7550 1531 Fax: +44 (0)20 7550 3024
www.arup.com

Client
The British Museum

Job Title
**British Museum
World Conservation and
Exhibitions Centre**



Drawing Title
**Mechanical Services
Level 6A
Special Extract Layout
Sheet C**

Scale of A0	1:50
Discipline	Mechanical
Job No	124020
Drawing No	ARUP-50-DR-6AXC
Drawing Status	Construction
Issue	C1