

Milan Nedelkovic  
Nedelkovic  
6 Powlis Gardens  
London  
W11 1JG

Application Ref: **2011/4796/P**  
Please ask for: **David Glasgow**  
Telephone: 020 7974 **5562**

9 November 2011

Dear Sir/Madam

## **DECISION**

Town and Country Planning Acts 1990 (as amended)  
Town and Country Planning (General Development Procedure) Order 1995  
Town and Country Planning (Applications) Regulations 1988

### **Full Planning Permission Granted**

Address:  
**146 Royal College Street  
London  
NW1 0SE**

Proposal:  
Replacement of entrance door at ground floor level with new glazed entrance doors and solid security roller shutter on elevation facing the Canal to existing Office use (Class B1)

Drawing Nos: Site location plan; 14RCS-PL-06A; 14RCS-PL-05A; 14RCS-PL-07A;  
14RCS-PL- PHOTOS

The Council has considered your application and decided to grant permission subject to the following condition(s):

Condition(s) and Reason(s):

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and



- Country Planning Act 1990 (as amended).
- 2 All new external work shall be carried out in materials that resemble, as closely as possible, in colour and texture those of the existing building, unless otherwise specified in the approved application.

Reason: To safeguard the appearance of the premises and the character of the immediate area in accordance with the requirements of policy CS14 of the London Borough of Camden Local Development Framework Core Strategy and policy DP24 and DP25 of the London Borough of Camden Local Development Framework Development Policies.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans: Site location plan; 14RCS-PL-06A; 14RCS-PL-05A; 14RCS-PL-07A; 14RCS-PL- PHOTOS

Reason: For the avoidance of doubt and in the interest of proper planning.

Informative(s):

- 1 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 2363).
- 2 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website <http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.
- 3 Reasons for granting permission.

The proposed development is in general accordance with the policy requirements of the London Borough of Camden Local Development Framework Core Strategy, with particular regard to policies CS1 (Distribution of growth), CS5 (Managing the impact of growth and development), CS14 (Promoting high quality places and conserving our heritage); the London Borough of Camden Local Development Framework Development Policies, with particular regard to policies DP24 (Securing high quality design), DP25 (Conserving Camden's heritage), DP26 (Managing the impact of development on occupiers and neighbours),

For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officer's report.

**Disclaimer**

***This is an internet copy for information purposes. If you require a copy of the signed original please telephone Contact Camden on (020) 7974 4444***