

Mr Richard Howard
The Interiors Group
20 Balderton Street
London
W1K 6TL

Application Ref: **2011/4492/P**
Please ask for: **Jenna Litherland**
Telephone: 020 7974 **3070**

26 October 2011

Dear Sir/Madam

DECISION

Town and Country Planning Acts 1990 (as amended)
Town and Country Planning (General Development Procedure) Order 1995
Town and Country Planning (Applications) Regulations 1988

Full Planning Permission Granted

Address:
170 Tottenham Court Road
London
W1T 7HA

Proposal:
Installation of two air conditioning units and air handling unit at roof level in connection with the existing offices (Class B1).

Drawing Nos: Site Location Plan; Q11097/M/02-C; Acoustic Report ref. no. CS7058A.

The Council has considered your application and decided to grant permission subject to the following conditions:

Conditions and Reasons:

- 1 The development hereby permitted must be begun not later than the end of three years from the date of this permission.

Reason: In order to comply with the provisions of Section 91 of the Town and Country Planning Act 1990 (as amended).



- 2 Noise levels at a point 1 metre external to sensitive facades shall be at least 5dB(A) less than the existing background measurement (LA90), expressed in dB(A) when all plant/equipment (or any part of it) is in operation unless the plant/equipment hereby permitted will have a noise that has a distinguishable, discrete continuous note (whine, hiss, screech, hum) and/or if there are distinct impulses (bangs, clicks, clatters, thumps), then the noise levels from that piece of plant/equipment at any sensitive façade shall be at least 10dB(A) below the LA90, expressed in dB(A).

Reason: To safeguard the amenities of the adjoining premises and the area generally in accordance with the requirements of policy CS5 of the London Borough of Camden Local Development Framework Core Strategy and policies DP26 and DP28 of the London Borough of Camden Local Development Framework Development Policies.

- 3 The development hereby permitted shall be carried out in accordance with the following approved plans Site Location Plan; Q11097/M/02-C; Acoustic Report ref. no. CS7058A.

Reason: For the avoidance of doubt and in the interest of proper planning.

Informatives:

- 1 Reasons for granting permission.

The proposed development is in general accordance with the London Borough of Camden Local Development Framework Core Strategy, with particular regard to policies CS5: Managing the impact of growth and development, CS4: Areas of more limited change, CS14: Promoting high quality places and conserving our heritage and the London Borough of Camden Local Development Framework Development Policies, with particular regard to policies DP24: Securing high quality design, DP26: Managing the impact of development on occupiers and neighbours, DP28: Noise . For a more detailed understanding of the reasons for the granting of this planning permission, please refer to the officer's report.

- 2 Your proposals may be subject to control under the Building Regulations and/or the London Buildings Acts which cover aspects including fire and emergency escape, access and facilities for people with disabilities and sound insulation between dwellings. You are advised to consult the Council's Building Control Service, Camden Town Hall, Argyle Street WC1H 8EQ, (tel: 020-7974 2363).
- 3 Noise from demolition and construction works is subject to control under the Control of Pollution Act 1974. You must carry out any building works that can be heard at the boundary of the site only between 08.00 and 18.00 hours Monday to Friday and 08.00 to 13.00 on Saturday and not at all on Sundays and Public Holidays. You are advised to consult the Council's Compliance and Enforcement team [Regulatory Services], Camden Town Hall, Argyle Street, WC1H 8EQ (Tel. No. 020 7974 4444 or on the website

<http://www.camden.gov.uk/ccm/content/contacts/council-contacts/environment/contact-the-environmental-health-team.en> or seek prior approval under Section 61 of the Act if you anticipate any difficulty in carrying out construction other than within the hours stated above.

- 4 You are advised that only plant cited in the acoustic report shall be installed, put to use and maintained as recommended by the manufacturers

Disclaimer

This is an internet copy for information purposes. If you require a copy of the signed original please telephone Contact Camden on (020) 7974 4444