

CONABEARE



ACOUSTICS

RECEIVED
05 SEP 2011

ACOUSTIC REPORT

Ref. No. CS 7076

**71 Kingsway
London
WC2**

15th August 2011

Prepared By:


.....

John E Redknap MBA, MIOA, MCMI

Checked By:


.....

David Whymark - Director

**Client: Callisia Limited
443 Stroude Road
Virginia Water
Surrey
GU25 4BU**

Conabears Acoustics Limited
10 Chiltern Enterprise Centre, Station Road, Theale, Berkshire. RG7 4AA
Telephone 0118 930 3050 Facsimile 0118 930 3912
sales@conabears.co.uk

FORWARD

New air conditioning equipment is proposed on the roof of the premises, adjacent to existing units. Conabeare Acoustics Limited has therefore been commissioned to undertake an Environmental Sound Survey at this level of the building.

The results of the survey will establish the Background Sound Level to enable checks to be made on the mechanical services plant in order that they comply with planning requirements.

SUMMARY

The lowest measured Background Sound Levels $L_{A90,15MIN}$ were as follows:

$L_{A90,15MIN}$	54.6dB(A) between 07:00 hours to 19:00 hours (Day Time)
$L_{A90,15MIN}$	45.6dB(A) between 19:00 hours to 23:00 hours (Evening)
$L_{A90,15MIN}$	40.3dB(A) between 23:00 hours to 07:00 hours (Night Time)

CONTENTS

1. Author
2. Client
3. Introduction
4. Noise Principles
5. The Site
6. Measurement Methodology
7. Planning noise requirements
8. Assessment
9. Sound Level Measurements
10. Glossary of Terms
11. Location Photograph

**1. Author**

John E Redknap MBA, MIOA, MCMI

The author has been practising in noise control engineering since 1985. He has gained a wide range of experience over this period and is employed as a Sales Engineer for **Conabeare Acoustics Ltd.**

2. Client

The survey and report has been undertaken on behalf of:

Callisia Limited
443 Stroude Road
Virginia Water
Surrey
GU25 4BU

3. Introduction

New air conditioning equipment is proposed on the roof of the premises, adjacent to existing units. Conabeare Acoustics Limited has therefore been commissioned to undertake an Environmental Sound Survey at this level of the building.

An Environmental Sound Survey has been carried out to establish the existing Background Sound Levels. The results of the Environmental Sound Survey are also used as a datum so that acoustic calculations can be undertaken to determine the likely impact of the proposed plant on the nearest sound sensitive locations.

4. Noise Principles

The Environmental Sound Survey has been carried out in accordance with the principles of BS7445-1 (2003) to establish the existing Background Sound Levels. The Background Sound Level measured is in terms of A-weighted sound pressure level L_{A90} with a time interval of 15 minutes.



5. The Site

The property is located at 71 Kingsway, London WC2, an area dominated by commercial/office buildings. The proposed air conditioning equipment is to be located at roof level, adjacent to the existing plant. It was noted whilst on site that there is also other existing plant on this roof as well a considerable amount of plant on the surrounding roof areas. The general ambient noise level in the area is therefore expected to be dominated by existing plant noise, plus traffic noise from the busy Kingsway.

6. Measurement Methodology

A SVAN 949 (Precision) Environmental Sound Level Analyser, fitted with an Electret Microphone was secured to the existing railings on the roof of the property, positioned as illustrated on the attached location photograph.

The survey was carried out from 08:59 hours on Tuesday 9th August 2011, up until 09:29 hours on Wednesday 10th August 2011.

The Analyser was programmed to produce the following indices:

L_{AEQ.15MIN}, L_{A90.15MIN}, L_{A10.15MIN}

Attached for your reference is a Glossary of these terms.

The analyser was checked for calibration before the survey commenced and at the end of survey with a CEL 284/2 Class 1 calibrator with no measurable deviation.

The weather was generally dry and warm, with partly cloudy skies.

Having reviewed the results of our survey, it is our opinion that the weather experienced over the survey period has not had any detrimental effect on the lowest recorded readings and therefore on our recommendations.

7. Planning Noise Requirements

The Planning noise requirement for this area will be assessed against the criteria set out in the Council's Unitary Development Plan (UDP). As a guide, the predicted level from any proposed plant should be at least 10dB(A) below the lowest measured Background Sound Level (L_{A90}) at 1 metre from the nearest effected residential property. Allowance should also be made for any tonal noise emanating from the proposed units.



8. Assessment

The objective of any specification limiting sound should be to ensure that sound emissions from the proposed plant should not materially add to the existing ambient noise climate when measured 1m from the nearest effected property window.

The level at which the target should be set is normally specified by the planning authority in their planning consent conditions.

In the absence of any such specification, we would recommend setting a limit on the proposed plant sound level as follows, with the proviso that any sound produced by this plant must be quite free of any audibly evident, tonality or similar characteristics.

The lowest measured Background Sound Levels $L_{A90-15min}$ were as follows:

$L_{A90-15min}$	54.6dB(A) between 07:00 hours to 19:00 hours (Day Time)
$L_{A90-15min}$	45.6dB(A) between 19:00 hours to 23:00 hours (Evening)
$L_{A90-15min}$	40.3dB(A) between 23:00 hours to 07:00 hours (Night Time)

Residential Accommodation

The current design policy of council planners is that noise produced by mechanical plant should be at least 10dB(A) below the background sound level at the nearest sound sensitive window.

It should also be noted that this should be achieved with all plant operating normally, any plant exhibiting characteristics which are tonal or intermittent in nature should be designed to criteria 5dB(A) more stringent. Allowances should also be made for the additional effect of multiple noise sources.

The above is generally acceptable to local authority for this area but this should be as a matter of course be verified with the local Environmental Health or Planning Departments.

Office Accommodation

Standing on the roof of the premises, there appeared to be no residential properties in the immediate vicinity.

At the rear of the property, across a lightwell, is the Kensington College of Business building, with the top floor virtually level with the roof of 71 Kingsway.

Further along Kingsway, across Wild Court, the upper floors of the building adjacent to number 71 Kingsway contains office accommodation.



For the purposes of this report, we have assumed these two locations to be the closest office accommodation and thereby the nearest sound sensitive windows.

The Kensington College of Business windows are estimated to be at distance of 5m from the centre of the proposed plant. This position is referenced as Assessment Location A in our acoustic calculations and on our location photograph.

The adjacent office windows are estimated to be at distance of 15m from the centre of the proposed plant. This position is referenced as Assessment Location B in our acoustic calculations and on our location photograph.

As we are not considering residential properties in this report, in our opinion it is appropriate to consider higher noise limits than those previously suggested for Residential Accommodation.

Proposed Design Target

BS8233: 1999 Sound insulation and noise reduction for buildings – Code of practice, recommends that noise levels in offices should be 40 to 45dB LAeq,T. In order to determine an appropriate noise criterion outside such offices it is necessary to consider the minimum sound reduction that may be provided by the external building fabric of such offices.

In the worst case it may be considered that some of the windows of these buildings may be openable. It is known that open windows provide a sound reduction of 10 – 15dBA. It is reasonable, therefore, to set a noise criterion of 50 to 55 dB LAeq,T at 1m from the façades of such buildings.

In our opinion the above would generally be acceptable to the local authority for this area, but all design targets should as a matter of course should be verified with the local Environmental Health or Planning Departments.

For Assessment Location A, we have illustrated on the attached calculation sheet that at 1 metre from the façade the Specific Sound Level would be 46dB(A). This figure is clearly below our limits of our suggested design target of 50 to 55 dB LAeq,T for Office Accommodation and should therefore meet the planning requirements of the local authority.

For Assessment Location B, we have illustrated on the attached calculation sheet that at 1 metre from the façade the Specific Sound Level would be 37dB(A). This figure is clearly below our limits of our suggested design target of 50 to 55 dB LAeq,T for Office Accommodation and should therefore meet the planning requirements of the local authority.



The proposed plant for this project is 3no. Mitsubishi SRK50ZJ-S and 2no. SRK63ZK-S as positioned on the Callisia drawing Q11115/M/03 revision A. We are advised that only single figure data is available for the proposed plant. Consequently, for the purposes of this report, and to enable spectrum analysis of the plant to be undertaken, we have been given sound data of a similar unit and asked to utilize this data in our calculations. It should therefore be noted that in both calculation sheets we have used the sound pressure spectrum data for a Mitsubishi PKA-RP100KAL.

9. Sound Level Measurements


The statistical readings obtained during the survey are attached to this report and are presented in both graphical and tabular form.

10. Glossary of Terms

L_{A90}	The sound pressure level in dB(A) which is exceeded for 90% of the time and is taken to be the effective lowest background sound level for the period by such methods of sound rating as that recommended in British Standard 4142. It will also be used as a basis for selecting limiting sound levels from new plant by Local Planning Authorities when setting Planning Consent Conditions.
L_{eq}	The "equivalent continuous sound level" for the measuring period, defined as the level in dB(A) which, if held constant over the measuring period, would produce the same amount of sound energy as does the actual varying ambient sound level. It is a measure of the amount of sound energy affecting the site from sources other than new plant or operations.
L_{A10}	The sound level exceeded for 10% of the time over the sample period. Originally used as a measure of subjective reaction to traffic noise in particular, it can also be taken as an indication of the practical maximum sound level that the building envelope will have to protect against.
dB(A)	Describes measured on a sound level meter incorporating a frequency weighting (A weighting) which differentiates between sounds of different frequency (pitch) in a similar way to the human ear. Measurements in dB(A) broadly agree with people's assessment of loudness. A change of 3dB(A) is the minimum perceptible under normal conditions, and a change of 10dB(A) corresponds roughly to halving or doubling the loudness of a sound.

11. Location Photographs

Assessment Location A




Part of existing plant

New plant to be positioned over yellow lines

Microphone and equipment set up on roof

Assessment Location B

Wild Court



CONABEARE ACOUSTICS LTD CALCULATION SHEET - One

CLIENT: Callisia		PROJECT: 71 Kingsway								
		DATE: 15th August 2011								
Roof Top Plant Location		Conabeare Acoustics ref: CS7076								
		Octave Band Centre Frequency (Hz)								
Description		63	125	250	500	1K	2K	4K	8K	dB(A)
LOCATION 'A' ASSESSMENT										
Mitsubishi PKA-RP100KAL	Lp @ 1m	45	45	48	44	45	43	36	27	49
Additional units	Four	6	6	6	6	6	6	6	6	
Combined Total		51	51	54	50	51	49	42	33	55
Additional Surface Reflections	None	0	0	0	0	0	0	0	0	
Screening via building	None	0	0	0	0	0	0	0	0	
Additional Distance 1to 5m to nearest window		-12	-12	-12	-12	-12	-12	-12	-12	
Façade Correction		3	3	3	3	3	3	3	3	
Lp @1m from receivers façade		42	42	45	41	42	40	33	24	46

Notes

Calculations are to the nearest top floor windows of the adjacent Kensington Business College
 No allowance has been made for any noise/vibration transfer through floor/structure
 Vibration isolation will be required for the new plant

CONABEARE ACOUSTICS LTD CALCULATION SHEET - Two


CLIENT: Callisia		PROJECT: 71 Kingsway								
		DATE: 15th August 2011								
Roof Top Plant Location		Conabeare Acoustics ref: CS7076								
		Octave Band Centre Frequency (Hz)								
Description		63	125	250	500	1K	2K	4K	8K	dB(A)
LOCATION 'B' ASSESSMENT										
Mitsubishi PKA-RP100KAL	Lp @ 1m	45	45	48	44	45	43	36	27	49
Additional units	Four	6	6	6	6	6	6	6	6	
Combined Total		51	51	54	50	51	49	42	33	55
Additional Surface Reflections	None	0	0	0	0	0	0	0	0	
Screening via building	None	0	0	0	0	0	0	0	0	
Additional Distance 1to 15m to nearest window		-21	-21	-21	-21	-21	-21	-21	-21	
Façade Correction		3	3	3	3	3	3	3	3	
Lp @1m from receivers façade		33	33	36	32	33	31	24	15	37

Notes

Calculations are to the nearest top floor windows of the adjacent office building
 No allowance has been made for any noise/vibration transfer through floor/structure
 Vibration isolation will be required for the new plant

Header information for the file[1] @CAL3230



Device type	SVAN 949
Serial No.	8572
Internal software version ...	5.13
File system version	5.12
Original file name	@CAL3230
Measurement hour	08:59'50
Measurement day	09/08/11
Device function	OCTAVE 1/1
Title text:	
Input	Microphone
Mic. polarization	0 V
Mic. field correction	FREE
Mic. outdoor filter	OFF
Compensation filter	OFF
Measurement range	105 dB
Leq integration	Linear
Trig. mode	OFF
Start delay	1 s
Integration time def.	15 m
Repetition cycle	Infinity
Number of spectra	1
Octave 1/1 lines	15+3
Octave 1/1 filter	Lin
Octave 1/1 in buffer	OFF
Number of histograms	3+18
Calibration type	Measuremer
Calibration time	08:52'12
Calibration date	09/08/11
Rotation measurement	OFF
Profile:	#1
Weighting filter	A
Detector type	Fast
Buffer contents definition ..	None
Calibration factor	2.5 dB





Main results:											
File	Date	Start	Filter	Detect	Time	units	Leq (A)	L1 dB(A)	L10 dB(A)	L90 dB(A)	
@CAL3230	09/08/11	08:59'50	A	Fast	00:15'00	dB	68.7	77.6	70.9	63.1	
@CAL3231	09/08/11	09:14'50	A	Fast	00:15'00	dB	68.0	75.2	71.0	63.4	
@CAL3232	09/08/11	09:29'50	A	Fast	00:15'00	dB	67.9	74.9	71.2	63.2	
@CAL3233	09/08/11	09:44'50	A	Fast	00:15'00	dB	65.7	71.7	67.9	62.2	
@CAL3234	09/08/11	09:59'50	A	Fast	00:15'00	dB	65.3	70.7	67.6	61.4	
@CAL3235	09/08/11	10:14'50	A	Fast	00:15'00	dB	65.7	72.3	68.3	61.4	
@CAL3236	09/08/11	10:29'50	A	Fast	00:15'00	dB	66.0	73.2	67.8	61.6	
@CAL3237	09/08/11	10:44'50	A	Fast	00:15'00	dB	66.0	72.9	68.2	62.0	
@CAL3238	09/08/11	10:59'50	A	Fast	00:15'00	dB	65.2	73.6	67.4	60.5	
@CAL3239	09/08/11	11:14'50	A	Fast	00:15'00	dB	68.1	80.1	67.8	60.2	
@CAL3240	09/08/11	11:29'50	A	Fast	00:15'00	dB	67.4	77.0	66.9	61.2	
@CAL3241	09/08/11	11:44'50	A	Fast	00:15'00	dB	68.5	80.7	67.5	61.2	
@CAL3242	09/08/11	11:59'50	A	Fast	00:15'00	dB	64.9	72.2	66.7	60.7	
@CAL3243	09/08/11	12:14'50	A	Fast	00:15'00	dB	65.7	73.4	67.6	61.7	
@CAL3244	09/08/11	12:29'50	A	Fast	00:15'00	dB	65.2	73.4	66.6	60.1	
@CAL3245	09/08/11	12:44'50	A	Fast	00:15'00	dB	63.9	69.9	66.2	60.5	
@CAL3246	09/08/11	12:59'50	A	Fast	00:15'00	dB	64.4	73.7	66.0	59.4	
@CAL3247	09/08/11	13:14'50	A	Fast	00:15'00	dB	63.8	71.0	65.7	59.1	
@CAL3248	09/08/11	13:29'50	A	Fast	00:15'00	dB	65.5	73.8	68.0	59.1	
@CAL3249	09/08/11	13:44'50	A	Fast	00:15'00	dB	65.6	73.6	69.1	59.9	
@CAL3250	09/08/11	13:59'50	A	Fast	00:15'00	dB	65.4	73.9	66.8	59.1	
@CAL3251	09/08/11	14:14'50	A	Fast	00:15'00	dB	61.1	69.5	63.3	56.3	
@CAL3252	09/08/11	14:29'50	A	Fast	00:15'00	dB	67.3	80.7	63.9	56.0	
@CAL3253	09/08/11	14:44'50	A	Fast	00:15'00	dB	61.8	69.4	63.9	56.6	
@CAL3254	09/08/11	14:59'50	A	Fast	00:15'00	dB	65.7	79.6	64.2	56.9	
@CAL3255	09/08/11	15:14'50	A	Fast	00:15'00	dB	62.6	72.1	64.8	56.8	
@CAL3256	09/08/11	15:29'50	A	Fast	00:15'00	dB	65.1	75.9	65.8	57.4	
@CAL3257	09/08/11	15:44'50	A	Fast	00:15'00	dB	67.8	80.9	66.9	57.7	

Main results:										
File	Date	Start	Filter	Detect	Time	units	Leq (A)	L1 dB(A)	L10 dB(A)	L90 dB(A)
@CAL3258	09/08/11	15:59'50	A	Fast	00:15'00	dB	67.1	79.4	66.9	60.8
@CAL3259	09/08/11	16:14'50	A	Fast	00:15'00	dB	67.8	80.0	66.4	58.4
@CAL3260	09/08/11	16:29'50	A	Fast	00:15'00	dB	67.5	78.3	64.0	57.4
@CAL3261	09/08/11	16:44'50	A	Fast	00:15'00	dB	66.0	78.3	64.9	57.0
@CAL3262	09/08/11	16:59'50	A	Fast	00:15'00	dB	61.2	67.8	63.6	56.7
@CAL3263	09/08/11	17:14'50	A	Fast	00:15'00	dB	64.7	72.5	64.7	57.3
@CAL3264	09/08/11	17:29'50	A	Fast	00:15'00	dB	61.9	69.7	64.4	57.8
@CAL3265	09/08/11	17:44'50	A	Fast	00:15'00	dB	61.7	69.4	63.8	56.5
@CAL3266	09/08/11	17:59'50	A	Fast	00:15'00	dB	62.6	69.5	65.5	57.8
@CAL3267	09/08/11	18:14'50	A	Fast	00:15'00	dB	61.8	69.1	64.3	57.3
@CAL3268	09/08/11	18:29'50	A	Fast	00:15'00	dB	65.9	76.9	65.9	57.9
@CAL3269	09/08/11	18:44'50	A	Fast	00:15'00	dB	62.6	70.1	64.9	57.9
@CAL3270	09/08/11	18:59'50	A	Fast	00:15'00	dB	62.1	67.9	64.7	57.7
@CAL3271	09/08/11	19:14'50	A	Fast	00:15'00	dB	61.3	67.7	64.1	55.9
@CAL3272	09/08/11	19:29'50	A	Fast	00:15'00	dB	67.0	80.0	66.8	58.0
@CAL3273	09/08/11	19:44'50	A	Fast	00:15'00	dB	62.9	70.2	65.8	57.1
@CAL3274	09/08/11	19:59'50	A	Fast	00:15'00	dB	63.6	70.7	66.3	58.8
@CAL3275	09/08/11	20:14'50	A	Fast	00:15'00	dB	62.8	68.5	65.4	58.4
@CAL3276	09/08/11	20:29'50	A	Fast	00:15'00	dB	63.8	72.2	66.5	57.4
@CAL3277	09/08/11	20:44'50	A	Fast	00:15'00	dB	64.8	75.0	67.5	58.3
@CAL3278	09/08/11	20:59'50	A	Fast	00:15'00	dB	62.0	68.4	64.9	56.9
@CAL3279	09/08/11	21:14'50	A	Fast	00:15'00	dB	63.7	72.3	66.4	57.6
@CAL3280	09/08/11	21:29'50	A	Fast	00:15'00	dB	63.3	72.9	64.7	57.2
@CAL3281	09/08/11	21:44'50	A	Fast	00:15'00	dB	65.4	77.9	65.4	55.7
@CAL3282	09/08/11	21:59'50	A	Fast	00:15'00	dB	57.7	64.2	61.0	52.3
@CAL3283	09/08/11	22:14'50	A	Fast	00:15'00	dB	55.3	64.0	57.7	50.0
@CAL3284	09/08/11	22:29'50	A	Fast	00:15'00	dB	54.1	62.7	56.4	47.2
@CAL3285	09/08/11	22:44'50	A	Fast	00:15'00	dB	52.2	58.9	55.0	46.4
@CAL3286	09/08/11	22:59'50	A	Fast	00:15'00	dB	53.0	62.2	55.6	45.6
@CAL3287	09/08/11	23:14'50	A	Fast	00:15'00	dB	53.4	61.7	55.1	45.7
@CAL3288	09/08/11	23:29'50	A	Fast	00:15'00	dB	52.5	59.9	55.0	45.1
@CAL3289	09/08/11	23:44'50	A	Fast	00:15'00	dB	50.9	58.5	54.1	44.4
@CAL3290	09/08/11	23:59'50	A	Fast	00:15'00	dB	50.8	57.3	54.5	44.1
@CAL3291	10/08/11	00:14'50	A	Fast	00:15'00	dB	52.0	60.9	54.8	44.4
@CAL3292	10/08/11	00:29'50	A	Fast	00:15'00	dB	50.3	58.6	53.3	43.2
@CAL3293	10/08/11	00:44'50	A	Fast	00:15'00	dB	49.8	57.1	53.1	43.0
@CAL3294	10/08/11	00:59'50	A	Fast	00:15'00	dB	47.0	54.6	50.4	41.3
@CAL3295	10/08/11	01:14'50	A	Fast	00:15'00	dB	48.8	56.3	51.2	41.4
@CAL3296	10/08/11	01:29'50	A	Fast	00:15'00	dB	47.4	55.2	50.6	41.2
@CAL3297	10/08/11	01:44'50	A	Fast	00:15'00	dB	47.2	54.9	51.0	41.0
@CAL3298	10/08/11	01:59'50	A	Fast	00:15'00	dB	48.0	56.3	51.5	41.1
@CAL3299	10/08/11	02:14'50	A	Fast	00:15'00	dB	47.5	55.5	51.1	40.6
@CAL3300	10/08/11	02:29'50	A	Fast	00:15'00	dB	47.0	54.7	50.6	40.3
@CAL3301	10/08/11	02:44'50	A	Fast	00:15'00	dB	54.5	63.4	56.2	40.8
@CAL3302	10/08/11	02:59'50	A	Fast	00:15'00	dB	50.8	57.2	50.4	40.4
@CAL3303	10/08/11	03:14'50	A	Fast	00:15'00	dB	47.3	54.6	51.3	41.0
@CAL3304	10/08/11	03:29'50	A	Fast	00:15'00	dB	48.0	56.8	51.6	40.8
@CAL3305	10/08/11	03:44'50	A	Fast	00:15'00	dB	47.7	55.0	51.4	40.7
@CAL3306	10/08/11	03:59'50	A	Fast	00:15'00	dB	48.4	56.7	52.3	41.2
@CAL3307	10/08/11	04:14'50	A	Fast	00:15'00	dB	50.5	59.3	54.0	41.3
@CAL3308	10/08/11	04:29'50	A	Fast	00:15'00	dB	49.5	57.7	52.8	41.4
@CAL3309	10/08/11	04:44'50	A	Fast	00:15'00	dB	50.2	58.2	53.8	41.7
@CAL3310	10/08/11	04:59'50	A	Fast	00:15'00	dB	50.1	56.5	53.9	42.8
@CAL3311	10/08/11	05:14'50	A	Fast	00:15'00	dB	50.2	56.8	54.2	43.1
@CAL3312	10/08/11	05:29'50	A	Fast	00:15'00	dB	52.0	58.8	55.5	44.2
@CAL3313	10/08/11	05:44'50	A	Fast	00:15'00	dB	53.9	61.6	57.2	45.9
@CAL3314	10/08/11	05:59'50	A	Fast	00:15'00	dB	54.3	61.0	57.2	48.0
@CAL3315	10/08/11	06:14'50	A	Fast	00:15'00	dB	54.0	61.3	57.4	47.4
@CAL3316	10/08/11	06:29'50	A	Fast	00:15'00	dB	56.6	62.3	58.9	52.0
@CAL3317	10/08/11	06:44'50	A	Fast	00:15'00	dB	55.9	61.0	58.8	50.0
@CAL3318	10/08/11	06:59'50	A	Fast	00:15'00	dB	57.1	63.2	59.8	52.3
@CAL3319	10/08/11	07:14'50	A	Fast	00:15'00	dB	59.7	68.6	61.7	54.6
@CAL3320	10/08/11	07:29'50	A	Fast	00:15'00	dB	63.3	70.4	66.4	58.3
@CAL3321	10/08/11	07:44'50	A	Fast	00:15'00	dB	66.6	74.6	68.3	62.4
@CAL3322	10/08/11	07:59'50	A	Fast	00:15'00	dB	66.2	74.2	68.0	61.6
@CAL3323	10/08/11	08:14'50	A	Fast	00:15'00	dB	68.0	73.8	69.8	64.3
@CAL3324	10/08/11	08:29'50	A	Fast	00:15'00	dB	66.2	73.7	68.4	62.2
@CAL3325	10/08/11	08:44'50	A	Fast	00:15'00	dB	68.2	75.5	70.5	63.5
@CAL3326	10/08/11	08:59'50	A	Fast	00:15'00	dB	67.7	75.0	70.1	62.3
@CAL3327	10/08/11	09:14'50	A	Fast	00:15'00	dB	67.4	74.9	70.0	62.8
@CAL3328	10/08/11	09:29'50	A	Fast	00:15'00	dB	67.5	76.1	70.1	62.4

Callisia Limited
71 Kingsway, London.





Callisia Limited
71 Kingsway, London.



Callisia Limited
71 Kingsway, London.

C



RECEIVED
19 OCT 2011


PKA-RP100KAL

Power Inverter Heat Pump

R410A Wall Mounted System

Advanced inverter technology makes the Mr Slim Power Inverter the number one choice for improving comfort. They provide energy savings of up to 70% annually when compared to a previous non-inverter model. Operating noise has also been reduced thanks to improvements in fan design, while existing pipe work is reusable for easier maintenance and installation.

- New flat panel, compact indoor unit design
- Adjustable louvres for uniform air distribution
- Internal pipe connection to wall mounted unit for easy and neat installation



Pictures not to scale

Product Details

PKA-RP100KAL Indoor Unit

Capacity (kW):	
Heating (Nominal) (Low - High)	11.20 (4.50 - 14.00)
Cooling (Nominal) (Low - High)	10.00 (4.90 - 11.40)
Heating (UK) (Low - High)	9.50 (3.85 - 11.90)
Cooling (UK) (Low - High)	9.20 (4.50 - 10.50)
SHF R410A (Nominal)	0.73
COP / EER (Nominal)	3.61 / 3.45
Energy Label Heating / Cooling	A / A
Width - mm	1170
Depth - mm	295
Height - mm	365
Weight - kg	21
Airflow (m3/min) - Lo-Mi-Hi	20-23-26
Noise (dBA) - Lo-Mi-Hi	41-45-49
Pipe Size Gas mm (in)	15.88 (5/8)
Pipe Size Liquid mm (in)	9.52 (3/8)
Electrical Supply	Fed by Outdoor Unit
Phase	Single
Fuse Rating (BS88) - HRC (A)	6
Interconnecting Cable No. Cores	4


PUHZ-RP100VKA Outdoor Unit

Width - mm	1050
Depth - mm	330+30
Height - mm	1338
Weight - kg	116
Noise (dBA) (Heating / Cooling) - Lo-Hi	51 / 46-49
Electrical Supply	220-240v, 50Hz
Phase	Single
Fuse Rating (BS88) - HRC (A)	32
SystemPower Input (kW) - Heating (Nominal)	3.1
SystemPower Input (kW) - Cooling (Nominal)	2.9
SystemPower Input (kW) - Heating (UK)	2.76
SystemPower Input (kW) - Cooling (UK)	2.47
Starting Current (A)	5
SystemRunning Current (A) - Heating / Cooling	14.15 / 13.25
Mains Cable No. Cores	3
Max Pipe Length (m)	75
Max Height Difference (m)	30
Charge (kg) - 30m	5


Dimensions

PKA-RP100KAL

Front View >




Side View >




PUHZ-RP100VKA


Upper View >



Front View >



Right Side View >




Telephone: 01707 282880

Email: air.conditioning@meuk.mee.com Website: <http://www.mitsubishielectric.co.uk/aircon>

Mitsubishi Electric reserves the right to make any variation in technical specification to the equipment described, or to withdraw or replace products without prior notification or public announcement.

Tel:

Fax:



RECEIVED
19 OCT 2011



410

SEZ-KD50VAQ

Inverter Heat Pump

R410A Ceiling Concealed Ducted System

Designed for homes, offices, restaurants or shops, the SEZ series operates at low noise levels and is virtually invisible when installed within a suspended ceiling. Its low unit height and lightweight design also helps to make installation easier and more convenient.



Pictures not to scale

Product Details

SEZ-KD50VAQ Indoor Unit


Capacity (kW):	
Heating (Nominal) (Low - High)	6.40 (1.10 - 7.20)
Cooling (Nominal) (Low - High)	5.10 (1.10 - 5.60)
Heating (UK) (Low - High)	5.30 (0.90 - 6.00)
Cooling (UK) (Low - High)	5.05 (1.10 - 5.55)
SHF R410A (Nominal)	0.76
COP / EER (Nominal)	3.54 / 3.11
Energy Label Heating / Cooling	B / B
Width - mm	990
Depth - mm	700
Height - mm	200
Weight - kg	23
Airflow (m ³ /min) - Lo-Mi-Hi	10-12.5-15
External Static Pressure Pa - Lo-Mid-Hi	5-15-50
Noise (dBA) - Lo-Mi-Hi	30-34-37
Pipe Size Gas mm (in)	12.7 (1/2)
Pipe Size Liquid mm (in)	6.35 (1/4)
Electrical Supply	Fed by Outdoor unit
Phase	Single
Fuse Rating (BS88) - HRC (A)	6
Interconnecting Cable No. Cores	4

SUZ-KA50VA2 Outdoor Unit


Width - mm	840
Depth - mm	330
Height - mm	850
Weight - kg	53
Noise (dBA) (Heating / Cooling)	55 / 53
Electrical Supply	220-240v, 50Hz
Phase	Single
Fuse Rating (BS88) - HRC (A)	20
System Power Input (kW) - Heating (Nominal)	1.81
System Power Input (kW) - Cooling (Nominal)	1.64
System Power Input (kW) - Heating (UK)	1.65
System Power Input (kW) - Cooling (UK)	1.31
Starting Current (A)	16.7
System Running Current (A) - Heating / Cooling	7.05 / 7.45
Mains Cable No. Cores	3
Max Pipe Length (m)	30
Max Height Difference (m)	30
Charge (kg) - 7m	1.6

Dimensions

SEZ-KD50VAQ



SUZ-KA50VA2




Telephone: 01707 282880

Email: air.conditioning@meuk.mee.com Website: <http://www.mitsubishielectric.co.uk/aircon>


Tel:

Fax:



Mitsubishi Electric reserves the right to make any variation in technical specification to the equipment described, or to withdraw or replace products without prior notification or public announcement.


All dimensions must be checked on site & not scaled from this drawing.




PROPOSED ROOF LAYOUT 1:50

PROPOSED LOCATION FOR NEW SPLIT AC UNIT CONDENSERS SERVING 4TH AND 5TH FLOOR. DIMENSION APPROX: 840wx330dx880h. WEIGHT: 55KG

CONDENSERS TO BE MOUNTED ON BIGFOOT FRAME. MINIMUM HEIGHT OF BIGFOOT FRAME IS 215mm HIGH.




PROPOSED ELEVATION OF NEW CONDENSERS SECTION "A"- "A" SCALE 1:20



PROPOSED ELEVATION OF NEW & EXISTING CONDENSERS SECTION "B"- "B" SCALE 1:50

EXISTING CONDENSERS SERVING WHOLE BUILDING MOUNTED ON BIGFOOT FRAME.



PICTURE OF NEW SPLIT AC UNIT CONDENSERS SERVING 4TH AND 5TH FLOOR. DIMENSION APPROX: 840wx330dx880h. WEIGHT: 55KG

E	ELEVATION OF NEW AND EXISTING CONDENSERS ADDED.	28.09.11
D	PICTURE OF BIGFOOT ADDED AND DIMENSION ADDED.	02.09.11
C	PICTURE OF CONDENSER ADDED.	18.08.11
B	CONTRACT NUMBER ADDED PROPOSED REFRIGERATION ROUTE ADDED.	16.08.11
A	ELEVATION ADDED TO LAYOUT FOR PLANNING PURPOSES.	02.08.11
Rev.	Description.	Date.

Callisia

Callisia Limited
443 Stroude Road,
Virginia Water,
Surrey,
GU25 4BU

T: 01344 845 000
F: 01344 845 757
E: info@callisia.co.uk
W: www.callisia.co.uk

Job Title:
**71 KINGSWAY
LONDON**

Drawing Title:
ROOF LAYOUT
PROPOSED MECHANICAL LAYOUT

Scale: A1
1:50

Date:
SEPT 2011


Drawn:
ZT

Checked:


Drawing Number:
2611/M/03

Rev.
E

19 OCT 2011



FOR PLANNING


NO.	DATE	REVISIONS	AMEND
APPROVED BY:			DATE:
CLIENT: MITSUBISHI			
SITE ADDRESS: 71 KINGSWAY LONDON WC2B 6			
DRAWING NAME: EXISTING ROOF PLAN			
DRAWN:	ASD	SCALE:	1:50@A1
CHECKED:		DATE:	
<div style="text-align: center;">  <p>Building on your design</p> </div> <p>20 Balderton Street London W1K 6TL</p> <p>Tel: +44 (0)20 7495 1885 Email: info@interiorsgroup.co.uk</p>			
DRAWING REF.		5224 EXISTING	



1



2



3



4

71 KINGSWAY: EXISTING ROOF

